



New Brunswick Innova® 2100/2150 Shaker

Operating manual

Copyright © 2014 Eppendorf AG, Germany. No part of this publication may be reproduced without the prior permission of the copyright owner.

Eppendorf® and the Eppendorf logo are registered trademarks of Eppendorf AG, Germany.

New Brunswick™ and the New Brunswick™ logo are trademarks of Eppendorf AG, Germany.

Innova® is a registered trademark of Eppendorf, Inc., USA.

Trademarks are not marked in all cases with ™ or ® in this manual.

Table of contents

1	Operating instructions	5
1.1	Using this manual	5
1.2	Danger symbols and danger levels	5
1.2.1	Hazard symbols	5
1.2.2	Degrees of danger	5
1.3	Symbols used	6
2	Safety	7
2.1	User profile	7
2.2	Warnings for intended use	7
3	Product description	9
3.1	Main Illustration	9
3.2	Features	10
3.2.1	Operation	10
3.2.2	Alarms	11
3.2.3	Platforms and accessories	11
3.3	Universal power module	11
3.4	Control panel	11
3.4.1	LED display	12
3.4.2	Keypad	13
3.4.3	Status indicators	13
3.4.4	Function indicators	13
3.5	Platform assemblies	13
3.6	Optional features	14
3.6.1	Temperature/monitor option	14
3.6.2	Capacity upgrade option	14
3.6.3	Quick change platform option	14
3.7	Heavy duty construction	14
3.7.1	Bearings	14
3.7.2	Motor	14
3.7.3	Triple eccentric drive	15
3.8	Electronic boards	15
4	Installation	17
4.1	Unpacking	17
4.2	Checking voltage configuration	17
4.3	Space requirements	17
4.4	Electrical connections	18
4.5	Install the platform	19
4.5.1	Quick change option	19
4.6	Install flask clamps	19
5	Operation	21
5.1	Getting started	21
5.2	Continuous/unlimited run	21
5.3	Checking setpoints	21
5.4	Timed functions	21

Table of contents

New Brunswick Digital Platform Shaker Innova® 2100/2150
English (EN)

5.4.1	Setting the timer	21
5.4.2	Canceling the timer	22
5.5	Alarm functions	22
5.5.1	Stopping the alarm	22
5.5.2	Deactivating the alarm	22
5.5.3	Reactivating the alarm	22
5.6	Total running time	23
5.7	Temperature monitor option	23
5.8	Recorder adaptation	24
6	Maintenance	25
6.1	Routine maintenance	25
6.2	Cleaning external and internal surfaces	25
6.3	Fuse replacement	25
7	Technical data	27
7.1	Specifications	27
7.1.1	Innova 2100	27
7.1.2	Innova 2150	28
8	Ordering information	31
8.1	Service parts 2100/2150	31
8.2	Platforms	31
8.3	Accessory flask clamps	32
8.4	Clamp hardware	32
8.5	Optional kits	33
8.5.1	Temperature/Monitor option	33
8.5.2	Quick change platform kit	33
8.5.3	Capacity upgrade option	34
9	Transport, storage and disposal	35
9.1	Disposal	35
10	Certifications	37
	Index	39

1 Operating instructions

1.1 Using this manual

- ▶ Carefully read this operating manual before using the device for the first time.
- ▶ Also observe the operating manual enclosed with the accessories.
- ▶ The operating manual should be considered as part of the product and stored in a location that is easily accessible.
- ▶ When passing the device on to third parties, be sure to include this operating manual.
- ▶ If this manual is lost, please request another one. The latest version can be found on our website www.eppendorf.com (international) or www.eppendorfnna.com (North America).

1.2 Danger symbols and danger levels

1.2.1 Hazard symbols

	Electric shock		Hazard point
	Crushing		Material damage
	Heavy loads		Explosion

1.2.2 Degrees of danger

The following degree levels are used in safety messages throughout this manual. Acquaint yourself with each item and the potential risk if you disregard the safety message.

DANGER	<i>Will</i> lead to severe injuries or death.
WARNING	<i>May</i> lead to severe injuries or death.
CAUTION	May lead to light to moderate injuries.
NOTICE	May lead to material damage.

Operating instructions

New Brunswick Digital Platform Shaker Innova® 2100/2150
English (EN)

1.3 Symbols used

Example		Meaning
	▶	You are requested to perform an action.
	1. 2.	Perform these actions in the sequence described.
	•	List.
		References useful information.

2 Safety

2.1 User profile



CAUTION!

- ▶ This equipment must be operated as described in this manual. If operational guidelines are not followed, equipment damage and personal injury can occur. Please read the entire Operating Manual before attempting to use this unit.
- ▶ Do not use this equipment in a hazardous atmosphere or with hazardous materials for which the equipment was not designed.
- ▶ Eppendorf is not responsible for any damage to this equipment that may result from the use of an accessory not manufactured by Eppendorf.

2.2 Warnings for intended use



WARNING! Heavy!

- ▶ Do not attempt to lift the Innova 2100/2150 Shaker by yourself.
- ▶ Ask for assistance or use suitable equipment when raising or handling the device.



WARNING! Risk of explosion and injury or death!

- ▶ Do not use equipment with flammable substances or organisms with flammable by-products.



WARNING! Risk of electric shock and/or damage to the device!

- ▶ Use a grounded power supply.



WARNING! Risk of electric shock and/or damage to the device!

- ▶ Before cleaning device, turn off and unplug from mains/power supply.



WARNING! Risk of electric shock when replacing fuses!

- ▶ Turn off shaker and disconnect from mains/power supply.



CAUTION!

- ▶ A minimum load is required to safely operate the Innova 2100/2150.
- ▶ Without a minimum load there is risk of instability that may cause serious injuries.

Safety

New Brunswick Digital Platform Shaker Innova® 2100/2150
English (EN)

3 Product description

3.1 Main Illustration




Fig. 3-1: Innova 2100/2150 front view

- 1 Temperature/monitor RTD probe and bracket (not shown)
Optional
- 2 Platform
- 3 Control panel



Unless otherwise indicated, all drawings represent both Innova 2100 and Innova 2150 models.

Product description

New Brunswick Digital Platform Shaker Innova® 2100/2150
English (EN)




Fig. 3-2: Innova 2100/2150 rear view

1 RTD connectos

Optional

2 Fuse

Control circuit

3 On/Off switch

4 Voltage selector

5 Universal power module

6 Power cord connection

7 Chart recorder connection

Optional

8 Cover plate

3.2 Features

The Innova 2100/2150 is a benchtop or floor shaker utilizing a triple eccentric counter-balanced drive to provide horizontal plane rotary motion in a 19 mm (3/4 in) circular orbit. A Proportional/Integral (PI) Microprocessor controller with instantaneous digital feedback controls the speed over a range of 25 – 500 rpm.

3.2.1 Operation

The shaker may be operated either continuously or in a timed mode via a programmable timer for shaking periods of 0 hr 1 min – 99.9 hr. A Temperature Monitoring option is available for the measurement, display and documentation of sample temperature.

3.2.2 Alarms

The Innova 2100/2150 is equipped with audible and visible alarms that alert the user to the following conditions:

- The end of a timed run
- Deviation of shaking speed outside the tolerance limits

3.2.3 Platforms and accessories

To accommodate customer needs, a wide variety of platforms can be used with the Innova 2100/2150. Dedicated platforms are available for a variety of flask sizes. Universal platforms are also available (see *Platforms on p. 31*).

3.3 Universal power module

The power module contains a voltage card and fuse holder which are used to select the appropriate voltage and fusing. This universal power entry system adapts to worldwide power requirements. Voltage and fusing has been set prior to shipment. Innova shakers are available in 100 V, 120 V, 220 V and 240 V configurations that accommodate both 50 and 60 Hz frequencies.



WARNING! Risk of electric shock and/or damage to device!

- ▶ Do not plug the shaker into a power source until you check the voltage and frequency settings.
 - ▶ Check the voltage selection on the power entry module against the serial tag located either on the side or rear of the device.
-

3.4 Control panel

The control panel is located on the front of the instrument. It serves as the operator interface, and consists of:

- A START/STOP key
- An up arrow (▲)
- A down arrow (▼)
- A SELECT key
- A 3-digit LED display that provides numeric values, and some letter codes
- 4 function indicator lights
- 4 status indicator lights

Product description

New Brunswick Digital Platform Shaker Innova® 2100/2150
English (EN)




Fig. 3-3: Control panel

1 Status indicators

3 Function indicators

2 LED display

4 Keypad

3.4.1 LED display

The Innova control panel has a 3-digit LED display. During normal shaker operation, the display will indicate:

- Shaker status (ON/OFF)
- Shaking speed
- Setpoints
- Hours remaining (timed run)
- Measured temperature (when temperature/monitor option is installed)

3.4.2 Keypad

START/STOP	- Starts and stops the drive - Activates or stops timer when timed run is desired
▲ ▼ Keys	- Adjusts the setpoint of a displayed parameter up or down - Used to enter the SET mode for setpoint changes
SELECT	- Changes the displayed parameter - Temperature (°C) cannot be selected unless the temperature/remote monitoring option is installed.

3.4.3 Status indicators

MAINT	Illuminates after 10000 hours of use. Indicates need for routine maintenance (see <i>Routine maintenance on p. 25</i>)
SET	Illuminates to indicate that: - Shaker is in SET mode - Setpoints are being displayed - Setpoints can be altered
TIME	Illuminates to indicate that the timer is in operation
MUTE	Illuminates to indicate that the audible alarm is disabled

3.4.4 Function indicators

RPM	Revolutions per minute shaking speed
HRS	Time remaining
°C	Temperature function (only activated if the temperature/monitor option is installed)
*	This function is not active in the Innova 2100/2150

3.5 Platform assemblies

Neither the Innova 2100 nor the 2150 can be used without a platform. One must be purchased and installed on your shaker prior to operation (see *Platforms on p. 31*).

The Innova 2100 can be used with a wide range of New Brunswick 28 cm x 33 cm (11 in x 13 in) platforms, which will accept a variety of clamps for flasks, test tubes, etc.

The Innova 2150 can accommodate an even wider range of New Brunswick 30.5 cm x 40.6 cm (12 in x 16 in) platforms, which will accept a variety of clamps for flasks, test tubes, etc.

Product description

New Brunswick Digital Platform Shaker Innova® 2100/2150
English (EN)

3.6 Optional features

3.6.1 Temperature/monitor option

A Temperature/Monitor Option is available for installation on the Innova 2100/2150. The ambient temperature or the temperature of the liquid in any vessel can be measured using the RTD electronics-based measuring device supplied with this option.

When the option is installed, the LED will display the measured temperatures in 0.1 °C increments. This option also allows the connection of a chart recorder so that shaking speed and temperature can be documented. The analog output for shaking speed is 0 – 5 V, 1 V per 100 rpm. For temperature, the output is 0 – 5 V (0.05 V per °C).

The output can also be connected to a data logging computer with an analog data acquisition card.

3.6.2 Capacity upgrade option

It is possible to significantly increase the capacity of your Innova 2100 Shaker with an available capacity upgrade package (M1194-9926). This option will convert an Innova 2100 to an Innova 2150 simply and easily.

This package consists of appropriate counterweights, outrigger feet and hardware. Large capacity Innova 2150 platforms must be used with the Innova 2150 configuration (see *Platforms on p. 31*).

3.6.3 Quick change platform option

This accessory enables the user to snap in platforms without tools or hardware. This is especially handy for those users who change platforms frequently. The kit includes a subplatform with spring clips, an extra counterweight, and hardware for installation. This option is available for both the Innova 2100 (M1192-9901) and the Innova 2150 (M1194-9927).

A speed range of 25 – 400 rpm is recommended when this option is installed.

3.7 Heavy duty construction

3.7.1 Bearings

Innova shakers employ sealed lubricated ball bearings of the highest quality. Sealed bearings minimize the generation of airborne particulates which may be disadvantageous in clean rooms or controlled environment areas.

3.7.2 Motor

The Innova 2100/2150 Shaker use a brushless ball bearing DC motor. This low profile motor provides high torque along with quiet, efficient operation and low maintenance. The rugged motor has a rating of 1/15 horsepower.

3.7.3 Triple eccentric drive

The drive mechanism (see following Figure) uses a counterweight system to stabilize the rotary motion produced during operation. When the work load moves in one direction, opposing forces are generated to stabilize the shaker. This action will help eliminate the problem of “walking” which may occur with less precisely balanced instruments. Vibration is minimized and the life of the unit is extended.




Fig. 3-4: Counterbalanced drive mechanism

- | | |
|-------------------------|-----------------------------|
| 1 Upper bearing housing | 5 Pulley with counterweight |
| 2 Shaker platform | 6 Eccentric drive shaft |
| 3 Upper ball bearing | 7 Lower bearing housing |
| 4 Ball bearing | |

3.8 Electronic boards

The main control board for Innova shakers has the following functions:

- Non-volatile memory for storage of key parameters during power interruption;
- Speed sensing, electronic commutation, and power control for the brushless DC drive motor;
- Maintains an elapsed running time clock;

Product description

New Brunswick Digital Platform Shaker Innova® 2100/2150
English (EN)

- Contains firmware for shaker control as well as recognition of an expansion connector for option modules;
- Provides an operator interface via displays, audible alarm, and connection to the keypad module (keypad buttons and display graphics).

The optional Temperature Monitor module is designed to “piggyback” onto the main board via an expansion connector. It has the following functions:

- Control of analog power supplies;
- Signal conditioning of RTD sensor readings;
- Provide remote monitoring capabilities by supplying analog outputs for speed and temperature that are compatible with chart recorders and analog data acquisition systems.

4 Installation

4.1 Unpacking

Upon unpacking the unit, inspect it carefully for any apparent damage that may have occurred during transit. Immediately report any damage to the carrier and to the Eppendorf Service Department. Do not discard the crate or packing material.



VERY IMPORTANT: There are 2 small plastic straps that hold the bearing housing in place for shipping. Be sure to remove these 2 straps before operation.

4.2 Checking voltage configuration



WARNING! Risk of electric shock and/or damage to device!

- ▶ Do not plug the shaker into a power source until you check the voltage and frequency settings.

Do not plug your shaker into the power source until you determine that voltage of your unit (by checking the voltage indicator and label on the rear of the unit) matches your electrical service.

4.3 Space requirements

It is essential that the unit be situated in an area where there is sufficient space for the shaker and platform to clear walls and other potential obstructions during operation.

The dimensions, including a platform but excluding glassware, are:

Model	Width	Depth	Height
Innova 2100 without capacity upgrade	48 cm (19 in)	55.5 cm (21 7/8 in)	17 cm (6 3/8 in)
Innova 2150 and 2100 with capacity upgrade	48 cm (24 in)	55.5 cm (21 7/8 in)	17 cm (6 3/8 in)

Installation

New Brunswick Digital Platform Shaker Innova® 2100/2150
English (EN)

The required surface area required for operation is:

Model	Width	Depth
Innova 2100 without capacity upgrade	56 cm (22 in)	61 cm (24 in)
Innova 2150 and 2100 with capacity upgrade	68.5 cm (27 in)	61 cm (24 in)

**WARNING!**

- ▶ Do not position the equipment so that it is difficult to operate the disconnecting device (main plug).
- ▶ For service reasons and for cases of emergencies, sufficient space must be provided for easy access to the main power cord/power switch (located at the back of the unit).

4.4 Electrical connections

**WARNING! Risk of electric shock and/or damage to device!**

- ▶ Use a grounded power supply.

**CAUTION!**

- ▶ A detachable main power cord has been provided with your unit.
- ▶ Only use the cord provided with the unit.

Before making electrical connections, be sure to follow these instructions:

1. Check the voltage selector in the Universal Power Module at the rear of the unit to ensure that it is set to the appropriate voltage.
2. Remove the CAUTION label from the universal power module.
3. Make sure the plastic straps have been removed from the upper bearing housing.
4. Make sure the power switch on the back of the unit is set in the OFF position.

ONLY THEN:

5. Connect the power cord to the universal power module and to a grounded electrical outlet.

4.5 Install the platform



CAUTION! Risk of damage to the device!

- ▶ Never run the shaker without a properly installed platform.

A platform (purchased separately) must be installed on the unit prior to use.

1. Set the power switch in the Off position.
2. Using the 7/32 inch allen key provided, remove the four Allen head platform screws installed in the subplatform of the bearing housing (under the shaker). One of the four screws has a tag so you can identify it. Set them aside for reuse.
3. Place the platform on top of the shaker's subplatform. Be sure to use the proper size platform for your particular model shaker (see *Platforms on p. 31*).
4. Reinstall and tighten the four platform screws (previously set aside) with the hex wrench to secure the platform.

4.5.1 Quick change option

If the Quick Change Platform option is installed:

1. Slip the appropriately sized platform between the side guides and push the platform to the rear retainer.
2. Press down on the front edge of the platform.
The platform should snap down into place and be retained by the springs.
3. Check that the rear edge of the platform is engaged under the bend of the rear clip.

4.6 Install flask clamps



WARNING!


- ▶ Do not overfill flasks (i.e., more than 50% of the flask volume).

Flask clamps purchased for use with universal platforms require installation. Clamps are installed by securing the base of the clamp to the platform. Flat head screws of different lengths and thread pitch are used. Consult the Flask Clamp Hardware reference tables (see *Clamp hardware on p. 32*) to identify the proper screw for your shaker application by reference to the head style.

Installation

New Brunswick Digital Platform Shaker Innova® 2100/2150
English (EN)

All clamps are shipped complete with hardware. Clamps for 2 – 6 L flasks are shipped with an additional girdle to keep the flasks in place. To install 2 – 6 L clamps:



1. Place each clamp on the platform, secure the clamp in place with the correct type and number of screws.
2. Place the loose girdle around the upper portion of clamp body so that it is held in place by the legs of the clamp.
3. Insert the flask into the clamp.

Fig. 4-1: Double girdle clamp



The instructions and illustration above also apply to 2800 ml Fernbach flask clamps.

1 Clamp mounting holes

With screws

2 Upper girdle with girdle tubes

Secures flask within the clamp

3 Lower girdle with girdle tubes

Prevents flask from spinning

4 Clamp body (legs and base)

5 Operation

5.1 Getting started

To start the instrument, turn the ON/OFF switch on the back of shaker to the ON position.

If the shaker is running, the LED display will track the speed as it accelerates to the last entered setpoint.

The shaking action may be stopped or started by pressing the START/STOP key on the control panel.

5.2 Continuous/unlimited run

1. If the LED displays OFF, press the START/STOP key.
2. Press the SELECT key to illuminate RPM.
3. Press either ▲ or ▼ to enter SET mode (SET indicator will illuminate).
4. Set the speed by using the ▲ or ▼ key until the desired setpoint is displayed.
Holding the ▲ or ▼ key will cause the setting to change more rapidly.

The setpoint may be changed at any time during a run without stopping the shaker by following steps 2 – 4. During speed changes, the alarm may sound until the speed returns to within 5 rpm of the setpoint.

5.3 Checking setpoints

To check any setpoint:

1. Press the SELECT key to illuminate the desired indicator.
2. Press either ▲ or ▼ to enter the SET mode and display the current setpoint.



Holding the ▲ or ▼ key for more than 0.5 s causes the setpoint to change. Should this occur, resetting will be necessary.

5.4 Timed functions

The shaker may be programmed to stop automatically after a preset time period of 0.1 to 99.9 hr. There must be power to the shaker in order to set the timer. However, a timed run can be initiated while the unit is either shaking or stopped.

5.4.1 Setting the timer

1. Press the SELECT key to light HRS.
2. Press either ▲ or ▼ to enter the SET mode, then set a time period of 0.1 – 99.9 hr.
3. While SET light is illuminated, press the START/STOP key to program the time (and start the run).

The TIME indicator will illuminate and remain on for the duration of the run. At the end of the timed run:

- The display will read OFF
- The time indicator will flash
- The audible alarm will sound

The setpoint may be changed during a run without stopping the shaker by following steps 1 and 2 above.

5.4.2 Canceling the timer

To cancel the timer **without** stopping the shaker:

1. Press the SELECT key to illuminate HRS.
2. Press either ▲ or ▼ to enter the SET mode, then immediately press the START/STOP key.
The Time indicator will go out and the display will read "OFF".

5.5 Alarm functions

Innova shakers have an audible alarm which is activated at predetermined times. It is possible to deactivate and reactivate the alarm, according to your needs.

5.5.1 Stopping the alarm

When the alarm sounds, you can stop it by pressing the SELECT key and changing to any other function.

5.5.2 Deactivating the alarm

The alarm may be deactivated in the following way:

1. Press SELECT to illuminate HRS.
2. **Simultaneously** press the ▲ and ▼ keys.
The SET and MAINT indicators will flash.
3. While the SET and MAINT indicators are flashing, press the START/STOP key.
The MUTE indicator will illuminate to advise that the audible alarm is deactivated.

5.5.3 Reactivating the alarm

The alarm may be reactivated in the following way:

1. Press SELECT to illuminate HRS.
2. **Simultaneously** press the ▲ and ▼ keys.
The SET and MAINT indicators will flash.
3. While the SET and MAINT indicators are flashing, press the START/STOP key.

The MUTE indicator will extinguish to advise that the audible alarm is active.



The shaker may be stopped or started by pressing the START/STOP key. When starting, the unit will automatically return to the last function and speed setting.
The audible alarm will sound until the speed is within 5 rpm of the setpoint.

The alarm will **not** sound while the shaker is accelerating immediately following turning on the power.

5.6 Total running time

The control modules of the Innova shakers keep track of the time the shaker has been on, tracking the hours of usage.

To display the accumulated running time:

1. Select HRS using the SELECT key.
2. Simultaneously press the ▲ and ▼ keys.

The SET and MAINT indicators will flash and the accumulated running time will be displayed in hundreds of hours (i.e., "02" equals 200 hours; "102" equals 10,200 hours). This display will continue for 10 seconds and then default to the previous mode readout.



After 10,000 hours of operation, the MAINT indicator will light. Preventive maintenance is recommended at this point. The Eppendorf Service Technician will deactivate the light when the technician performs the required maintenance.

5.7 Temperature monitor option

This option consists of an internal electrical interface, an RTD temperature probe and an analog output for chart recorder or data acquisition system. When this option is installed, either the ambient temperature or the temperature of any vessel on the shaker platform can be measured with the probe:

1. Remove the probe from its holder and insert it into the vessel to be monitored.
2. Use the SELECT key to indicate °C.



The °C indicator will only function when the temperature/monitor option is installed.

Since the Temperature Monitor option does not provide temperature control, any attempt to enter a temperature setpoint results in *Err* ("Error") being displayed.

Operation

New Brunswick Digital Platform Shaker Innova® 2100/2150
English (EN)

5.8 Recorder adaptation

To record speed or temperature, an auxiliary recorder (not supplied, but available from Eppendorf) can be used. The recorder should have the following capabilities:




Fig. 5-1: Recorder connector as seen from the rear of the unit

- For speed, each channel should have signal conditioning that accepts 0 – 5 V input.
- For temperature, each channel should have a signal conditioning that accepts 0 – 5 V input
- A mating connector is required on the recorder cable (not supplied, but available from Eppendorf). This is a 9-pin male D subminiature connector, AMP Amplitite HDP-20 series or equivalent.

Pin number	Signal name	Scale
6	Speed	1 V = 100 rpm
2	Ground	
7	Temperature	1 V = 20 °C
3	Ground	

6 Maintenance



WARNING!

- ▶ Before performing any service, turn off the power, using the ON/OFF switch on the rear panel, and disconnect the power cord.
-

6.1 Routine maintenance

No routine maintenance is required for the Innova 2100/2150 Shaker.

The MAINT indicator light illuminates at the end of 10000 hours of use. At that time, contact your local Eppendorf Service Engineer, or call the Eppendorf Service Department. This periodic maintenance will keep your unit in premium condition.

6.2 Cleaning external and internal surfaces



WARNING! Personnel injury and equipment damage!

- ▶ When cleaning the unit, always turn off the shaker and disconnect the power cord from the power supply.
-

The unit may be cleaned using a damp cloth or any standard household or laboratory cleaner to wipe down its outer surfaces. Do not use abrasive or corrosive compounds to clean this instrument, as they may damage the unit.

6.3 Fuse replacement



WARNING! Risk of electric shock when replacing fuses!

- ▶ Turn off shaker and disconnect from mains/power supply.
-



CAUTION!

- ▶ A detachable main power cord has been provided with your unit.
 - ▶ Only use the cord provided with the unit.
-

Maintenance

New Brunswick Digital Platform Shaker Innova® 2100/2150
English (EN)

To replace fuses (without changing the fusing arrangement):

1. Disconnect the unit from the power source.
2. Using a small screwdriver, remove the cover/fuse block located on the rear of the unit.
3. Remove the old fuse.
4. Insert a new one of the same type.
5. Replace the cover/fuse block into the power module.



Spare fuses are supplied with the unit.




Fig. 6-1: Power entry module (2000/2050)

- | | |
|-------------------------|--------------|
| 1 Housing | 4 Cover |
| 2 Voltage selector card | 5 Fuse block |
| 3 Indicator pin | |

7 Technical data

7.1 Specifications

7.1.1 Innova 2100

Tab. 7-1: Shaking

Speed	25 – 500 rpm
Control accuracy	±1 rpm
Indication	3-Digit LED, in 1 rpm increments
Stroke/Orbit	1.9 cm (¾ in)
Setpoint and control	Digital adjustment with PI microprocessor control and instantaneous visual feedback.
Operating ambient	0 – 60 °C, 90 % humidity, non-condensing. Up to 2000 m.
Timer	Programmable shaking periods from 0.1 to 99.9 hours by a digital timer that shuts off at the end of period and energizes status light. Timer counts down and digital display indicates remaining time. Can be deactivated for continuous operation. Additionally, unit will display total accumulated running time for service information.
Alarms	Warning signal (audible and visual) indicates when shaking speed deviates more than 5 rpm from setpoint and when timed operation has expired. Audible alarm can be deactivated/activated by the operator.
LED display	Indicates speed, running time alarm conditions, and displays readout of internal clock (actual accumulated operating time).
Automatic restart	Automatic restart after power is restored, indicated by flashing display.
Setpoint retention	All setpoints and operating status are retained in non-volatile memory.
Drive	Triple-eccentric counterbalanced ball bearing drive.
Drive motor	1/15 hp 3-phase brushless ball bearing DC motor.
Electrical	100 V / 120 V / 220 V / 240 V All voltages 50/60 Hz, 80 VA. Universal power entry system adapts to U.S. or international requirements.
Electrical protection	Main fuses in power entry module. Control circuits provided with separate fuse.
Dimensions	Width: 48 cm (19 in) with knobs Depth: 55.5 cm (21 7/8 in) Height: 17 cm (6 ¾ in)
Platform	46 × 46 cm (18 × 18 cm)
Weight	Net: 34.5 kg (76 lb) Gross: 54.5 kg (120 lb)
Cabinet	Heavy gauge steel, phosphate coated, and texture painted.
Remote monitoring (optional)	0 – 5 V chart recorder output for speed: 1 V per 100 rpm. Accuracy ±25 mV.
Temperature monitor (optional)	RTD digital temperature monitor displays individual flask or ambient temperature in 0.1 °C increments. Chart recorder output provided.

Technical data

New Brunswick Digital Platform Shaker Innova® 2100/2150

English (EN)



At 25 – 400 rpm, the unit will perform to specifications with up to ± 10 % line voltage fluctuation. To attain speed accuracy at 401 – 500, the line voltage cannot be lower than 5 % of the rated voltage.



The Innova 2100 can be upgraded to a larger capacity platform with a kit that converts this shaker to an Innova 2150. This kit can be installed in the field.

7.1.2 Innova 2150

Tab. 7-2: Shaking

Speed	25 – 500 rpm
Control accuracy	± 1 rpm
Indication	3-Digit LED, in 1 rpm increments
Stroke/Orbit	1.9 cm ($\frac{3}{4}$ in)
Setpoint and control	Digital adjustment with PI microprocessor control and instantaneous visual feedback.
Operating ambient	0 – 60 °C, 90 % humidity, non-condensing. Up to 2000 m
Timer	Programmable shaking periods from 0.1 to 99.9 hours by a digital timer that shuts off at the end of period and energizes status light. Timer counts down and digital display indicates remaining time. Can be deactivated for continuous operation. Additionally, unit will display total accumulated running time for service information.
Alarms	Warning signal (audible and visual) indicates when shaking speed deviates more than 5 rpm from setpoint and when timed operation has expired. Audible alarm can be deactivated/activated by the operator.
LED display	Indicates speed, running time alarm conditions, and displays readout of internal clock (actual accumulated operating time).
Automatic restart	Automatic restart after power is restored, indicated by flashing display.
Setpoint retention	All setpoints and operating status are retained in non-volatile memory.
Drive	Triple-eccentric counterbalanced ball bearing drive.
Drive motor	1/15 hp 3-phase brushless ball bearing DC motor.
Electrical requirements	100 / 120 / 220 / 240 VAC, 50/60 Hz. 35 VA universal power entry system adapts to U.S. or international needs.
Electrical protection	Main fuses in power entry module. Control circuits provided with separate fuse.
Dimensions	Width: 48 cm (19 in) Depth: 55.5 cm (21 $\frac{1}{4}$) Height (to platform surface): 17 cm (6 $\frac{3}{8}$ in)
Platform	46 × 61 cm (18 × 24 in)
Weight	Net: 36 kg (80 lb) Gross: 57 kg (125 lb)
Cabinet	Heavy gauge steel, phosphate coated and texture painted.

Remote monitoring (optional)	0 – 5 V chart recorder output for speed: 1 V per 100 rpm. Accuracy ± 25 mV.
Temperature monitor (optional)	RTD digital temperature monitor displays individual flask or ambient temperature in 0.1 °C increments. Chart recorder output provided.



At 25 – 400 rpm, the unit will perform to specifications with up to ± 10 % line voltage fluctuation. To attain speed accuracy at 401 – 500 rpm, the line voltage cannot be lower than 5 % of the rated voltage.

Technical data

New Brunswick Digital Platform Shaker Innova® 2100/2150
English (EN)

8 Ordering information

8.1 Service parts 2100/2150

Part number	Description	Quantity
P0380-3710	5x20 mm / 0.16 A / 250 V / Time Delay - Fuse	1
P0380-3530	3AG Fuse / 1.6A / 250V / Time Delay - Fuse	1
P0420-1610	10 VA Transformer	1
M1191-5300	130 VA Transformer Assembly	1
P0320-0350	2100 µF Capacitor	1
P0460-4091	Diode Bridge	1
P0360-4040	130 V Varistor	2
M1195-4001	Medium Motor Assembly	1
M1190-9940	Main Control P.C.B. Assembly	1
M1190-5000	Membrane Switch Panel	1
P0460-2200	Power Entry Module	1
P0720-2053	Power Cord 120 V 10 A	1
P0720-2021	Power Cord 220 V	1
P0180-0102	Bearing, Sealed, Upper	3
P0180-0101	Bearing Shield, Lower	6
P0700-5242	Belt	1
M1194-6330	Bearing Housing Assembly	1
M1194-8000	Stainless Steel RTD Assembly (Optional)	1
M1194-0050	Innova 2100/2150 Operations Manual	1

8.2 Platforms

Tab. 8-1: Innova 2100 interchangeable platforms (constructed of phenolic composite)

Part number	46 x 46 cm (18 x 18 in) Platform	
	Clamp quantity	Size of glassware
M1194-9909	Utility Carrier	
M1194-9910	Utility Tray	
M1194-9902	Universal Platform	
M1194-9903	64	50mL Erlenmeyer Flask
M1194-9904	34	125mL Erlenmeyer Flask
M1194-9905	25	250/300mL Erlenmeyer Flask
M1194-9906	16	500mL Erlenmeyer Flask
M1194-9907	9	1L Erlenmeyer Flask
M1194-9908	5	2L Erlenmeyer Flask

Ordering information

New Brunswick Digital Platform Shaker Innova® 2100/2150
English (EN)

Tab. 8-2: Innova 2150 platforms (constructed of phenolic composite)

Part number	46 x 61 cm (18 x 24 in) Platform	
	Clamp quantity	Size of glassware
M1194-9921	Utility Carrier	
M1194-9922	Utility Tray	
M1194-9912	Universal Platform	
M1194-9915	80	50mL Erlenmeyer Flask
M1194-9916	48	125mL Erlenmeyer Flask
M1194-9917	35	250/300mL Erlenmeyer Flask
M1194-9918	20	500mL Erlenmeyer Flask
M1194-9919	12	1L Erlenmeyer Flask
M1194-9920	8	2L Erlenmeyer Flask

8.3 Accessory flask clamps

All clamps listed are made of stainless steel.

Catalog number	Clamp type
ACE-105	10 mL Erlenmeyer
ACE-255	25 mL Erlenmeyer
ACE-505	50 mL Erlenmeyer
ACE-125S	125 mL Erlenmeyer
ACE-250S	250 mL Erlenmeyer
ACE-500S	500 mL Erlenmeyer
ACE-1000S	1.0 L Erlenmeyer
ACE-2000S	2.0 L Erlenmeyer
ACE-4000S	4.0 L Erlenmeyer
ACE-6000S	6.0 L Erlenmeyer
ACFE-2800S	2.8 L or 2800 mL Fernbach
ACSB-500S	500 mL Media Bottles
ACSB-1000S	for 1 L Media Bottles

8.4 Clamp hardware

Eppendorf flask clamps are used on a variety of shaker platforms. Flat Phillips and flat head screws of different lengths and thread pitch are used to secure the clamp. The following tables identify the proper screw for your shaker application by reference to the head style.

Tab. 8-3: 10 – 500 mL clamp hardware application chart

Description	Part number	Qty.	Application
10-24 x 5/8 (15.87 mm) flat Phillips (+) head screw	S2116-3101	1	19.05 mm (3/4 in) thick wood platform
10-24 x 5/16 (7.9 mm) flat Phillips (+) head screw	S2116-3051	1	7.9 mm (5/16 in) thick aluminum, phenolic and stainless steel platforms
10-32 x 5/16 (7.9 mm) flat slotted (-) head screw	S2117-3050	1	All stainless steel platforms

Tab. 8-4: 1 – 6 Liter clamp hardware application chart

Description	Part number	Qty.	Application
10-24 x 5/8 (15.87 mm) flat Phillips (+) head screw	S2116-3101	5	19.05 mm (3/4 in) thick wood platform
10-24 x 5/16 (7.9 mm) flat Phillips (+) head screw	S2116-3051	5	7.9 mm (5/16 in) thick aluminum, phenolic and stainless steel platforms
10-32 x 5/16 (7.9 mm) flat slotted (-) head screw	S2117-3050	5	All stainless steel platforms



The 1 – 6 liter chart also applies to 2800 mL Fernbach flask clamps.

8.5 Optional kits

8.5.1 Temperature/Monitor option

The temperature and speed monitoring kit (M1194-9924) allows an Innova 2100 or 2150 to measure and display sample or ambient temperature and to record it on a remote chart recorder or computer. This kit consists of an internal electrical interface, an RTD temperature probe and an analog output for chart recorder or computer. The package does not include a chart recorder.

This kit must be installed by an authorized service technician.

8.5.2 Quick change platform kit

The easy-loading Quick Change Platform enables users of the Innova 2100 or Innova 2150 to snap in or out any platform of an appropriate size, without the use of tools or hardware.

Quick Change Platform Kit		
Innova 2100	Kit #M1192- 9901	46 × 46 cm (18 × 18 in) platforms
Innova 2150	Kit #M1194- 9927	46 × 61 cm (18 × 24 in) platforms

This kit should be installed by an authorized service technician.

Ordering information

New Brunswick Digital Platform Shaker Innova® 2100/2150
English (EN)

8.5.3 Capacity upgrade option

With this kit (M1194-9926), an Innova 2100, which has an 46 × 46 cm (18 × 18 in) platform, can be converted to an Innova 2150, with an 46 × 61 cm (18 × 24 in) platforms platform.

The kit consists of counterweighting, hardware, and outrigger feet. Platforms must be purchased separately.

This option must be installed by a qualified service engineer.

9 Transport, storage and disposal

9.1 Disposal

In case the product is to be disposed of, the relevant legal regulations are to be observed.

Information on the disposal of electrical and electronic devices in the European Community:

Within the European Community, the disposal of electrical devices is regulated by national regulations based on EU Directive 2012/19/EU pertaining to waste electrical and electronic equipment (WEEE).

According to these regulations, any devices supplied after August 13, 2005, in the business-to-business sphere, to which this product is assigned, may no longer be disposed of in municipal or domestic waste. To document this, they have been marked with the following identification:



Because disposal regulations may differ from one country to another within the EU, please contact your supplier if necessary.

In Germany, this is mandatory from March 23, 2006. From this date, the manufacturer has to offer a suitable method of return for all devices supplied after August 13, 2005. For all devices supplied before August 13, 2005, the last user is responsible for the correct disposal.

Transport, storage and disposal

New Brunswick Digital Platform Shaker Innova® 2100/2150
English (EN)

10 Certifications

eppendorf

Declaration of Conformity

The product named below fulfills the requirements of directives and standards listed. In the case of unauthorized modifications to the product or an unintended use this declaration becomes invalid.

Product name:

Innova® 2100 and 2150
including accessories

Product type:

Benchtop open air shaker

Relevant directives / standards:

2006/95/EC: EN 61010-1
2004/108/EC: EN 61000-6-1, EN 61000-6-4
2011/65/EU
2012/19/EU



Management Board



Portfolio Management

Date: October 28, 2013

Your local distributor: www.eppendorf.com/contact
Eppendorf AG · 22331 Hamburg · Germany
eppendorf@eppendorf.com

Eppendorf and the Eppendorf Logo are registered trademarks of Eppendorf AG Hamburg/Germany.
All rights reserved incl. graphics and pictures. Copyright 2013 © by Eppendorf AG.

ISO 9001
Certified

ISO 13485
Certified

ISO 14001
Certified

MI194-2115-00

www.eppendorf.com

Certifications

New Brunswick Digital Platform Shaker Innova® 2100/2150
English (EN)

Index

A

Accessories.....	11
Alarm	11, 22, 22, 22

B

Bearings	14
----------------	----

C

Clamps.....	32
Cleaning	25
Construction	14
Continuous run.....	21
Control board.....	15
Control panel	11

D

Display.....	12
Disposal	35

E

Eccentric drive	15
Electrical connections	18

F

Features	10
Flask clamp hardware	32
Flask clamp installation.....	19
Front view.....	9
Fuse replacement	25

I

Indicators.....	13, 13
Installation location	17

K

Keypad	13
--------------	----

M

Main illustration.....	9
Mains/power	11
Maintenance	25
Manual conventions.....	6
Measuring temperature	23
Motor	14

O

Operation	10
Optional features.....	14
Optional kits.....	33

P

Parts	31
Platform assemblies.....	13
Platform installation.....	19
Platforms.....	11

Q

Quick change	19
--------------------	----

R

Run time.....	23
---------------	----

S

Setpoints	21
Space requirements	17
Specifications.....	27
Speed	27, 28
Speed/monitor option	24
Starting the shaker.....	21

Index

New Brunswick Digital Platform Shaker Innova® 2100/2150
English (EN)

Symbols used6

T

Temperature monitor23

Timer21, 22

U

Universal power module11

Unpacking17

Using this manual.....5

V

Voltages17

Evaluate your manual

Give us your feedback.
www.eppendorf.com/manualfeedback