



ARTISAN[®]
TECHNOLOGY GROUP

Your **definitive** source
for quality pre-owned
equipment.

Artisan Technology Group

(217) 352-9330 | sales@artisanng.com | artisanng.com

Full-service, independent repair center

with experienced engineers and technicians on staff.

We buy your excess, underutilized, and idle equipment

along with credit for buybacks and trade-ins.

Custom engineering

so your equipment works exactly as you specify.

- Critical and expedited services
- In stock / Ready-to-ship
- Leasing / Rentals / Demos
- ITAR-certified secure asset solutions

Expert team | Trust guarantee | 100% satisfaction

All trademarks, brand names, and brands appearing herein are the property of their respective owners.

Find the Koganei JAM12PJ at our website: **Click [HERE](#)**

KOGANEI

Air Valve

SOLENOID VALVES JA SERIES

INSTRUCTION MANUAL Ver.1.0

Handling Instructions and Precautions




Solenoid


Internal circuit

● Positive common (DC24V, DC12V)

Single solenoid




Double solenoid




<Low current type> (DC24V)

Single solenoid




Double solenoid




● Negative common (DC24V, DC12V)

Single solenoid




Double solenoid




<Low current type> (DC24V)

Single solenoid



Double solenoid



Cautions: 1. Do not apply megger between the pins.

2. Leakage current inside the circuit could result in failure of the solenoid valve to return to the rest position or in other erratic operation. Always use it at less than the allowable leakage current shown in the solenoid specifications on p.213. If circuit conditions, etc. cause the leakage current to exceed the maximum allowable leakage current, consult us.

3. For the double solenoid specification, avoid energizing both solenoids simultaneously. (Excluding the tandem 3-port valve)


4. The standard housing type is colored blue, while the low current type is light blue.

5. The low current type will not activate if the power supply voltage is raised slowly. Always apply the appropriate voltage.

Operating principles of low current type

The low current type uses a timer circuit, as shown above, that achieves power savings by switching to holding operations mode after a certain period of time to operate at about 1/2 of the starting power consumption.

● Power waveform




Wiring instructions (When using as a single unit or non-plug-in type manifold)

1. Attaching and removing plug connector

Use fingers to insert the connector into the pin, push it in until the lever claw latches onto the protruded section of the connector housing, and complete the connection.

To remove the connector, squeeze the lever along with the connector, lift the lever claw up from the protruded section of the connector housing, and pull it out.



Caution: When removing the connector, confirm that the lever claw is completely disengaged from the protruded section before pulling out. The housing may be damaged if it is pulled out while engaging with the protruded section.


2. Attaching and removing plug connector and contact

● Attaching

Insert the contact with lead wire into a plug connector □ hole until the contact hook latches on and is secured to the plug connector. Confirm that the lead wire cannot be easily pulled out. (See below)

● Removing


To remove it, insert a tool with a fine tip (such as a small screwdriver) into the rectangular hole on the side of the plug connector to push up on the hook, and then pull out the lead wire. When re-using the contacts, restore the hook back so that they spread outward.




3. Common terminal and short bar

A short bar is attached to the plug connector to ensure that the wiring of solenoid A and B become positive common or negative common. Do not remove the short bar.

● For positive common




● For negative common



Caution: The plug connectors for positive common and negative common differ in shape.

4. Crimping of connecting lead wire and contact

To crimp lead wires into contacts, strip off 4mm [0.16in.] of the insulation from the end of the lead wire, insert it into the contact, and crimp it. Be sure to avoid catching the insulation on the exposed wire crimping section.



Cautions: 1. Do not pull the lead wire too hard.


2. Always use a dedicated tool for crimping of connecting lead wire and contact.
Contact: Model 706312-2MK Manufactured by Sumiko Tech, Inc.
Crimping tool: Model F1 (For 706312-2MK) Manufactured by Sumiko Tech, Inc.

5. Common connector assembly for manifold


Using common connector assembly for the solenoid valve for manifold provides common wiring for all solenoid valves and greatly reduces wiring work.

The common connector types are determined by the location viewed from the lead wire side, the right end one is A type, the left end one is C type, and all others are B type. (See below)

- For positive common




- For negative common




For common connector assembly, order the common connector assemblies listed below.

- For positive common


A type Model : JAZ-PA□※



B type Model : JAZ-PB□※




C type Model : JAZ-PC□※




※Lead wire length **Blank** : 300mm[11.8in.]
 3 : 3000mm[118in.]

- For negative common


A type Model : JAZ-MA□※



B type Model : JAZ-MB□※



C type Model : JAZ-MC□※




*Lead wire length **Blank** : 300mm[11.8in.]
 3 : 3000mm[118in.]



Manual override

Manual override (Blank: Non-locking type, -83: Locking protruding type)


To lock the locking protruding type, use a small screwdriver to push down on the manual override all the way and turn it clockwise 90 degrees. When locked, turning the manual override 90 degrees in the counterclockwise direction releases a spring on the manual override, returns it to the original position, and releases the lock. When the manual override is not turned, this type acts just like the non-locking type, like the valve energizing status as long as the manual override is pushed down, and returning to the rest position upon release.



Cautions:

1. The JA series valves are pilot type solenoid valves. As a result, the manual override cannot switch the main valve without air supplied from the 1(P) port.
2. Always release the lock on the locking protruding type manual overrides before commencing normal operation.
3. Do not attempt to operate the manual override with a pin or other object having an extremely fine tip. It could damage the manual override button.


Handling Instructions and Precautions



Manifold

Installing and removing valves


To remove the valve body from the sub-base or manifold, loosen the valve mounting screws (2 places), and pull the valve straight out in the direction of the arrow (see illustration to the right). For mounting, perform the same procedure in reverse. The recommended tightening torque for the valve mounting screw is 17.6N·cm {1.8kgf·cm} [1.56in·lbf].



Port isolator

In the split manifold, inserting port isolators into the 1(P), 3(R2), and 5(R1) ports between each of the stations isolates the air path between stations equipped with port isolators and stations with smaller station numbers. Care should be taken, however, that a piping block must be placed on both ends.

- Port isolator for 1(P) port — Can supply two different pressures. (Model: **JAZ-S1**)
- Port isolator for 3(R2) and 5(R1) ports — Can isolate exhaust air. (prevents exhaust interference) (Model: **JAZ-S3**)
- Port isolator for 1(P), 3(R2) and 5(R1) ports — Can supply two different pressures, and can isolate exhaust air. (prevents exhaust interference) (Model: **JAZ-SA**)





Caution: Mounting port isolators requires disassembly and re-assembly of manifolds. See the disassembly diagram, unit adding procedure, and cautions on p.181 ~183.

Replacement of muffler

When using a piping block with built-in muffler, follow the below procedure to replace the muffler. (Muffler single unit model: **JAZ-M**)

- ① Remove the mounting screws (2 pcs.) holding the cover on top of the piping block.
 - ② Remove the muffler to be replaced.
 - ③ Insert the new muffler so that it reaches the bottom of the groove.
 - ④ Reinstall the cover, and tighten the mounting screws.
- Tightening torque: 49N·cm {5kgf·cm} [4.3in·lbf]



Fittings

Replacement of fittings

1. Replacement of delivery port fittings for monoblock manifolds

Remove the fitting to be replaced, attach a gasket to the new fitting, and tighten.


Tightening torque: 196N·cm {20kgf·cm} [17.3in·lbf] (Fitting single unit model: **JAZ-J4K, JAZ-J6K**)

2. Replacement of delivery port fittings for split manifolds

- ① Loosen the mounting screws of the valve for the fitting to be replaced, and remove the valve.
- ② Use a flatblade screwdriver (blade width 2mm [0.08in.]) to remove the stopper pin holding the fitting to the valve base from the valve base hook, and pull it out.
- ③ Remove the fitting to be replaced, and push in and attach the new fitting as far as it will go.
- ④ Push in the stopper pin until it hooks onto the valve base.
- ⑤ Mount the valve back into place.

Note: Ensure that the fitting and the stopper pin mounting in place are firmly secured.

(Fitting single unit model: **JAZ-J4, JAZ-J6, JAZ-J1/8, JAZ-J1/4**)



Tube

1. Attaching and removing tubes

For tube connection, insert an appropriate size tube until it comes into contact with the tube stopper, and lightly pull it to check the connection.

For tube removal, push the tube against the tube stopper, then push the release ring and at the same time pull the tube out.

2. Either a nylon tube or urethane tube can be used.

Use tubes with an outer diameter tolerance within $\pm 0.1\text{mm}$ [$\pm 0.004\text{in.}$] of the nominal diameter, and ensure the ovalness (difference between large diameter and small diameter) is 0.2mm [0.008in.] or less.

(Using a Koganei tube is recommended.)


- Cautions:**
1. Do not use extra-soft tubes since their pull-out strength is significantly reduced.
 2. Only use tubes without scratches on the outer surfaces. If a scratch occurs during repeated use, cut off the scratched section.
 3. Do not bend the tube excessively near the fittings. The minimum bending radius for nylon tubes is as shown in the table below.
 4. When attaching or removing tubes, always stop the air supply. In addition, always confirm that air has been completely exhausted from the manifold.

mm [in.]	
Tube size	Minimum bending radius
$\phi 4$ [0.157in.]	20 [0.8]
$\phi 6$ [0.236in.]	30 [1.2]
$\phi 8$ [0.315in.]	50 [2.0]
1/8 in.	20 [0.8]
1/4 in.	30 [1.2]
3/8 in.	50 [2.0]


Precautions for use of back pressure prevention valve

Mounting the back pressure prevention valve on the manifold enables users to prevent erratic cylinder operation due to exhaust from other valves. This is particularly effective when using single acting cylinders or exhaust center valves. Care should be taken, however, that the effective OUT-EXH area is reduced to 2.5mm² [Cv:0.14] when using the back pressure prevention valve. In addition, do not let the manifold's exhaust port throttle the exhaust air, since the back pressure prevention valve allows leaks in back pressure. When mounting additional back pressure prevention valves to existing units, observe the following items:

- ① Loosen the valve mounting screws used to install the back pressure prevention valve, and remove the valve.
- ② For the monoblock manifold, temporarily remove the gasket from between the valve and manifold, insert the back pressure prevention valve into the exhaust port, place the gasket, and then mount the valve.



For the split type manifold, remove the gasket from between the valve and manifold, insert the back pressure prevention valve into the exhaust port, mount the dedicated gasket provided, and then install the valve.



Tightening torque of mounting screw : 17.6N·cm {1.8kgf·cm}
[1.56in·lbf]
[Back pressure prevention valve single unit model: **JAZ-E1** (for monoblock type), **JAZ-E2** (for split type)]

Precautions for use of individual air supply spacer


By mounting an individual air supply spacer on the manifold, air supply can be provided individually on the unit. Care should be taken that when spacers are used, the effective area is reduced by about 20%. When mounting additional spacers to existing units, observe the following items.

● Procedure for mounting spacers

- ① Loosen the valve mounting screws for the added individual air supply spacer, and remove the valve.
- ② Install the gaskets provided with the individual air supply spacer, and use the mounting screws provided to mount the valve and spacer on the manifold. (See below)

For plug-in type, also install the provided connector Ass'y. Tightening torque of the mounting screw: 17.6N·cm {1.8kgf·cm} [1.56in·lbf]

(Individual air supply spacer single unit model: **JAZ-NPM**, **JAZ-PPM**)




Remark: When attaching fittings to the Individual air supply spacer, use the recommended fittings shown below.

TSH4-M5M, TSH4-M5, TSH6-M5M, TS4-M50, TS4-M5M


However, only the TSH4-M5M can be attached to JA10A7, A8, and A9 (3-position valve).

● Dimensions mm [in.]


For non-plug-in type
JAZ-NPM



For plug-in type
JAZ-PPM




Connector Ass'y



Changing the direction of the connector bracket


Change the connector from upward facing to side facing by removing the wiring block mounting screws, setting the connector bracket in the position shown in the illustration, and then turning the connector 90 degrees so that it faces to the outside.



Tightening torque of mounting screw:
49N·cm {5kgf·cm} [4.3in·lbf]

Caution: The direction of the -D370U connector cannot be changed, D-sub on top is the only option.

Figure 1



Manifold Unit Adding Procedure (JA Series Non-Plug-in Type)

■ Adding valve base unit

Use the valve base assembly for adding valve base units.

- ① Loosen the mounting screw on the end block until it can slide (see Fig.1).
- ② Disconnect the link between the valve base assembly's bases where the new unit is to be added.
- ③ Mount the valve base assembly to be added on the DIN rail shown in Fig. 2.
- ④ Press the bases together from both sides to ensure that there is no gap between them, and then tighten the end block mounting screws, and install the units in place on the DIN rail (see Fig. 3).
Tightening torque: 147N·cm {15kgf·cm} [13in·lbf]

Note: Confirm that the DIN rail mounting bracket hooks secure the DIN rail (see Fig. 3).

【 Caution】

- Always cut off the power and air supply before working. In addition, always confirm that air has been completely exhausted from the manifold.
- Care should be exercised not to become trapped or lose gaskets.
- Before supplying air to the manifold, always confirm that the bases are connected and the end block mounting screws are tightened, etc. Supplying air when either of the end blocks is not securing the DIN rail could result in air leaks or separate manifold bases.
- When there are a large number of valves simultaneously delivering air to the secondary side, or when there is a large number of valves overall, we recommend using two air supplies and exhausts (on each side).

Adding units of the piping block assembly is performed in the same way as adding units of the valve base assembly.

Figure 2




Figure 3





Figure 1



Manifold Unit Adding Procedure (JA Series Plug-in Type)

■ Adding valve base unit

Use the valve base assembly for adding manifold units.

- ① Loosen the mounting screw on the end block until it can slide (see Fig.1).
- ② Add units on the side shown in Fig. 1 (with the solenoid on top and the right). Disconnect the link between the bases where the new unit is to be added.
- ③ Mount the valve base assembly to be added on the DIN rail shown in Fig. 2.
- ④ Press the bases together from both sides to ensure that there is no gap between them, and then tighten the end block mounting screws, and install the units in place on the DIN rail (see Fig. 3).
Tightening torque: $147\text{N}\cdot\text{cm}$ { $15\text{kgf}\cdot\text{cm}$ } [$13\text{in}\cdot\text{lbf}$].

Note: Confirm that the DIN rail mounting bracket hooks secure the DIN rail (see Fig. 3).

Figure 2





Figure 3



■ Wiring Procedure (for positive common)

- ① Press down the upper part of the cover, and open it. Loosen the mounting screws of the valves next to the valve base assemblies to be added, remove the valves, and remove the plug-in connector (see Fig. 4).
- ② The end terminal lead wire (short, red wire) is inserted into the pin insert section (No.4) of the plug-in connectors that were removed in step ① (see Fig. 5).
(When shipping, the end terminal lead wire is inserted into the plug-in connector of the end unit valve.) Remove this end terminal lead wire, and insert it into the insertion section (No. 4) of the plug-in connector of the valve base assembly to be added. Afterward, insert the common wire (red) of this plug-in connector into the insertion section (No.4) of the removed plug-in connector.
Note: When inserting the lead wire, confirm that the short bar of the plug-in connector's common wire insertion section has been attached.
- ③ Install each of the wired plug-in connectors in step ② to the valve base, and mount the valve.
- ④ Remove the wiring block mounting screws and place them in the positions shown in Fig. 7, then connect the lead wire (white) of the added valve base after confirming the pin location (For details, see the detailed diagram of the wiring block internal connections on p.184).
- ⑤ Return the connector brackets to their original position, and tighten the wiring block mounting screws in place, then install the cover while exercising caution that the lead wires are not trapped by the cover.

■ Wiring Procedure (for negative common)

- ① Press down the upper part of the cover, and open it. Loosen the mounting screws of the valves next to the valve base assemblies to be added, remove the valves, and remove the plug-in connectors (see Fig. 4).
- ② The end terminal lead wire (short, black wire) is inserted into the pin insert section (No.3) of the plug-in connectors that were removed in step ① (see Fig. 6).
(When shipping, the end terminal lead wire is inserted into the plug-in connector of the end unit valve.) Remove this end terminal lead wire, and insert it into the insertion section (No.3) of the plug-in connector for the valve base assembly to be added. Afterward, insert the common wire (black) of this plug-in connector into the insertion section (No.3) of the removed plug-in connector.
Note: When inserting the lead wire, confirm that the short bar of the plug-in connector's common wire insertion section has been attached.
- ③ Install each of the wired plug-in connectors in step ② to the valve base, and mount the valve.
- ④ Remove the wiring block mounting screws and place them in the positions shown in Fig. 7, then connect the lead wire (white) of the added valve base after confirming the pin location (For details, see the detailed diagram of the wiring block internal connections on p.184).
- ⑤ Return the connector brackets to their original position, and tighten the wiring block mounting screws in place, then install the cover while exercising caution that the lead wires are not trapped by the cover.

[Caution]

- Always cut off the power and air supply before working. In addition, always confirm that air has been completely exhausted from the manifold.
- When removing lead wires from the plug-in connector, use a tool with a fine tip (such as a small screwdriver) to press lightly on the contact hook from a hole on the side of the plug-in connector, and pull out the lead wire. When re-inserting the lead wire to the connector, spread the contact hooks so that they face outward, and then insert into the plug-in connector. At this time, pull the lead wire lightly to confirm that it is securely inserted.
- Always connect the end terminal lead wire. (see Figs. 5 and 6)
- Care should be taken not to become trapped or lose gaskets.
- Before supplying air to the manifold, always confirm that the bases are connected, and that the end block mounting screws are tightened, etc.
- Supplying air when either of the end blocks do not secure the DIN rail could result in air leaks or separate manifold bases.
- Be aware that the number of valve units that can be added is limited in the manifold, by the wiring specifications and wiring connection type, etc.
- When there are large number of valves simultaneously delivering air to the secondary side, or when there is a large number of valves overall, we recommend using two air supplies and exhausts (on each side).

Adding units of the piping block assembly is performed in the same way as adding units of the valve base assembly.

- When the wiring specification is -D370U and adding units is required, consult us.

Figure 4






Figure 5 ●For positive common



※1: Always insert the end terminal lead wire.

※2: Shows when both A and B are used.


Figure 6 ●For negative common



※1: Always insert the end terminal lead wire.

※2: Shows when both A and B are used.

Figure 7




Tightening torque of mounting screw: 49N·cm {5kgf·cm} [4.3in·lbf].


See "Detailed Diagram of Wiring Block Internal Connections" on p.184.

Detailed Diagram of Wiring Block Internal Connections


Flat cable connector 20, 26 pins



D-sub connector



Serial transmission block



Serial Transmission Block Specifications

General Specifications


Voltage	DC24V $\pm$ 10%
Operating temperature range	5~50°C [41~122°F]
Vibration resistance	49.0m/s ² {5.0G} (Conforms to JIS C 0911)
Shock resistance	98.1m/s ² {10.0G} (Conforms to JIS C 0912)

● For details of specifications, see the user's manual. (See below)

Serial Transmission Block and Terminal Block (LED) Part Names

● For OMRON CompoBus/S

Transmission block specification: -A1 (16 outputs), -A2 (8 outputs)



LED indicator

Indicator	State	color	Description
PWR	Lights up	Green	• During power supply
	Shut off		• Power is not supplied
COMM	Lights up	Yellow	• During normal communication
	Shut off		• Communication fault, or standby
ERR	Lights up	Red	• Communication fault occurred
	Shut off		• During normal communication, or standby

Remarks

※ For details about CompoBus/S, see the OMRON catalog, user's manual, etc.

● Number of outputs per block


16 solenoids (transmission block specification: -A1)

8 solenoids (transmission block specification: -A2)

● Related materials: User's manual, document No.HV030

● For Mitsubishi Electric CC-Link

Transmission block specification: -B1



LED indicator

Indicator	Description
PW	• Lights up when power is turned on
L RUN	• Lights up when normal data is received from a master station
SD	• Lights up during sending data
RD	• Lights up during receiving data
L ERR.	• Lights up during transmission errors, and shuts off when time is over. Lights up during a station number setting error or transmission speed setting error

Remarks

※ For details about CC-Link, see the Mitsubishi Electric catalog, user's manual, etc.

● Number of outputs per block


16 solenoids (transmission block specification: -B1)

※ Since the block occupies one station, if the block is entirely composed of remote I/O stations, a maximum of 64 units can be connected to one master station.

● Related materials: User's manual, document No.HV031

● For DeviceNet (OMRON CompoBus/D)

Transmission block specification: -D1



LED indicator

Indicator	State	color	Description
MS	Lights up	Green	• Normal status
	Flashing		• No setting status
	Lights up	Red	• Serious breakdown
	Flashing		• Minor breakdown
	Shut off	—	• No power supply
NS	Lights up	Green	• Communication connection achieved
	Flashing		• No communication connection
	Lights up	Red	• Serious communication fault
	Flashing		• Minor communication fault
	Shut off	—	• No power supply

Remarks

※ Conforms to DeviceNet (CompoBus/D)

● Number of outputs per block

Maximum of 16 solenoids

● Related materials: User's manual, document No.HV032

■ For details about specifications and handling, see the above-listed user's manuals (Document No. HV030~HV032).

Application Examples for Serial Transmission Block of General Purpose Type

If manifolds with flat cable connectors released previously have F201 wiring specifications (with positive common specifications only), the serial transmission blocks (general purpose type with F201 compatible flat cable) **YS5□U** can be connected to the manifold to convert it into a serial transmission-compatible manifold.



● Connectable Manifolds


- FM-SOLID MANIFOLD X80M, X88M Series
- Koganei Solenoid Valves F series
- Koganei Solenoid Valves JA series

※ Voltage should meet DC24V specifications.


(Flat cable length approximately 90mm [3.5in.], DIN rail length 75mm [3in.])

2-port


Normally closed (NC)




Normally open (NO)



JA10A1
De-energized



JA10A2
De-energized




Major Parts and Materials


Parts		Materials
Valve	Body	Aluminum alloy (anodized)
	Stem	Aluminum alloy
	Exhaust valve	Synthetic rubber
	Lip seal	
	Flapper	Aluminum alloy (anodized)
	Sub-base	
	Plunger	Magnetic stainless steel
	Column	Steel
Manifold	End cover	Plastic
	Body	Monoblock Aluminum alloy (anodized)
	Split type	Plastic
	Block-off plate	Mild steel (nickel plated)
Seal		Synthetic rubber

3-port


Normally closed (NC)




Normally open (NO)



JA10A3
De-energized




JA10A4
De-energized




5-port, 2-position


Single solenoid




JA10A5
De-energized



Double solenoid




JA10A6
De-energized condition after energizing solenoid 12(SB)




5-port, 3-position

[Both 14 (SA) and 12 (SB) are de-energized]


Closed center




JA10A7




Exhaust center




JA10A8



Pressure center




JA10A9




Tandem 3-port, 4-position

[Both 14 (SA) and 12 (SB) are de-energized]


**Normally closed (NC),
Normally closed (NC)**




JA10AA




**Normally open (NO),
Normally open (NO)**




JA10AB



**Normally closed (NC),
Normally open (NO)**



JA10AC



JA Series Order Codes

The Solenoid Valves JA series order codes are classified into the following 5 categories.


For details of order codes, see the designated pages.

JA10A□ : Single valve unit




p. 189

JAM□AJ : Monoblock manifold



p. 191

JAM□NJ : Split manifold non-plug-in type



p. 193

JAM□PJ : Split manifold plug-in type



p. 197

JAM□SJ : Serial transmission type



p. 201

Single Valve Unit Order Codes



Model

JA10


Standard type

JA10L


Low current type

Valve specification


A1:2-port normally closed




A2:2-port normally open




A3:3-port normally closed




A4:3-port normally open




A5:5-port 2-position, single solenoid




A6:5-port 2-position, double solenoid




A7:3-position, closed center




A8:3-position, exhaust center




A9:3-position, pressure center




AA:Tandem 3-port (normally closed & normally closed)



AB:Tandem 3-port (normally open & normally open)



AC:Tandem 3-port (normally closed & normally open)




Sub-base

Without sub-base^{Note1}



Blank


With sub-base^{Note2}



-25

Wiring specification

Plug-in



Blank

S type plug connector
Without connector and leads



-PN

Positive common
S type plug connector
Lead wire 300mm [11.8in.]




-PS

Positive common
S type plug connector
Lead wire 3000mm [118in.]



-PS3

Negative common
S type plug connector
Lead wire 300mm [11.8in.]



-MS


Negative common
S type plug connector
Lead wire 3000mm [118in.]



-MS3


Manual override

Non-locking type



Blank

Locking protruding type



-83

Voltage

-D4

DC24V

-D5

DC12V

^{Note3}

Model	Valve specification	Sub-base	Manual override	Wiring specification	Voltage
JA10 JA10L	A1 A2 A3 A4 A5 A6 A7 A8 A9 AA AB AC	Blank -25 ^{Note2}	Blank -83	Blank ^{Note2} -PN -PS -PS3 -MS -MS3	-D4 -D5 ^{Note3}

Notes: 1. Cannot be used as a single valve unit. Two manifold mounting screws are provided.

2. When ordering with a sub-base, the "Blank (plug-in)" cannot be selected as the wiring specification. Select from among -PN, -PS, -PS3, -MS or -MS3.

3. -D5(DC12V) is not available in the low current type.

Additional Parts Order Codes for Single Valve Unit

Parts for single valve unit

JAZ -

Parts content

25 : Sub-base (sub-base and gasket)^{Note 1}

GS1 : Gasket^{Note 2}

Notes: 1. Valve mounting screws are not included.

2. Care should be taken that this gasket is different from the **GS2** gasket for the split manifolds.

Connector-related

JAZ -

Connector specification

CP : Positive common plug connector, lead wire length 300mm [11.8in.]


CP3 : Positive common plug connector, lead wire length 3000mm [118in.]

CPN : Positive common plug connector, without lead wire (short bar and contacts included)


CM : Negative common plug connector, lead wire length 300mm [11.8in.]

CM3 : Negative common plug connector, lead wire length 3000mm [118in.]

CMN : Negative common plug connector, without lead wire (short bar and contacts included)



Monoblock Manifold Order Codes



Model

JA10


Standard type

JA10L


Low current type

Valve specification


A1:2-port normally closed




A2:2-port normally open




A3:3-port normally closed




A4:3-port normally open




A5:5-port 2-position, single sol. AB:Tandem 3-port (normally open & normally open)




A6:5-port 2-position, double sol. AC:Tandem 3-port (normally closed & normally open)




A7:3-position, closed center




A8:3-position, exhaust center




A9:3-position, pressure center




AA:Tandem 3-port (normally closed & normally closed)



AB:Tandem 3-port (normally open & normally open)




AC:Tandem 3-port (normally closed & normally open)




Manual override

Non-locking type



Blank


Locking protruding type



-83


Wiring specification

S type plug connector
Without connector and leads




-PN

Positive common
S type plug connector
Lead wire 300mm [11.8in.]




-PS

Negative common
S type plug connector
Lead wire 300mm [11.8in.]




-MS

Positive common
S type plug connector
Lead wire 3000mm [118in.]




-PS3

Negative common
S type plug connector
Lead wire 3000mm [118in.]




-MS3

Positive common pre-wired terminal
S type plug connector
Lead wire 300mm [11.8in.]




-CPS

Negative common pre-wired terminal
S type plug connector
Lead wire 300mm [11.8in.]



-CMS

Positive common pre-wired terminal
S type plug connector
Lead wire 3000mm [118in.]



-CPS3

Negative common pre-wired terminal
S type plug connector
Lead wire 3000mm [118in.]



-CMS3


Manifold fitting specification

With $\phi 4$ [0.157in.] fittings



-J4K


With $\phi 6$ [0.236in.] fittings



-J6K

Individual air supply spacer

Without spacer



Blank

With individual air supply spacer



-NPM

Back pressure prevention valve

Blank

Without back pressure prevention valve

-E1

With back pressure prevention valve

Voltage

-D4

DC24V

-D5

DC12V

Note2

Model	Number of units	Station	Model	Valve specification	Manual override	Wiring specification	Manifold fitting specification	Back pressure prevention valve	Individual air supply spacer	Voltage
Manifold model			Mounting valve model							
JAM	2 : 20	AJ	stn. 1 : stn. ☐ Note1	JA10 JA10L	Blank -83	-PN -PS -PS3 -CPS -CPS3 -MS -MS3 -CMS -CMS3	-J4K -J6K	Blank -E1	Blank -NPM	-D4 -D5 ^{Note2}
JABP (for block-off plate)										

Notes: 1. Valve mounting location is from the left, with the solenoid on top, and the 4(A) and 2(B) ports in front.
2. -D5 (DC12V) is not available in the low current type.

Additional Parts Order Codes for Monoblock Manifold

Manifold parts

JAZ -

Parts description

GS1 : Gasket

E1 : Back pressure prevention valve (2 pcs. for monoblock type)

J4K : ϕ 4 fitting (2 pcs. for monoblock type, and 1 pc. gasket)

J6K : ϕ 6 fitting (2 pcs. for monoblock type, and 1 pc. gasket)

NPM : Individual air supply spacer

(Spacer body, gasket and 2 mounting screws)

Block-off plate (block-off plate and 2 mounting screws)

JABP

Connector-related

JAZ -

Connector specification

CP : Positive common plug connector, lead wire length 300mm [11.8in.]

CP3 : Positive common plug connector, lead wire length 3000mm [118in.]

CPN : Positive common plug connector, without lead wire (short bar and contacts included)

PA : Positive common A type, plug connector lead wire length 300mm* [11.8in.]

PA3 : Positive common A type, plug connector lead wire length 3000mm* [118in.]

PB : Positive common B type, plug connector lead wire length 300mm* [11.8in.]

PB3 : Positive common B type, plug connector lead wire length 3000mm* [118in.]

PC : Positive common C type, plug connector lead wire length 300mm* [11.8in.]

PC3 : Positive common C type, plug connector lead wire length 3000mm* [118in.]

CM : Negative common plug connector, lead wire length 300mm [11.8in.]

CM3 : Negative common plug connector, lead wire length 3000mm [118in.]

CMN : Negative common plug connector, without lead wire (short bar and contacts included)

MA : Negative common A type, plug connector lead wire length 300mm* [11.8in.]

MA3 : Negative common A type, plug connector lead wire length 3000mm* [118in.]


MB : Negative common B type, plug connector lead wire length 300mm* [11.8in.]

MB3 : Negative common B type, plug connector lead wire length 3000mm* [118in.]

MC : Negative common C type, plug connector lead wire length 300mm* [11.8in.]

MC3 : Negative common C type, plug connector lead wire length 3000mm* [118in.]

※ For details, see p.178.



Manifold Order Code Example (6 units of JA series)

JAM6AJ

stn.1~2 JA10A5-PS-J4K-D4

stn.3~5 JA10A6-PS-J6K-D4

stn.6 JABP-J6K

Note: This order code example has no relation to the illustration above.


Precautions for Order Codes

● Order for valves only

Place orders by “**Single Valve Unit Order Codes**” on p.189.

For common terminal wiring connections, order separately the common connector assemblies listed above.

Split Manifold Non-Plug-in Type Order Codes



Piping block specification (air supply and exhaust)

- JR :1(P) and 3, 5(R) ports ϕ 8 [0.315in.] fitting right-side mounting
- JL :1(P) and 3, 5(R) ports ϕ 8 [0.315in.] fitting left-side mounting
- JD :1(P) and 3, 5(R) ports ϕ 8 [0.315in.] fitting both-side mounting
- JR1/4 :1(P) and 3, 5(R) ports 1/4 inch fitting right-side mounting
- JL1/4 :1(P) and 3, 5(R) ports 1/4 inch fitting left-side mounting
- JD1/4 :1(P) and 3, 5(R) ports 1/4 inch fitting both-side mounting
- JR3/8 :1(P) and 3, 5(R) ports 3/8 inch fitting right-side mounting
- JL3/8 :1(P) and 3, 5(R) ports 3/8 inch fitting left-side mounting
- JD3/8 :1(P) and 3, 5(R) ports 3/8 inch fitting both-side mounting



The photo shows the -JR type.

- MR :1(P) port ϕ 8 [0.315in.] fitting, 3, 5(R) ports built-in muffler right-side mounting
- ML :1(P) port ϕ 8 [0.315in.] fitting, 3, 5(R) ports built-in muffler left-side mounting
- MD :1(P) port ϕ 8 [0.315in.] fitting, 3, 5(R) ports built-in muffler both-side mounting
- MR1/4 :1(P) port 1/4 inch fitting, 3, 5(R) ports built-in muffler right-side mounting
- ML1/4 :1(P) port 1/4 inch fitting, 3, 5(R) ports built-in muffler left-side mounting
- MD1/4 :1(P) port 1/4 inch fitting, 3, 5(R) ports built-in muffler both-side mounting
- MR3/8 :1(P) port 3/8 inch fitting, 3, 5(R) ports built-in muffler right-side mounting
- ML3/8 :1(P) port 3/8 inch fitting, 3, 5(R) ports built-in muffler left-side mounting
- MD3/8 :1(P) port 3/8 inch fitting, 3, 5(R) ports built-in muffler both-side mounting



The photo shows the -MR type.

Model

JA10

Standard type

JA10L

Low current type


Valve specification

- A1: 2-port normally closed
- A2: 2-port normally open
- A3: 3-port normally closed
- A4: 3-port normally open
- A5: 5-port 2-position, single sol.
- A6: 5-port 2-position, double sol.
- A7: 3-position, closed center
- A8: 3-position, exhaust center
- A9: 3-position, pressure center
- AA: Tandem 3-port (normally closed & normally closed)
- AB: Tandem 3-port (normally open & normally open)
- AC: Tandem 3-port (normally closed & normally open)


Model	Valve units	Piping block specification (air supply and exhaust)	
Manifold model			
JAM	2 ⋮ 20	NJ	-JR -MR -JL -ML -JD -MD -JR1/4 -MR1/4 -JL1/4 -ML1/4 -JD1/4 -MD1/4 -JR3/8 -MR3/8 -JL3/8 -ML3/8 -JD3/8 -MD3/8

Manual override

Non-locking type



Locking protruding type




Wiring specification


S type plug connector
Without connector ass'y



Positive common
S type plug connector
Lead wire 300mm [11.8in.]



Negative common
S type plug connector
Lead wire 300mm [11.8in.]




Positive common
S type plug connector
Lead wire 3000mm [118in.]




Negative common
S type plug connector
Lead wire 3000mm [118in.]




Positive common
pre-wired terminal
S type plug connector
Lead wire 300mm [11.8in.]




Negative common
pre-wired terminal
S type plug connector
Lead wire 300mm [11.8in.]



Positive common
pre-wired terminal
S type plug connector
Lead wire 3000mm [118in.]




Negative common
pre-wired terminal
S type plug connector
Lead wire 3000mm [118in.]




Manifold fitting specification


With $\phi 4$ [0.157in.] fittings




With $\phi 6$ [0.236in.] fittings



With 1/8 inch fittings



With 1/4 inch fittings



Back pressure prevention valve

Blank


Without back pressure prevention valve

-E2


With back pressure prevention valve

Individual air supply spacer

Without spacer



With individual air supply spacer



Port isolator

Blank : Without port isolator

-S1 : For 1(P) port

-S3 : For 3(R2) and 5(R1) ports

-SA : For 1(P), 3(R2) and 5(R1) ports

Voltage

-D4

DC24V

-D5

DC12V

Note3

Station	Model	Valve specification	Manual override	Wiring specification	Manifold fitting specification	Back pressure prevention valve	Individual air supply spacer	Port isolator	Voltage
---------	-------	---------------------	-----------------	----------------------	--------------------------------	--------------------------------	------------------------------	---------------	---------

Mounting valve model

stn. 1 ⋮ stn. ☐ Note1	JA10 JA10L	A1 A2 A3 A4 A5 A6 A7 A8 A9 AA AB AC	Blank -83	-PN -PS -PS3 -CPS -CPS3 -MS -MS3 -CMS -CMS3	-J4 -J6 -J1/8 -J1/4	Blank -E2	Blank -NPM	Blank -S1 -S3 -SA	-D4 -D5
JABP (for block-off plate)									

Notes: 1. Valve mounting location is from the left, with the solenoid on top, and the 4(A) and 2(B) ports in front.

2. Port isolators can be installed only when piping blocks are mounted on both sides. In addition, only one location for each port isolator can be installed in one manifold for -SA, or one each port isolator for -S1 and -S3 for a total of two locations. When shipping, the designated port isolators are installed between the designated station and the station to its immediate left (the next smaller stn. No.).

3. -D5 (DC12V) is not available in the low current type.

Additional Parts Order Codes for Split Manifold Non-Plug-in Type

Manifold parts

JAZ -

Parts description

GS2 : Gasket (for split type)
E2 : Back pressure prevention valve (2 pcs. for split type and 1 pc. gasket)
J4 : 2 pcs. ϕ 4 fittings, and 1 pc. stopper pin
J6 : 2 pcs. ϕ 6 fittings, and 1 pc. stopper pin
J8 : 2 pcs. ϕ 8 fittings, and 1 pc. stopper pin
J1/8 : 2 pcs. 1/8 inch fittings, and 1 pc. stopper pin
J1/4 : 2 pcs. 1/4 inch fittings, and 1 pc. stopper pin
J1/4P : 2 pcs. 1/4 inch fittings for 1(P) and 3, 5(R) ports, and 1 pc. stopper pin
J3/8 : 2 pcs. 3/8 inch fittings, and 1 pc. stopper pin
M : Muffler for piping block
NPM : Individual air supply spacer (spacer body, gasket and 2 mounting screws)
S1 : Port isolator for 1(P) port
S3 : Port isolator for 3(R2) and 5(R1) ports
SA : Port isolator for 1(P) port, 3(R2) and 5(R1) ports

Block-off plate (block-off plate and 2 mounting screws)

JABP

Piping block assembly

JAZ -

Piping specification

PJ : 1(P) and 3, 5(R) ports ϕ 8 fittings
PJ1/4 : 1(P) and 3, 5(R) ports 1/4 inch fittings
PJ3/8 : 1(P) and 3, 5(R) ports 3/8 inch fittings
PM : 1(P) port ϕ 8 fitting, 3, 5(R) ports built-in mufflers
PM1/4 : 1(P) port 1/4 inch fitting, 3, 5(R) ports built-in mufflers
PM3/8 : 1(P) port 3/8 inch fitting, 3, 5(R) ports built-in mufflers

End blocks (one set of left and right)

JAZ - E

Connector-related

JAZ -

Connector specification

CP : Positive common plug connector, lead wire length 300mm [11.8in.]
CP3 : Positive common plug connector, lead wire length 3000mm [118in.]
CPN : Positive common plug connector, without lead wire (short bar and contacts included)
PA : Positive common A type, plug connector lead wire length 300mm* [11.8in.]
PA3 : Positive common A type, plug connector lead wire length 3000mm* [118in.]
PB : Positive common B type, plug connector lead wire length 300mm* [11.8in.]
PB3 : Positive common B type, plug connector lead wire length 3000mm* [118in.]
PC : Positive common C type, plug connector lead wire length 300mm* [11.8in.]
PC3 : Positive common C type, plug connector lead wire length 3000mm* [118in.]
CM : Negative common plug connector, lead wire length 300mm [11.8in.]
CM3 : Negative common plug connector, lead wire length 3000mm [118in.]
CMN : Negative common plug connector, without lead wire (short bar and contacts included)
MA : Negative common A type, plug connector lead wire length 300mm* [11.8in.]
MA3 : Negative common A type, plug connector lead wire length 3000mm* [118in.]
MB : Negative common B type, plug connector lead wire length 300mm* [11.8in.]
MB3 : Negative common B type, plug connector lead wire length 3000mm* [118in.]
MC : Negative common C type, plug connector lead wire length 300mm* [11.8in.]
MC3 : Negative common C type, plug connector lead wire length 3000mm* [118in.]


※For details, see p.178.

Valve base assembly (valve base and gasket)

JAZ -

Piping specification

VJ4 : With ϕ 4 fitting
VJ6 : With ϕ 6 fitting
VJ1/8 : With 1/8 inch fitting
VJ1/4 : With 1/4 inch fitting



Manifold Order Code Example (6 units of JA series)

JAM6NJ-JR

stn.1~2 JA10A5-PS-J4-D4

stn.3~5 JA10A6-PS-J6-D4

stn.6 JABP-J6

Note: This order code example has no relation to the illustration above.

Precautions for Order Codes


● Order for valves only

Place orders by "Single Valve Unit Order Codes" on p.189.

For wiring specifications, **Blank** (plug-in type valve) cannot be selected.

For common terminal wiring connections, order separately the common connector assemblies listed to the left.

Split Manifold Plug-in Type Order Codes



Piping block specification (air supply and exhaust)

- JR :1(P) and 3, 5(R) ports ϕ 8 [0.315in.] fitting right-side mounting
- JL :1(P) and 3, 5(R) ports ϕ 8 [0.315in.] fitting left-side mounting
- JD :1(P) and 3, 5(R) ports ϕ 8 [0.315in.] fitting both-side mounting
- JR1/4 :1(P) and 3, 5(R) ports 1/4 inch fitting right-side mounting
- JL1/4 :1(P) and 3, 5(R) ports 1/4 inch fitting left-side mounting
- JD1/4 :1(P) and 3, 5(R) ports 1/4 inch fitting both-side mounting
- JR3/8 :1(P) and 3, 5(R) ports 3/8 inch fitting right-side mounting
- JL3/8 :1(P) and 3, 5(R) ports 3/8 inch fitting left-side mounting
- JD3/8 :1(P) and 3, 5(R) ports 3/8 inch fitting both-side mounting



The photo shows the -JR type.


- MR :1(P) port ϕ 8 [0.315in.] fitting, 3, 5(R) ports built-in muffler right-side mounting
- ML :1(P) port ϕ 8 [0.315in.] fitting, 3, 5(R) ports built-in muffler left-side mounting
- MD :1(P) port ϕ 8 [0.315in.] fitting, 3, 5(R) ports built-in muffler both-side mounting
- MR1/4 :1(P) port 1/4 inch fitting, 3, 5(R) ports built-in muffler right-side mounting
- ML1/4 :1(P) port 1/4 inch fitting, 3, 5(R) ports built-in muffler left-side mounting
- MD1/4 :1(P) port 1/4 inch fitting, 3, 5(R) ports built-in muffler both-side mounting
- MR3/8 :1(P) port 3/8 inch fitting, 3, 5(R) ports built-in muffler right-side mounting
- ML3/8 :1(P) port 3/8 inch fitting, 3, 5(R) ports built-in muffler left-side mounting
- MD3/8 :1(P) port 3/8 inch fitting, 3, 5(R) ports built-in muffler both-side mounting




The photo shows the -MR type.

Wiring specification (wiring block)

Flat cable connector (with socket and strain relief)



- F200 : 20-pin (connector on upper side)
- F201 : 20-pin (connector on upper side)
- F260 : 26-pin (connector on upper side)



- F200E : 20-pin (connector on side)
- F201E : 20-pin (connector on side)
- F260E : 26-pin (connector on side)

D-sub connector




- D250 : 25-pin (connector on upper side) (M2.6 mounting screws)
- D251 : 25-pin (connector on upper side) (M2.6 mounting screws)
- D250U : 25-pin (connector on upper side) (4-40UNC mounting screws)
- D251U : 25-pin (connector on upper side) (4-40UNC mounting screws)

※ For details of wiring specification, see p.205.

D-sub connector



- D250E : 25-pin (connector on side) (M2.6 mounting screws)
- D251E : 25-pin (connector on side) (M2.6 mounting screws)
- D250EU : 25-pin (connector on side) (4-40UNC mounting screws)
- D251EU : 25-pin (connector on side) (4-40UNC mounting screws)



- D370U : 37-pin (connector on upper side) (4-40UNC mounting screws)

Wiring connection specification

Blank

Packed wiring : Wiring is made in accordance with the mounted valve specifications.^{Note}

-D

Double wiring : Wiring is always the one for the double solenoid, regardless of the specifications of the mounted valve.^{Note}

Note: The wiring for the block-off plate is normally the one for the double solenoid. However, when -S is designated as the block-off plate wiring specification, the block-off plate wiring of the station is changed to the single solenoid.

Pre-wired common

Blank

Positive common

-CM

Negative common

Voltage

-D4

DC24V



















-D5

Note4

DC12V

Model	Valve units		Piping block specification (air supply and exhaust)	Wiring specification	Wiring connection specification	pre-wired common	Voltage
Manifold model							
JAM	2 : : Note1	PJ	-JR -MR -JL -ML -JD -MD -JR1/4 -MR1/4 -JL1/4 -ML1/4 -JD1/4 -MD1/4 -JR3/8 -MR3/8 -JL3/8 -ML3/8 -JD3/8 -MD3/8	-F200 -F201 -F260 -F200E -F201E -F260E -D250 -D251 -D250U -D251U -D250E -D251E -D250EU -D251EU -D370U	Blank -D	Blank -CM	-D4 -D5 ^{Note4}

Notes: 1. For the maximum number of units, see the table for the maximum number of valve units by wiring specification, on p.199.

Model	Manual override		Manifold fitting specification		Back pressure prevention valve		Block-off plate wiring specification		
JA10 Standard type JA10L Low current type	Non-locking type Blank	Locking protruding type -83	With ϕ 4[0.157in.] fittings  -J4 With ϕ 6[0.236in.] fittings  -J6 With 1/8 inch fittings  -J1/8 With 1/4 inch fittings  -J1/4	Blank Without back pressure prevention valve -E2 With back pressure prevention valve	Blank Wiring is always the one for the double solenoid. -S When -S is designated, the block-off plate wiring of the station is changed to the single solenoid.				
Valve specification			Individual air supply spacer		Port isolator		Voltage		
A1 : 2-port normally closed  A2 : 2-port normally open  A3 : 3-port normally closed  A4 : 3-port normally open  A5 : 5-port 2-position, single sol.  A6 : 5-port 2-position, double sol.  A7 : 3-position, closed center  A8 : 3-position, exhaust center  A9 : 3-position, pressure center  AA : Tandem 3-port (normally closed & normally closed)  AB : Tandem 3-port (normally open & normally open)  AC : Tandem 3-port (normally closed & normally open) 			Without spacer  Blank With individual air supply spacer  -PPM		Blank : Without port isolator -S1 : For 1(P) port -S3 : For 3(R2) and 5(R1) ports -SA : For 1(P), 3(R2) and 5(R1) ports		-D4 DC24V -D5 DC12V Note4		
Station	Model	Valve specification	Manual override	Manifold fitting specification	Back pressure prevention valve	Individual air supply spacer	Port isolator	Block-off plate wiring specification	Voltage
Mounting valve model									
stn. 1 ⋮ stn. ☐ Note2	JA10 JA10L	A1 A2 A3 A4 A5 A6 A7 A8 A9 AA AB AC	Blank -83	-J4 -J6 -J1/8 -J1/4	Blank -E2	Blank -PPM	Blank -S1Note3 -S3Note3 -SANote3		-D4 -D5Note4
	JABPP (for block-off plate)							Blank -S	

Notes: 2. Valve mounting location is from the left, with the solenoid on top, and the 4(A) and 2(B) ports in front.

3. Port isolators can be installed only when piping blocks are mounted on both sides. In addition, only one location of each port isolator can be installed in one manifold for **-SA**, or one each port isolator for **-S1** and **-S3**, for a total of two locations. When shipping, the designated port isolators are installed between the designated station and the station to its immediate left (the next smaller stn. No.).

4. **-D5** (DC12V) is not available in the low current type.

Additional Parts Order Codes for Split Manifold Plug-in Type

Manifold parts

JAZ -

Parts description

- GS2** : Gasket (for split type)
E2 : Back pressure prevention valve (2 pcs. for split type, and 1 pc. gasket)
J4 : 2 pcs. ϕ 4 fittings, and 1 pc. stopper pin
J6 : 2 pcs. ϕ 6 fittings, and 1 pc. stopper pin
J8 : 2 pcs. ϕ 8 fittings, and 1 pc. stopper pin
J1/8 : 2 pcs. 1/8 inch fittings, and 1 pc. stopper pin
J1/4 : 2 pcs. 1/4 inch fittings, and 1 pc. stopper pin
J1/4P : 2 pcs. 1/4 inch fittings for 1(P) and 3, 5(R) ports, and 1 pc. stopper pin
J3/8 : 2 pcs. 3/8 inch fittings, and 1 pc. stopper pin
M : Muffler for piping block
PPM : Individual air supply spacer (spacer body, gasket, 2 mounting screws, and connector Ass'y)
S1 : Port isolator for 1(P) port
S3 : Port isolator for 3(R2) and 5(R1) ports
SA : Port isolator for 1(P) port, 3(R2) and 5(R1) ports

Block-off plate (block-off plate, 2 mounting screws, and plug)

JABPP

Piping block assembly

JAZ -

Piping specification

- PJ** : 1(P) and 3, 5(R) ports ϕ 8 fittings
PJ1/4 : 1(P) and 3, 5(R) ports 1/4 inch fittings
PJ3/8 : 1(P) and 3, 5(R) ports 3/8 inch fittings
PM : 1(P) port ϕ 8 fitting, 3, 5(R) ports built-in mufflers
PM1/4 : 1(P) port 1/4 inch fitting, 3, 5(R) ports built-in mufflers
PM3/8 : 1(P) port 3/8 inch fitting, 3, 5(R) ports built-in mufflers

Wiring block assembly (one set)

JAZ - - -

Voltage

- D4** : DC24V
D5 : DC12V

Pre-wired common

- Blank** : Positive common
CM : Negative common

Wiring specification

- F200** : Flat cable connector
F201 : Flat cable connector
F260 : Flat cable connector
D250 : D-sub connector with M2.6 mounting screws
D251 : D-sub connector with M2.6 mounting screws
D250U : D-sub connector with 4-40 UNC mounting screws
D251U : D-sub connector with 4-40 UNC mounting screws
D370U : D-sub connector with 4-40 UNC mounting screws

End blocks (one set of left and right)

JAZ - EP

Valve base assembly (valve base, gasket, lead wire and plug-in connector)

JAZ - - -

Pre-wired common

- Blank** : Positive common
CM : Negative common

Wiring specification


- D** : For D-sub connector
F : For flat cable connector

Piping specification

- VJ4** : With ϕ 4 fitting
VJ6 : With ϕ 6 fitting
VJ1/8 : With 1/8 inch fitting
VJ1/4 : With 1/4 inch fitting

Table for maximum number of valve units by wiring specification

		Maximum number of units	
		Wiring specification	
Wiring specification	Max. outputs	Packed wiring (Blank)	Double wiring (-D)
F200 Flat cable (20P)	16	Varies depending on the mounted number of single solenoids, double solenoids and block-off plates. The number of controllable solenoids should be the maximum number of outputs or less. Max. 20 units possible.	8 units
F201 Flat cable (20P)	16		8 units
F260 Flat cable (26P)	20		10 units
D250 D-sub connector (25P)	16		8 units
D251 D-sub connector (25P)	20		10 units
D370U D-sub connector (37P)	32		16 units



Manifold Order Code Example (8 units of JA series)

JAM8PJ-JR-F201-D4

stn.1~4 JA10A5-J4-D4

stn.5~7 JA10A6-J6-D4

stn.8 JABPP-J6

Note: This order code example has no relation to the illustration above.

Precautions for Order Codes

● Order for valves only

Place orders by "Single Valve Unit Order Codes" on p.189.

The wiring specification, however, is compatible with the **Blank** (plug-in type) only.


● Wiring connection specification

Blank (packed wiring) : Wiring is made in accordance with the mounted valve specifications.

-D (double wiring) : Wiring is always for the double solenoid, regardless of the mounted valve specifications.

Note: The wiring for the block-off plate is normally the one for the double solenoid. However, when **-S** is designated as the block-off plate wiring specification, the block-off plate wiring of the station is changed to the single solenoid.

Serial Transmission Type Order Codes



Piping block specification (air supply and exhaust)

- JR :1(P) and 3, 5(R) ports ϕ 8 [0.315in.] fitting right-side mounting
- JL :1(P) and 3, 5(R) ports ϕ 8 [0.315in.] fitting left-side mounting
- JD :1(P) and 3, 5(R) ports ϕ 8 [0.315in.] fitting both-side mounting
- JR1/4 :1(P) and 3, 5(R) ports 1/4 inch fitting right-side mounting
- JL1/4 :1(P) and 3, 5(R) ports 1/4 inch fitting left-side mounting
- JD1/4 :1(P) and 3, 5(R) ports 1/4 inch fitting both-side mounting
- JR3/8 :1(P) and 3, 5(R) ports 3/8 inch fitting right-side mounting
- JL3/8 :1(P) and 3, 5(R) ports 3/8 inch fitting left-side mounting
- JD3/8 :1(P) and 3, 5(R) ports 3/8 inch fitting both-side mounting



The photo shows the -JR type.

- MR :1(P) port ϕ 8 [0.315in.] fitting, 3, 5(R) ports built-in muffler right-side mounting
- ML :1(P) port ϕ 8 [0.315in.] fitting, 3, 5(R) ports built-in muffler left-side mounting
- MD :1(P) port ϕ 8 [0.315in.] fitting, 3, 5(R) ports built-in muffler both-side mounting
- MR1/4 :1(P) port 1/4 inch fitting, 3, 5(R) ports built-in muffler right-side mounting
- ML1/4 :1(P) port 1/4 inch fitting, 3, 5(R) ports built-in muffler left-side mounting
- MD1/4 :1(P) port 1/4 inch fitting, 3, 5(R) ports built-in muffler both-side mounting
- MR3/8 :1(P) port 3/8 inch fitting, 3, 5(R) ports built-in muffler right-side mounting
- ML3/8 :1(P) port 3/8 inch fitting, 3, 5(R) ports built-in muffler left-side mounting
- MD3/8 :1(P) port 3/8 inch fitting, 3, 5(R) ports built-in muffler both-side mounting



The photo shows the -MR type.

Serial transmission block specification

※ These are serial transmission block specifications compatible with each system.



For details, see p.185.

- A1 : For Omron CompoBus/S (16 outputs)
- A2 : For Omron CompoBus/S (8 outputs)
- B1 : For Mitsubishi Electric CC-Link
- D1 : For DeviceNet (CompoBus/D)

Wiring connection specification

Blank

Packed wiring : Wiring is made in accordance with the mounted valve specifications.^{Note}

-D

Double wiring : Wiring is always the one for the double solenoid, regardless of the specifications of the mounted valve.^{Note}

Note: The wiring for the block-off plate is normally the one for the double solenoid. However, when -S is designated as the block-off plate wiring specification, the block-off plate wiring of the station is changed to the single solenoid.

Model	Valve units		Piping block specification (air supply and exhaust)	Serial transmission block specification	Wiring connection specification
Manifold model					
JAM	2 ⋮ ☐ Note 1	SJ	-JR -JL -JD -JR1/4 -JL1/4 -JD1/4 -JR3/8 -JL3/8 -JD3/8 -MR -ML -MD -MR1/4 -ML1/4 -MD1/4 -MR3/8 -ML3/8 -MD3/8	-A1 -A2 -B1 -D1	Blank -D

Notes: 1. For the maximum number of units, see the table for the maximum number of valve units by serial transmission block specification, on p.203.

Model

JA10

Standard type

JA10L

Low current type

Manual override

Non-locking type

Blank

Locking protruding type

-83

Valve specification

A1 : 2-port normally closed

A2 : 2-port normally open

A3 : 3-port normally closed

A4 : 3-port normally open

A5 : 5-port 2-position, single sol.

A6 : 5-port 2-position, double sol.

A7 : 3-position, closed center

A8 : 3-position, exhaust center

A9 : 3-position, pressure center

AA : Tandem 3-port (normally closed & normally closed)

AB : Tandem 3-port (normally open & normally open)

AC : Tandem 3-port (normally closed & normally open)

Manifold fitting specification

With ϕ 4[0.157in.] fittings

-J4

With ϕ 6[0.236in.] fittings

-J6

With 1/8 inch fittings

-J1/8

With 1/4 inch fittings

-J1/4

Back pressure prevention valve

Blank

Without back pressure prevention valve

-E2

With back pressure prevention valve

Individual air supply spacer

Without spacer

Blank

With individual air supply spacer

-PPM

Port isolator

Blank : Without port isolator

-S1 : For 1(P) port

-S3 : For 3(R2) and 5(R1) ports

-SA : For 1(P), 3(R2) and 5(R1) ports

Block-off plate wiring specification

Blank

Wiring is always the one for the double solenoid.

-S

When -S is designated, the block-off plate wiring of the station is changed to the single solenoid.

Voltage

-D4

DC24V

Station

Model

Valve specification

Manual override

Manifold fitting specification

Back pressure prevention valve

Individual air supply spacer

Port isolator

Block-off plate wiring specification

Voltage

Mounting valve model

stn. 1

⋮

stn. ☐

Note2

JA10

JA10L

A1

A2

A3

A4

A5

A6

A7

A8

A9

AA

AB

AC

Blank

-83

-J4

-J6

-J1/8

-J1/4

Blank

-E2

Blank

-PPM

Blank

-S1 ^{Note3}

-S3 ^{Note3}

-SA ^{Note3}

-D4

JABPP (for block-off plate)

Blank

-S

Notes: 2. Valve mounting location is from the left, with the solenoid on top, and the 4(A) and 2(B) ports in front.

3. Port isolators can be installed only when piping blocks are mounted on both sides. In addition, only one location of each port isolator can be installed in one manifold for -SA, or one each port isolator for -S1 and -S3, for a total of two locations. When shipping, the designated port isolators are installed between the designated station and the station to its immediate left (the next smaller stn. No.).

Additional Parts Order Codes for Serial Transmission Type

Manifold parts

JAZ -

Parts description

GS2 : Gasket (for split type)
E2 : Back pressure prevention valve (2 pcs. for split type, and 1 pc. gasket)
J4 : 2 pcs. ϕ 4 fittings, and 1 pc. stopper pin
J6 : 2 pcs. ϕ 6 fittings, and 1 pc. stopper pin
J8 : 2 pcs. ϕ 8 fittings, and 1 pc. stopper pin
J1/8 : 2 pcs. 1/8 inch fittings, and 1 pc. stopper pin
J1/4 : 2 pcs. 1/4 inch fittings, and 1 pc. stopper pin
J1/4P : 2 pcs. 1/4 inch fittings for 1(P) and 3, 5(R) ports, and 1 pc. stopper pin
J3/8 : 2 pcs. 3/8 inch fittings, and 1 pc. stopper pin
M : Muffler for piping block
PPM : Individual air supply spacer (spacer body, gasket, 2 mounting screws, and connector Ass'y)
S1 : Port isolator for 1(P) port
S3 : Port isolator for (R2) and 5(R1) ports
SA : Port isolator for 1(P) port, 3(R2) and 5(R1) ports

Block-off plate (block-off plate, 2 mounting screws, and plug)

JABPP

End blocks (one set of left and right)

JAZ - EP

Valve base assembly (valve base, gasket, lead wire and plug-in connector)

JAZ - - F

Piping specification

VJ4 : With ϕ 4 fitting
VJ6 : With ϕ 6 fitting
VJ1/8 : With 1/8 inch fitting
VJ1/4 : With 1/4 inch fitting

Serial transmission block (single unit)

YS5

Options

Blank: For replacement of JA Series serial transmission block
U : With flat cable (general purpose type) ^{Note} compatible with F201
 Note: For general purpose type, see p.185.

Serial transmission block specification

A1 : For Omron CompoBus/S (16 outputs)
A2 : For Omron CompoBus/S (8 outputs)
B1 : For Mitsubishi Electric CC-Link
D1 : For DeviceNet (CompoBus/D)

Piping block assembly


JAZ -

Piping specification

PJ : 1(P) and 3, 5(R) ports ϕ 8 fittings
PJ1/4 : 1(P) and 3, 5(R) ports 1/4 inch fittings
PJ3/8 : 1(P) and 3, 5(R) ports 3/8 inch fittings
PM : 1(P) port ϕ 8 fitting, 3, 5(R) ports built-in mufflers
PM1/4 : 1(P) port 1/4 inch fitting, 3, 5(R) ports built-in mufflers
PM3/8 : 1(P) port 3/8 inch fitting, 3, 5(R) ports built-in mufflers

Table for maximum number of valve units by serial transmission block specification

		Maximum number of units	
		Wiring specification	
Transmission block specification	Max. outputs	Packed wiring (Blank)	Double wiring (-D)
-A1 : For Omron CompoBus/S (16 outputs)	16	Varies depending on the mounted number of single solenoids, double solenoids and block-off plates. The number of controllable solenoids should be the maximum number of outputs or less.	8 units
-A2 : For Omron CompoBus/S (8 outputs)	8		4 units
-B1 : For Mitsubishi Electric CC-Link	16		8 units
-D1 : For DeviceNet (CompoBus/D)	16		8 units



Manifold Order Code Example (8 units of JA series)

JAM8SJ-JR-A1

stn.1~4 JA10A5-J4-D4

stn.5~7 JA10A6-J6-D4

stn.8 JABPP-J6

Note: This order code example has no relation to the illustration above.

Precautions for Order Codes

● Order for valves only

Place orders by "Single Valve Unit Order Codes" on p.189.

The wiring specification, however, is compatible with the **Blank** (plug-in type) only.

● Wiring connection specification

Blank (packed wiring) : Wiring is made in accordance with the mounted valve specifications.


-D (double wiring) : Wiring is always for the double solenoid, regardless of the mounted valve specifications.

Note: The wiring for the block-off plate is normally the one for the double solenoid. However, when **-S** is designated as the block-off plate wiring specification, the block-off plate wiring of the station is changed to the single solenoid.

Split Manifold Plug-in Type Pin Locations by Wiring Specification (TOP VIEW)


Flat cable connector (20-pin)

●-F200□ (Maximum 16 outputs)



1~16 : Control pin
17, 18 : (−) pin (Short-circuited within the wiring block)
19, 20 : (+) pin (Short-circuited within the wiring block)

●-F201□ (Maximum 16 outputs)




1~8 : Control pin
11~18 : Control pin
9, 19 : (−) pin (Short-circuited within the wiring block)
10, 20 : (+) pin (Short-circuited within the wiring block)

Caution: The above pin numbers are assigned for the sake of convenience. Use the ▽ mark as a reference.

Remark : The -F201 corresponds Koganei's pin locations for the PC wiring system (wire-saving unit). For details, see Catalog No.V3124 PC Wiring Systems.

Flat cable connector (26-pin)

●-F260□ (Maximum 20 outputs)




1~20 : Control pin
23, 24 : (−) pin (Short-circuited within the wiring block)
25, 26 : (+) pin (Short-circuited within the wiring block)

※For the relationship between the pin No. (terminal No.) and the corresponding solenoid, see p.208~211.

D-sub connector (25-pin)

●-D250□ (Maximum 16 outputs)



1~16 : Control pin
20, 21, 22 : (−) pin (Short-circuited within the wiring block)
23, 24, 25 : (+) pin (Short-circuited within the wiring block)

Caution: For the sake of convenience, the connector pins are assigned based on the solenoid valve wiring sequence, which differs from the pin locations and pin numbers (marked) prescribed in JIS-X5101 for the data circuit-terminating equipment (DCE).

●-D251□ Pin locations based on JIS (Maximum 20 outputs)



1~10, 14~23 : Control pin
12, 13 : (−) pin (Short-circuited within the wiring block)
24, 25 : (+) pin (Short-circuited within the wiring block)

D-sub connector (37-pin)


●-D370U (Maximum 32 outputs)



1~32 : Control pin
34, 35 : Common pin (For negative common)
36, 37 : Common pin (For positive common)

Caution: For the sake of convenience, the connector pins are assigned based on the solenoid valve wiring sequence, which differs from the pin locations and pin numbers (marked) prescribed in JIS-X5103 for the data circuit-terminating equipment (DCE).


●Special cable assemblies are available.
For details, see p.206~207.




Detailed Diagram of Wiring System

Flat cable connector and D-sub connector (DC24V, DC12V)

●Positive common



●Negative common




Detailed Diagram of Wiring System

D-sub connector -D370U

●Positive common

●Negative common



JA Series Split Manifold Plug-in Type Cable Assemblies by Wiring Specification mm [in.]

Special cable assemblies are individually available for every wiring specification.

Order Code

FMA - [] - [] - []

Types of special cables

- 200W : -F200[] special cable assembly
- 201W : -F201[] special cable assembly
- 260W : -F260[] special cable assembly
- 250W : -D250[] special cable assembly
- 251W : -D251[] special cable assembly

Lead wire end processing

Blank: w/o processed lead wire end
[with special label/No. indication]


Y : Y terminal (M3.5) [with marker tube/No. indication]

Cable length (m): 0.5~5.0 [20~197in.]
(Enter with 0.5m [20in.] pitch).
※ Used cable: UL STYLE NO.20266 150V 80°C
AWG28 (7/0.127 [cables/mm])

Note: Always perform wiring correctly by confirming the pin locations, connector numbers, label numbers, marker tube numbers, etc.

●-F200[] special cable assembly

FMA-200W-[]-[]




A side	-F200 pin location	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
	Connector No.	①	②	③	④	⑤	⑥	⑦	⑧	⑨	⑩	⑪	⑫	⑬	⑭	⑮	⑯	⑰	⑱	⑳	
B side	Label and marker tube No.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	—	—	+	+

JA Series Split Manifold Plug-in Type Cable Assemblies by Wiring Specification mm [in.]

●-F201 special cable assembly

FMA-201W-□-□


Note: Caution should be exercised that there are differences between the pin location numbers and connector numbers.



A side	-F201 pin location	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
	Connector No.	20	18	16	14	12	10	8	6	4	2	19	17	15	13	11	9	7	5	3	1
B side	Label and marker tube No.	1	2	3	4	5	6	7	8	—	+	9	10	11	12	13	14	15	16	—	+

●-F260 special cable assembly

FMA-260W-□-□




A side	-F260 pin location	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
	Connector No.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
B side	Label and marker tube No.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	—	—	—	—	+	+

●-D250, -D250E special cable assembly

FMA-250W-□-□


Note: Caution should be exercised that there are differences between the pin location numbers and connector numbers.



A side	-D250 pin location	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25
	Connector No.	1	14	2	15	3	16	4	17	5	18	6	19	7	20	8	21	9	22	10	23	11	24	12	25	13
B side	Label and marker tube No.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	—	—	—	—	—	—	—	—	—

●-D251, -D251E special cable assembly

FMA-251W-□-□



A side	-D251 pin location	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25
	Connector No.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25
B side	Label and marker tube No.	1	2	3	4	5	6	7	8	9	10	—	—	11	12	13	14	15	16	17	18	19	20	—	—	—

Pin Numbers and Corresponding Solenoids (For Split Manifold Plug-in Type)

The examples below show the relationship between the split manifold pin numbers and the corresponding solenoids.
The installation examples show the maximum numbers of outputs in use.

Flat cable connector (20-pin)


Wiring specification **-F200** (Maximum 16 outputs)

Example 1

JAM10PJ-JR-F200-D4 stn. 1~4 JA10A5-J4-D4


stn. 5~9 JA10A6-J4-D4

stn. 10 JABPP-J4



Number of units : 10 units
Wiring specification : **-F200**
Wiring connection specification :
Blank (packed wiring)

(TOP VIEW)




Pin No.	19	17	15	13	11	9	7	5	3	1
Valve No.	+	-	10A	9A	8A	7A	6A	5A	3A	1A
Pin No.	20	18	16	14	12	10	8	6	4	2
Valve No.	+	-	10B	9B	8B	7B	6B	5B	4A	2A

Example 2

JAM8PJ-JR-F200-D-D4 stn. 1~4 JA10A5-J4-D4


stn. 5~7 JA10A6-J4-D4

stn. 8 JABPP-J4



Number of units : 8 units
Wiring specification : **-F200**
Wiring connection specification :
-D (double wiring)

(TOP VIEW)



Pin No.	19	17	15	13	11	9	7	5	3	1
Valve No.	+	-	8A	7A	6A	5A	4A	3A	2A	1A
Pin No.	20	18	16	14	12	10	8	6	4	2
Valve No.	+	-	8B	7B	6B	5B	4B	3B	2B	1B

Flat cable connector (20-pin)


Wiring specification **-F201** (Maximum 16 outputs)

Example 1

JAM10PJ-JR-F201-D4 stn. 1~4 JA10A5-J4-D4

stn. 5~9 JA10A6-J4-D4

stn. 10 JABPP-J4



Number of units : 10 units
Wiring specification : **-F201**
Wiring connection specification :
Blank (packed wiring)

(TOP VIEW)




Pin No.	11	12	13	14	15	16	17	18	19	20
Valve No.	7A	7B	8A	8B	9A	9B	10A	10B	-	+
Pin No.	1	2	3	4	5	6	7	8	9	10
Valve No.	1A	2A	3A	4A	5A	5B	6A	6B	-	+

Example 2

JAM8PJ-JR-F201-D-D4 stn. 1~4 JA10A5-J4-D4

stn. 5~7 JA10A6-J4-D4

stn. 8 JABPP-J4



Number of units : 8 units
Wiring specification : **-F201**
Wiring connection specification :
-D (double wiring)

(TOP VIEW)



Pin No.	11	12	13	14	15	16	17	18	19	20
Valve No.	5A	5B	6A	6B	7A	7B	8A	8B	-	+
Pin No.	1	2	3	4	5	6	7	8	9	10
Valve No.	1A	1B	2A	2B	3A	3B	4A	4B	-	+

Caution: Connector pin numbers are assigned for the sake of convenience. Use the ▽ mark as a reference.

- Notes: 1. In the figures, the valve numbers 1A, 1B, 2A, 2B... show the stn. numbers, while the letters A and B show the A or B side of the solenoid.
2. The stn. numbers are counted from the left, 1, 2..., with the solenoid on top and the valve outlet ports in front.
3. When selecting wiring connection specification **-D**, all wiring is double wiring, regardless of valve specifications.
4. The wiring for the block-off plate is normally assigned as double wiring (2 pins to 1 unit), regardless of the wiring specifications. However, when **-S** is designated as the block-off plate wiring specification, the block-off plate wiring of the station is changed to the single solenoid.
5. Connector pin numbers are assigned for the sake of convenience. Use the ▽ mark as a reference.


Pin Numbers and Corresponding Solenoids (For Split Manifold Plug-in Type)

The examples below show the relationship between the split manifold pin numbers and the corresponding solenoids.
The installation examples show the maximum numbers of outputs in use.

Flat cable connector (26-pin)

●Wiring specification **-F260** (Maximum 20 outputs)

Example 1




(TOP VIEW)



Pin No.	25	23	21	19	17	15	13	11	9	7	5	3	1
Valve No.	+	-		12A	11A	10A	9A	8A	7A	6A	5A	3A	1A
Pin No.	26	24	22	20	18	16	14	12	10	8	6	4	2
Valve No.	+	-		12B	11B	10B	9B	8B	7B	6B	5B	4A	2A

Example 2



(TOP VIEW)



Pin No.	25	23	21	19	17	15	13	11	9	7	5	3	1
Valve No.	+	-		10A	9A	8A	7A	6A	5A	4A	3A	2A	1A
Pin No.	26	24	22	20	18	16	14	12	10	8	6	4	2
Valve No.	+	-		10B	9B	8B	7B	6B	5B	4B	3B	2B	1B


- Notes: 1. In the figures, the valve numbers 1A, 1B, 2A, 2B... show the stn. numbers, while the letters A and B show the A or B side of the solenoid.
2. The stn. numbers are counted from the left, 1, 2..., with the solenoid on top and the valve outlet ports in front.
3. When selecting wiring connection specification **-D**, all wiring is double wiring, regardless of valve specifications.
4. The wiring for the block-off plate is normally assigned as double wiring (2 pins to 1 unit), regardless of the wiring specifications. However, when **-S** is designated as the block-off plate wiring specification, the block-off plate wiring of the station is changed to the single solenoid.
5. Connector pin numbers are assigned for the sake of convenience. Use the ▽ mark as a reference.

The examples below show the relationship between the split manifold pin numbers and the corresponding solenoids.
The installation examples show the maximum numbers of outputs in use.

D-sub connector (25-pin)


●Wiring specification -D250 □ (Maximum 16 outputs)

Example 1




Caution: For the sake of convenience, the connector pins are assigned based on the solenoid valve wiring sequence, which differs from the pin locations and pin numbers (marked) prescribed in JIS-X5101 for the data circuit-terminating equipment (DCE).

(TOP VIEW)




Pin No.	1	3	5	7	9	11	13	15	17	19	21	23	25
Valve No.	1A	3A	5A	6A	7A	8A	9A	10A			-	+	+
Pin No.	2	4	6	8	10	12	14	16	18	20	22	24	
Valve No.	2A	4A	5B	6B	7B	8B	9B	10B		-	-	+	

Example 2



(TOP VIEW)




Pin No.	1	3	5	7	9	11	13	15	17	19	21	23	25
Valve No.	1A	2A	3A	4A	5A	6A	7A	8A			-	+	+
Pin No.	2	4	6	8	10	12	14	16	18	20	22	24	
Valve No.	1B	2B	3B	4B	5B	6B	7B	8B		-	-	+	


D-sub connector (25-pin)

●Wiring specification -D251 □ Pin locations based on JIS specification (Maximum 20 outputs)

Example 1




(TOP VIEW)




Pin No.	1	2	3	4	5	6	7	8	9	10	11	12	13
Valve No.	1A	2A	3A	4A	5A	5B	6A	6B	7A	7B		-	-
Pin No.	14	15	16	17	18	19	20	21	22	23	24	25	
Valve No.	8A	8B	9A	9B	10A	10B	11A	11B	12A	12B	+	+	

Example 2



(TOP VIEW)



Pin No.	1	2	3	4	5	6	7	8	9	10	11	12	13
Valve No.	1A	1B	2A	2B	3A	3B	4A	4B	5A	5B		-	-
Pin No.	14	15	16	17	18	19	20	21	22	23	24	25	
Valve No.	6A	6B	7A	7B	8A	8B	9A	9B	10A	10B	+	+	

Notes: 1. In the figures, the valve numbers 1A, 1B, 2A, 2B... show the stn. numbers, while the letters A and B show the A or B side of the solenoid.

2. The stn. numbers are counted from the left, 1, 2..., with the solenoid on top and the valve outlet ports in front.

3. When selecting wiring connection specification -D, all wiring is double wiring, regardless of valve specifications.

4. The wiring for the block-off plate is normally assigned as double wiring (2 pins to 1 unit), regardless of the wiring specifications. However, when -S is designated as the block-off plate wiring specification, the block-off plate wiring of the station is changed to the single solenoid.


Pin Numbers and Corresponding Solenoids (For Split Manifold Plug-in Type)

The examples below show the relationship between the split manifold pin numbers and the corresponding solenoids. The installation examples show the maximum numbers of outputs in use.

D-sub connector (37-pin)

●Wiring specification -D370U (Maximum 32 outputs)

Example 1




Caution: For the sake of convenience, the connector pins are assigned based on the solenoid valve wiring sequence, which differs from the pin locations and pin numbers (marked) prescribed in JIS-X5103 for the data circuit-terminating equipment (DCE).

JAM18PJ-JR-D370U-D4 stn.1~4 JA10A5-J4-D4
stn.5~17 JA10A6-J4-D4
stn.18 JABPP-J4


Number of units : 18 units
Wiring specification : -D370U
Wiring connection specification :
Blank (packed wiring)

(TOP VIEW)



Pin No.	1	3	5	7	9	11	13	15	17	19	21	23	25	27	29	31	33	35	37
Valve No.	1A	3A	5A	6A	7A	8A	9A	10A	11A	12A	13A	14A	15A	16A	17A	18A			+
Pin No.	2	4	6	8	10	12	14	16	18	20	22	24	26	28	30	32	34	36	
Valve No.	2A	4A	5B	6B	7B	8B	9B	10B	11B	12B	13B	14B	15B	16B	17B	18B			+


Example 2



JAM16PJ-JR-D370U-D-D4 stn.1~4 JA10A5-J4-D4
stn.5~15 JA10A6-J4-D4
stn.16 JABPP-J4

Number of units : 16 units
Wiring specification : -D370U
Wiring connection specification :
-D (double wiring)

(TOP VIEW)



Pin No.	1	3	5	7	9	11	13	15	17	19	21	23	25	27	29	31	33	35	37
Valve No.	1A	2A	3A	4A	5A	6A	7A	8A	9A	10A	11A	12A	13A	14A	15A	16A			+
Pin No.	2	4	6	8	10	12	14	16	18	20	22	24	26	28	30	32	34	36	
Valve No.	1B	2B	3B	4B	5B	6B	7B	8B	9B	10B	11B	12B	13B	14B	15B	16B			+

Notes: 1. In the figures, the valve numbers 1A, 1B, 2A, 2B... show the stn. numbers, while the letters A and B show the A or B side of the solenoid.
2. The stn. numbers are counted from the left, 1, 2..., with the solenoid on top and the valve outlet ports in front.
3. When selecting wiring connection specification -D, all wiring is double wiring, regardless of valve specifications.
4. The wiring for the block-off plate is normally assigned as double wiring (2 pins to 1 unit), regardless of the wiring specifications. However, when -S is designated as the block-off plate wiring specification, the block-off plate wiring of the station is changed to the single solenoid.

Solenoid Valves JA Series

Specifications and Dimensions

Specifications	213
Dimensions of Single Valve Unit	216
Dimensions of Monoblock Manifold	218
Dimensions of Split Manifold	
Non-Plug-in Type	219
Dimensions of Split Manifold Plug-in Type	220
Dimensions of Serial Transmission Type	227

JA SERIES SPECIFICATIONS

Specifications

Basic Models and Functions

Item \ Basic model	JA10□A1 JA10□A2 JA10□A3 JA10□A4	JA10□A5	JA10□A6	JA10□A7 JA10□A8 JA10□A9	JA10□AA JA10□AB JA10□AC
Number of positions	2 positions			3 positions	4 positions
Number of ports	2, 3 ports	5 ports			Tandem 3 ports
Valve function	Single solenoid NC, NO	Single solenoid	Double solenoid	Closed center, Exhaust center, Pressure center	NC/NC, NO/NO, NC/NO

Remark: For the optional specifications and order codes, see p.188.

Specifications

Basic model	JA10□A1 JA10□A2 JA10□A3 JA10□A4	JA10□A5	JA10□A6	JA10□A7 JA10□A8 JA10□A9	JA10□AA JA10□AB JA10□AC
Item					
Media	Air				
Operation type	Internal pilot type				
Effective area [Cv] ^{Note1}	mm ²	3.5 [0.19]		3.4 [0.19]	3.5 [0.19]
Port size ^{Note2}	φ 4, φ 6 fitting, 1/8, 1/4 inch fitting, Rc1/8				
Lubrication	Not required				
Operating pressure range	MPa {kgf/cm ² } [psi.]	0.2~0.7 {2~7.1} [29~102]			
Proof pressure	MPa {kgf/cm ² } [psi.]	1.05 {10.7} [152]			
Response time (ON/OFF) ^{Note 3}	ms	15/15 (15/20) or below	15 (20) or below	15/25 (15/35) or below	15/20 (15/30) or below
Maximum operating frequency	Hz	5			
Minimum time to energize for self holding ^{Note4}	ms	—	50	—	
Operating temperature range (atmosphere and media)	°C [°F]	5~50[41~122]			
Shock resistance	m/s ² {G}	245 {25}			
Mounting direction	Any				

Notes: 1. For details, see the effective area on p.214.

2. For details, see the port size on p.214.

3. Values when air pressure is 0.5MPa [73psi.]. Values in parentheses () are for the low-current specification. In addition, the values for the 3-position valves are switching time from neutral position.

4. For double solenoid valve.

Solenoid Specifications

Rated voltage			DC24V (Standard specification)	DC24V (low current specification)	DC12V (Standard specification)	
Item						
Operating voltage range			V	21.6~26.4 (24±10%)	21.6~26.4 (24±10%)	10.8~13.2 (12±10%)
Standard	Current (when rated voltage is applied) mA(r.m.s)		21	—	42	
	Power consumption W		0.5	—	0.5	
Low current specification	Current (when rated voltage is applied)	Starting mA	—	21	—	
		Holding mA	—	10.5	—	
	Power consumption	Starting W	—	0.5	—	
		Holding W	—	0.25	—	
	Start-up time (standard time) ms		—	50	—	
Allowable leakage current mA		1.0				
Insulation resistance MΩ		Over 100 (value at DC500V megger)				
Color of LED indicator			14 (SA) : Red, 12(SB) : Green			
Surge suppression (as standard)			Surge absorption transistor	Flywheel diode	Surge absorption transistor	

Port Size

Piping specification \ Port	2 (B), 4(A)	1(P)	3, 5(R)
With sub-base	Rc1/8	Rc1/8	Rc1/8
Monoblock manifold	φ 4 [0.157in.] or φ 6 [0.236in.] fitting	Rc1/8	Rc1/8
Split manifold	φ 4 [0.157in.], φ 6 [0.236in.] fitting, or 1/8, 1/4 inch fitting	φ 8 [0.315in.] fitting, or 1/4, 3/8 inch fitting	φ 8 [0.315in.] fitting, or 1/4, 3/8 inch fitting or muffler

Effective Area [Cv]

●When used as a single unit

Basic model	Effective area [Cv]	mm ²
JA10□A1-25 JA10□A2-25 JA10□A3-25 JA10□A4-25 JA10□A5-25 JA10□A6-25	3.2 [0.18]	
JA10□A7-25 JA10□A8-25 JA10□A9-25	3.1 [0.17]	
JA10□AA-25 JA10□AB-25 JA10□AC-25	3.2 [0.18]	


●When mounted on a manifold

Valve model \ Manifold model	mm ² [Cv]			
	JAM□AJ	JAM□N(P)(S)J		
	Outlet port φ4 [0.157in.] fitting	φ6 [0.236in.] fitting	Outlet port φ 4 or 1/8 inch fitting	φ 6 or 1/4 inch fitting
JA10□A1 JA10□A2 JA10□A3 JA10□A4 JA10□A5 JA10□A6	2.8 [0.16]	3.0 [0.17]	3.2 [0.18]	3.5 [0.19]
JA10□A7 JA10□A8 JA10□A9	2.7 [0.15]	2.9 [0.16]	3.1 [0.17]	3.4 [0.19]
JA10□AA JA10□AB JA10□AC	2.8 [0.16]	3.0 [0.17]	3.2 [0.18]	3.5 [0.19]

- Notes: 1. When using the back pressure prevention valve, the effective area of OUT-EXH is reduced to 2.5mm² [Cv=0.14] regardless of the manifold specifications.
2. When the individual air supply spacer is used, effective area decreases about 20%.

Flow Rate

JA10□



1MPa = 145psi., 1 l /min = 0.0353ft³/min.

How to read the graph

When the supply pressure is 0.5MPa [73psi.] and flow rate is 170 l /min [6ft³/min.] (ANR), the valve outlet pressure becomes 0.4MPa [58psi.].

Mass

Single Valve Unit Mass

g [oz.]

Options Valve specification	Wiring specification			Additional mass
	Blank PN	PS MS	PS3 MS3	25 (with sub-base)
JA10□A1~A4	36 [1.27]	40 [1.41]	61 [2.15]	51 [1.80]
JA10□A5				48 [1.69]
JA10□A6	44 [1.55]	49 [1.73]	81 [2.86]	
JA10□A7~A9	46 [1.62]	51 [1.80]	83 [2.93]	
JA10□AA~AC	44 [1.55]	49 [1.73]	81 [2.86]	

Monoblock Manifold Mass

g [oz.]

Monoblock manifold	Mass calculation of each unit (n: number of units)		Additional mass
	Manifold outlet port specification		
	-J4K (ϕ 4 fitting)	-J6K (ϕ 6 fitting)	
Monoblock Manifold AJ type	(33.5×n) [(1.18×n)]	(30.5×n) [(1.08×n)]	79 [2.79]

Block-off plate : 5g [0.18oz.]

Split Manifold Non-Plug-in Type Mass

g [oz.]

Split manifold	Mass calculation of each unit (n: number of units)		Additional mass					
	Manifold outlet port specification		Piping block				End block	
	-J4 (ϕ 4 fitting) -J1/8 (1/8 inch fitting) -J1/4 (1/4 inch fitting)	-J6 (ϕ 6 fitting)	With fitting		Built-in muffler			
			ϕ 8 fitting 1/4 inch fitting	3/8 inch fitting	ϕ 8 fitting 1/4 inch fitting	3/8 inch fitting		
Non-plug-in type	(25.5×n) [(0.90×n)]	(21.5×n) [(0.76×n)]	67 [2.36]	98 [3.46]	66 [2.33]	83 [2.93]	126 [4.44]	

Block-off plate : 5g [0.18oz.]

Split Manifold Plug-in Type Mass

g [oz.]

Split manifold	Mass calculation of each unit (n: number of units)		Additional mass							
	Manifold outlet port specification		Piping block				Wiring block			
	-J4 (φ 4 fitting) -J1/8 (1/8 inch fitting) -J1/4 (1/4 inch fitting)	-J6 (φ 6 fitting)	With fitting		Built-in muffler		-F20□	-F26□	-D25□	-D370U
			φ 8 fitting 1/4 inch fitting	3/8 inch fitting	φ 8 fitting 1/4 inch fitting	3/8 inch fitting				
Plug-in type	(28×n) [(0.99×n)]	(24×n) [(0.85×n)]	67 [2.36]	98 [3.46]	66 [2.33]	83 [2.93]	55 [1.94]	56 [1.98]	58 [2.05]	155 [5.47]

Block-off plate : 5.5g [0.19oz.]

Split Manifold Serial Transmission Type Mass

g [oz.]

Split manifold	Mass calculation of each unit (n: number of units)		Additional mass							
	Manifold outlet port specification		Piping block				Serial transmission block			
	-J4 (φ 4 fitting) -J1/8 (1/8 inch fitting) -J1/4 (1/4 inch fitting)	-J6 (φ 6 fitting)	With fitting		Built-in muffler		-A□	-B1	-D1	End block
			φ 8 fitting 1/4 inch fitting	3/8 inch fitting	φ 8 fitting 1/4 inch fitting	3/8 inch fitting				
Serial transmission type	(28×n) [(0.99×n)]	(24×n) [(0.85×n)]	67 [2.36]	98 [3.46]	66 [2.33]	83 [2.93]	120 [4.23]	129 [4.55]	126 [4.44]	123 [4.34]

Block-off plate : 5.5g [0.19oz.]

Calculation example : **JAM8SJ-JR-B1**

stn.1 ~ 8 JA10A6-J6-D4

$(44 \times 8) + (24 \times 8) + 67 + 129 + 123 = 863\text{g}$

$[(1.55 \times 8) + (0.85 \times 8) + 2.36 + 4.55 + 4.34] = 30.45\text{oz.}$

Dimensions of JA Series Single Valve Unit (mm)

2-, 3-port, single solenoid

JA10□A1-□-PS

JA10□A2-□-PS

JA10□A3-□-PS

JA10□A4-□-PS

S type plug connector


Caution

A1: 2(B) plugged in 2-port normally closed type

A2: 4(A) plugged in 2-port normally open type

A3: 2(B) plugged in 3-port normally closed type


A4: 4(A) plugged in 3-port normally open type



5-port, single solenoid

JA10□A5-□-PS


S type plug connector



5-port, double solenoid


JA10□A6-□-PS

S type plug connector




Options

●Locking protruding type manual override : -83



For single solenoid



For double solenoid

Dimensions of JA Series Single Valve Unit (mm)


5-port, 3-position

JA10□A7-□-PS

JA10□A8-□-PS

JA10□A9-□-PS

S type plug connector




Tandem 3-port, 4-position

JA10□AA-□-PS

JA10□AB-□-PS


JA10□AC-□-PS

S type plug connector



Option

●Locking protruding type manual override : **-83**




JAM ☐ **AJ**



Dimensions of JA Series Split Manifold Non-Plug-in Type (mm)

JAM ☐ NJ



[Installation example]

JAM5NJ-JR

stn.1 JA10A1-PS-J4-D4

stn.2 JA10A5-PS-J4-D4

stn.3 JA10A6-PS-J4-D4

stn.4 JA10A7-PS-J4-D4

stn.5 JABP-J4

Unit dimensions


Number of units	L1	DIN rail length	L2 ^{Note}	DIN rail length ^{Note}
2	75.0	125	93.0	125
3	85.5	125	103.5	150
4	96.0	125	114.0	150
5	106.5	150	124.5	175
6	117.0	150	135.0	175
7	127.5	175	145.5	175
8	138.0	175	156.0	200
9	148.5	200	166.5	200
10	159.0	200	177.0	225
11	169.5	200	187.5	225
12	180.0	225	198.0	250
13	190.5	225	208.5	250
14	201.0	250	219.0	250
15	211.5	250	229.5	275
16	222.0	275	240.0	275
17	232.5	275	250.5	300
18	243.0	275	261.0	300
19	253.5	300	271.5	325
20	264.0	300	282.0	325

Note : When using two piping blocks.

Dimensions of JA Series Split Manifold Plug-in Type (mm)

JAM□PJ

Flat cable connector 20-pin
Connector on side specification




[Installation example]
JAM5PJ-MR-F20□E-D4
stn.1 JA10A1-J6-D4
stn.2 JA10A5-J6-D4
stn.3 JA10A6-J6-D4
stn.4 JA10A7-J6-D4
stn.5 JABPP-J6

Unit dimensions

Number of units	L1	DIN rail length	L2 ^{Note}	DIN rail length ^{Note}
2	95.0	150	113.0	175
3	105.5	175	123.5	175
4	116.0	175	134.0	200
5	126.5	175	144.5	200
6	137.0	200	155.0	200
7	147.5	200	165.5	225
8	158.0	225	176.0	225
9	168.5	225	186.5	250
10	179.0	225	197.0	250
11	189.5	250	207.5	275
12	200.0	250	218.0	275
13	210.5	275	228.5	275
14	221.0	275	239.0	300
15	231.5	300	249.5	300
16	242.0	300	260.0	325

Note : When using two piping blocks.

Flat cable connector 26-pin
Connector on upper side specification




JAM5PJ-JR-F260-D4
stn.1 JA10A1-J4-D4
stn.2 JA10A5-J4-D4
stn.3 JA10A6-J4-D4
stn.4 JA10A7-J4-D4
stn.5 JABPP-J4

Number of units	L1	DIN rail length	L2 ^{Note}	DIN rail length ^{Note}
2	95.0	150	113.0	175
3	105.5	175	123.5	175
4	116.0	175	134.0	200
5	126.5	175	144.5	200
6	137.0	200	155.0	200
7	147.5	200	165.5	225
8	158.0	225	176.0	225
9	168.5	225	186.5	250
10	179.0	225	197.0	250
11	189.5	250	207.5	275
12	200.0	250	218.0	275
13	210.5	275	228.5	275
14	221.0	275	239.0	300
15	231.5	300	249.5	300
16	242.0	300	260.0	325
17	252.5	300	270.5	325
18	263.0	325	281.0	350
19	273.5	325	291.5	350
20	284.0	350	302.0	350

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisanTG.com

Flat cable connector 26-pin
Connector on side specification




Number of units	L1	DIN rail length	L2 ^{Note}	DIN rail length ^{Note}
2	95.0	150	113.0	175
3	105.5	175	123.5	175
4	116.0	175	134.0	200
5	126.5	175	144.5	200
6	137.0	200	155.0	200
7	147.5	200	165.5	225
8	158.0	225	176.0	225
9	168.5	225	186.5	250
10	179.0	225	197.0	250
11	189.5	250	207.5	275
12	200.0	250	218.0	275
13	210.5	275	228.5	275
14	221.0	275	239.0	300
15	231.5	300	249.5	300
16	242.0	300	260.0	325
17	252.5	300	270.5	325
18	263.0	325	281.0	350
19	273.5	325	291.5	350
20	284.0	350	302.0	350

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisanTG.com

JAM□PJ

D-sub connector 25-pin

Connector on upper side specification



[Installation example]

JAM5PJ-JR-D25□-D4

stn.1 JA10A1-J4-D4

stn.2 JA10A5-J4-D4

stn.3 JA10A6-J4-D4

stn.4 JA10A7-J4-D4

stn.5 JABPP-J4

Unit dimensions


Number of units	L1	DIN rail length	L2 ^{Note}	DIN rail length ^{Note}
2	95.0	150	113.0	175
3	105.5	175	123.5	175
4	116.0	175	134.0	200
5	126.5	175	144.5	200
6	137.0	200	155.0	200
7	147.5	200	165.5	225
8	158.0	225	176.0	225
9	168.5	225	186.5	250
10	179.0	225	197.0	250
11	189.5	250	207.5	275
12	200.0	250	218.0	275
13	210.5	275	228.5	275
14	221.0	275	239.0	300
15	231.5	300	249.5	300
16	242.0	300	260.0	325
17	252.5	300	270.5	325
18	263.0	325	281.0	350
19	273.5	325	291.5	350
20	284.0	350	302.0	350

Note : When using two piping blocks.

Dimensions of JA Series Split Manifold Plug-in Type (mm)

JAM□PJ

D-sub connector 25-pin
Connector on side specification



[Installation example]
JAM5PJ-MR-D25□E-D4
stn.1 JA10A1-J6-D4
stn.2 JA10A5-J6-D4
stn.3 JA10A6-J6-D4
stn.4 JA10A7-J6-D4
stn.5 JABPP-J6

Unit dimensions

Number of units	L1	DIN rail length	L2 ^{Note}	DIN rail length ^{Note}
2	95.0	150	113.0	175
3	105.5	175	123.5	175
4	116.0	175	134.0	200
5	126.5	175	144.5	200
6	137.0	200	155.0	200
7	147.5	200	165.5	225
8	158.0	225	176.0	225
9	168.5	225	186.5	250
10	179.0	225	197.0	250
11	189.5	250	207.5	275
12	200.0	250	218.0	275
13	210.5	275	228.5	275
14	221.0	275	239.0	300
15	231.5	300	249.5	300
16	242.0	300	260.0	325
17	252.5	300	270.5	325
18	263.0	325	281.0	350
19	273.5	325	291.5	350
20	284.0	350	302.0	350

Note : When using two piping blocks.

D-sub connector 37-pin
Connector on upper side specification



JAM5PJ-JR3/8-D370U-D4
stn.1 JA10A1-J1/4-D4
stn.2 JA10A5-J1/4-D4
stn.3 JA10A6-J1/4-D4
stn.4 JA10A7-J1/4-D4
stn.5 JABPP-J1/4

Number of units	L1	DIN rail length	L2 ^{Note}	DIN rail length ^{Note}
2	95.0	150	113.0	175
3	105.5	175	123.5	175
4	116.0	175	134.0	200
5	126.5	175	144.5	200
6	137.0	200	155.0	200
7	147.5	200	165.5	225
8	158.0	225	176.0	225
9	168.5	225	186.5	250
10	179.0	225	197.0	250
11	189.5	250	207.5	275
12	200.0	250	218.0	275
13	210.5	275	228.5	275
14	221.0	275	239.0	300
15	231.5	300	249.5	300
16	242.0	300	260.0	325
17	252.5	300	270.5	325
18	263.0	325	281.0	350
19	273.5	325	291.5	350
20	284.0	350	302.0	350

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisanTG.com

JAM ☐ SJ

JAM5SJ-MR-D1
stn.1 JA10A1-J6-D4
stn.2 JA10A5-J6-D4
stn.3 JA10A6-J6-D4
stn.4 JA10A7-J6-D4
stn.5 JABPP-J6

Number of units	L1	DIN rail length	L2 ^{Note}	DIN rail length ^{Note}
2	125.0	175	143.0	200
3	135.5	200	153.5	200
4	146.0	200	164.0	225
5	156.5	225	174.5	225
6	167.0	225	185.0	250
7	177.5	225	195.5	250
8	188.0	250	206.0	275
9	198.5	250	216.5	275
10	209.0	275	227.0	275
11	219.5	275	237.5	300
12	230.0	275	248.0	300
13	240.5	300	258.5	325
14	251.0	300	269.0	325
15	261.5	325	279.5	325
16	272.0	325	290.0	350

Artisan Technology Group - Quality Instrumentation ... Guaranteed | (888) 88-SOURCE | www.artisanTG.com

Artisan Technology Group is an independent supplier of quality pre-owned equipment

Gold-standard solutions

Extend the life of your critical industrial, commercial, and military systems with our superior service and support.

We buy equipment

Planning to upgrade your current equipment? Have surplus equipment taking up shelf space? We'll give it a new home.

Learn more!

Visit us at [artisanng.com](https://www.artisanng.com) for more info on price quotes, drivers, technical specifications, manuals, and documentation.

Artisan Scientific Corporation dba Artisan Technology Group is not an affiliate, representative, or authorized distributor for any manufacturer listed herein.

We're here to make your life easier. How can we help you today?

(217) 352-9330 | sales@artisanng.com | [artisanng.com](https://www.artisanng.com)

