


Rosemount 1153 Series D

Alphaline® Nuclear Pressure Transmitter

Product Discontinued



CE

IMPORTANT NOTICE – ERRATA

Model 1153 Series D Product Manual 00809-0100-4388 Rev BA (January 2008)

No.	Affected Pages	Description of Change	Effect. Date
1	6-8	Process Flagel – CF3M (Cast version of 316L SST) Drain/Vent Valves – 316L SST Process Connections – 3/8-inch Swagelok compression fitting, 316L SST (1/4-18 NPT optional)	10/21/09
2	3-8	Change the first paragraph on the page to read as follows: “Damping electronics are available as an option. Transmitters with standard electronics can be retrofitted with the adjustable damping feature by changing out both the amplifier board and the calibration board. Please reference Table 6-2 (Rosemount 1153 Series D Spare Parts List) for the applicable part numbers.”	4/13/12
3	6-11	Table 6-2, “Rosemount 1153 Series D Spare Parts List”, in all locations the following part numbers are updated: <u>Amplifier Circuit Board, Output Code R:</u> “01154-0001-0005” is replaced by “01154-0153-0001” <u>Amplifier Circuit Board with Damping, Output Code R:</u> “01154-0021-0004” is replaced by “01154-0156-0001” <u>Amplifier Circuit Board, Output Code R, N0026:</u> “01154-0001-0006” is replaced by “01154-0153-0002” <u>Sensor Module, 316 SST⁽⁵⁾</u> 0-5/30 inH ₂ O: “01153-0320-0232” is replaced by “01153-5320-0232” “01153-0320-0132” is replaced by “01153-5320-0132” 0-25/150 inH ₂ O: “01153-0320-0242” is replaced by “01153-5320-0242” “01153-0320-0342” is replaced by “01153-5320-0342” “01153-0320-0142” is replaced by “01153-5320-0142” 0-125/750 inH ₂ O: “01153-0320-0252” is replaced by “01153-5320-0252” “01153-0320-0352” is replaced by “01153-5320-0352” “01153-0320-0152” is replaced by “01153-5320-0152” “01153-0320-0052” is replaced by “01153-5320-0052” 0-17/100 psi: “01153-0320-0262” is replaced by “01153-5320-0262” “01153-0320-0362” is replaced by “01153-5320-0362” “01153-0320-0162” is replaced by “01153-5320-0162” “01153-0320-0062” is replaced by “01153-5320-0062” 0-50/300 psi: “01153-0320-0272” is replaced by “01153-5320-0272” “01153-0320-0372” is replaced by “01153-5320-0372” “01153-0320-0172” is replaced by “01153-5320-0172” “01153-0320-0072” is replaced by “01153-5320-0072” 0-170/1,000 psi: “01153-0320-0282” is replaced by “01153-5320-0282” “01153-0320-0182” is replaced by “01153-5320-0182” “01153-0320-0082” is replaced by “01153-5320-0082” 0-500/3,000 psi: “01153-0320-0192” is replaced by “01153-5320-0192” 0-1,000/4,000 psi: “01153-0320-0102” is replaced by “01153-5320-0102”	4/13/12
4	6-12	Table 6-2, “Rosemount 1153 Series D Spare Parts List”, the table footnotes are updated to add note (5) which will read as follows: (5) IMPORTANT NOTICE: To maintain a transmitter’s qualified configuration, when purchasing or installing a new Sensor Module, Rosemount Qualification report D2011019 must be carefully reviewed to verify that the Sensor Module to be installed and the associated Amplifier Circuit Board in a given transmitter is a qualified configuration. As detailed in the referenced report, not all Sensor Module part numbers are considered qualified in conjunction with certain Amplifier Circuit Boards.	4/13/12
5	6-11	Table 6-2, “Rosemount 1153 Series D Spare Parts List”, in all locations the following part numbers are updated: <u>Amplifier Circuit Board, Output Code R:</u> “01154-0153-0001” is replaced by “01154-0263-0001” <u>Amplifier Circuit Board with Damping, Output Code R:</u> “01154-0156-0001” is replaced by “01154-0266-0001” <u>Amplifier Circuit Board, Output Code R, N0026:</u> “01154-0153-0002” is replaced by “01154-0263-0002”	6/9/17

Rosemount 1153 Series D Alphaline® Pressure Transmitters

NOTICE

Read this manual before working with the product. For personal and system safety, and for optimum product performance, make sure you thoroughly understand the contents before installing, using, or maintaining this product.

For equipment service needs outside the United States, contact the nearest Rosemount representative.

Within the United States, the North American Response Center is at your service 24 hours a day, and is a single-point contact for all Rosemount equipment service needs. If at any time you are not sure what to do, you have a question about using the product, or you have a service or support request, call the center toll free at 1-800-654-RSMT (7768). This contact is your fastest link to quick and complete answers about any Rosemount group, product, or service.

Alphaline, Rosemount and the Rosemount logotype are registered trademarks of Rosemount Inc.

δ-Cell is a trademark of Rosemount Inc.

D.C. 55 is a registered trademarks of Dow Corning.

Loctite is a registered trademark of Henkel KGaA Corporation.

Grafoil is a trademark of Union Carbide Corp.

Swagelok is a registered trademark of Swagelok Co.

Lubri-Bond is a registered trademark of E/M Corporation.

Cover Photo: 1153-001AB



Rosemount Nuclear Instruments, Inc. satisfies all obligations coming from legislation to harmonize product requirements in the European Union.



Rosemount 1153 Series D

Rosemount Nuclear Instruments, Inc. Warranty and Limitations of Remedy

The warranty and limitations of remedy applicable to this Rosemount equipment are as stated on the reverse of the current Rosemount quotation and customer acknowledgment forms.

RETURN OF MATERIAL

Authorization for return is required from Rosemount Nuclear Instruments, Inc. prior to shipment. Contact Rosemount Nuclear Instruments, Inc. (1-952-949-5210) for details on obtaining Return Material Authorization (RMA). **Rosemount Nuclear Instruments will not accept any returned material without a Returned Material Authorization.** Material returned without authorization is subject to return to customer.

Material returned for repair, whether in or out of warranty, should be shipped prepaid to:

Rosemount Nuclear Instruments, Inc.
8200 Market Blvd.
Chanhassen, MN 55317
USA

IMPORTANT

The Rosemount 1153 Series D Pressure Transmitter is designed for Nuclear Class IE usage, has been tested per IEEE Std 323-1974 and 344-1975 as defined in the Qualifications Test Report D8300040, and is manufactured to the requirements of NQA-1; 10CFR50, Appendix B quality assurance programs; and 10CFR Part 21. During qualification testing, interfaces were defined between the transmitter and its environment that are essential to meeting IEEE Std 323-1974 requirements. To ensure compliance with 10CFR Part 21, the transmitter must comply with the requirements herein throughout its installation, operation, and maintenance. It is incumbent upon the user to ensure that the Rosemount Nuclear Instruments, Inc. component traceability program is continued throughout the qualified life of the transmitter.

In order to maintain the qualified life status of the transmitter, the essential environmental interfaces must not be compromised.

Performance of any operations on the transmitter other than those specifically authorized in this manual has the potential for compromising an essential environmental interface.

Where the manual uses the terms *requirements*, *mandatory*, *must*, or *required*, the instructions so referenced must be carefully followed. Rosemount Nuclear Instruments, Inc. expressly disclaims all responsibility and liability for transmitters for which the foregoing has not been complied with by the user.

Revision Status

Changes From 1999 to January 2008

Page (Old)	Page (New)	Changes
Cover	Cover	Document revision date change from May 1999 to January 2008, rev from AA to BA
Inside cover, i, ii, 5-9 & back cover	ii & back cover	Include errata sheet information on address and phone numbers
3-7, 6-9 & 6-10	3-8, 6-11 & 6-12	Include errata sheet information on circuit board number changes: - Replaced amplifier circuit card, output code R P/N 01154-0001-0001 with 01154-0001-0005. - Replaced amplifier circuit card with damping, output code R P/N 01154-0021-0002 with 01154-0021-0004. - Replaced amplifier circuit card, output code R, N0026 P/N 01154-0001-0002 with 01154-0001-0006.
Throughout	Throughout	References to Fisher-Rosemount were changed to Emerson Process Management
i, back cover	Cover, i, ii & back cover	Web address changed from www.rosemount.com to www.rosemountnuclear.com
-	Cover, i, back page	Added reference to European Union product requirement (CE)
2-1,3-1,4-1,5-1,6-1	2-1,3-1,4-1,5-1,6-1	Added table of contents to each section
2-2	2-2	Updated reference to Swagelok catalog and added web address, removed street address
2-2	2-2	Removed word "process" from sentence indicating user assumes responsibility for qualifying the connection interface
2-4	2-4	Rearranged wording on shielded cable, removed reference to 353C
2-6 & 2-7	2-7 & 2-8	Added word 'nominal' to Notes in drawings. Changed significant digits to conform to standards
5-6 & 6-10	5-6 & 6-12	Inserted information on the spare parts kit for bolts and nuts for process flange
6-2	6-2	Changed ISO 9001 to ISO 9001:2000
6-10	6-12	Replaced pipe mount bracket kit (adapters) P/N 01154-0038-0001 with P/N 01154-0044-0001
-	Back cover	Added trademark & registration information

NOTE

The above Revision Status list summarizes the changes made. Please refer to both manuals for complete comparison details.

Table of Contents

SECTION 1	
Introduction	Overview 1-1
	About The Transmitter 1-1
SECTION 2	
Installation	Overview 2-1
	General Considerations 2-1
	Mechanical Considerations 2-2
	Process Connections 2-2
	Conduit 2-4
	Electrical Considerations 2-4
	Installation Procedures 2-6
	Mechanical 2-6
	Transmitter 2-6
	Conduit 2-8
	Electrical 2-9
SECTION 3	
Calibration	Overview 3-1
	Calibration 3-1
	Span Adjustment 3-1
	Zero Adjustment 3-1
	Calibration Procedures 3-3
	Zero and Span Adjustment 3-3
	Linearity Adjustment 3-5
	Damping Adjustment 3-8
	Correction For High Line Pressure (Rosemount 1153DD and 1153HD Only) 3-9
	Span 3-9
	Zero 3-11
SECTION 4	
Operation	Overview 4-1
	Transmitter Operation 4-1
	The d-Cell Sensor 4-3
	Demodulator 4-3
	Linearity Adjustment 4-3
	Oscillator 4-4
	Voltage Regulator 4-4
	Zero And Span Adjustments 4-4
	Current Control 4-4
	Current Limit 4-4
	Reverse Polarity Protection 4-4

Rosemount 1153 Series D

SECTION 5 **Maintenance and** **Troubleshooting**

Overview	5-1
Safety Messages	5-1
Test Terminals	5-2
Board Checkout	5-2
Sensing Module Checkout	5-2
Disassembly Procedure	5-3
Process Flange Removal	5-3
Electrical Housing Disassembly	5-4
Removing Sensor Module from Electrical Housing	5-4
Reassembly Procedure	5-4
Preliminary	5-5
Connecting Electrical Housing to Sensor Module	5-5
Electrical Housing Reassembly	5-5
Process Flange Reassembly	5-6
Post-assembly Tests	5-6

SECTION 6 **Specifications and** **Reference Data**

Nuclear Specifications	6-1
Output Code P	6-1
Output Code R	6-1
Both Output Codes	6-2
Performance Specifications	6-3
Functional Specifications	6-6
Physical Specifications	6-8
Spare Parts Shelf Life	6-12
Important Notice	6-13

Section 1 Introduction

Overview	page 1-1
About The Transmitter	page 1-1

OVERVIEW

This manual is designed to assist in installing, operating, and maintaining the Rosemount 1153 Series D Pressure Transmitter. The manual is organized into the following six sections:

Section 1: Introduction

Section 2: Installation

Provides general, mechanical, and electrical installation considerations to guide you through a safe and effective transmitter installation.

Section 3: Calibration

Provides transmitter calibration procedures.

Section 4: Operation

Provides descriptions of how the transmitter operates.

Section 5: Maintenance and Troubleshooting

Provides basic hardware troubleshooting considerations including sensing module checkout, disassembly and reassembly procedures, and post-assembly tests.

Section 6: Specifications and Reference Data

Provides nuclear, performance, functional, and physical transmitter specifications; also includes ordering information, and a list of spare parts.

ABOUT THE TRANSMITTER

Rosemount 1153 Series D Alphaline Pressure Transmitters are designed for precision pressure measurements in nuclear applications requiring reliable performance and safety over a specified qualified life. These transmitters were generically tested to the IEEE Std 323-1974 and IEEE Std 344-1975 per the Qualification Test Report D8300040. The Rosemount 1153 Series D has been qualification tested to environments typical of Pressurized Water Reactors (PWR) under accident conditions. Stringent quality control during the manufacturing process includes traceability of pressure retaining parts, special nuclear cleaning, and hydrostatic testing.

Rosemount 1153 Transmitters are of a design unique to Class 1E nuclear service while retaining the working concept and design parameters of the Rosemount 1151 Series that have become a standard of reliable service. Units are available in Absolute (A), Gage (G), Differential (D), and High-Line Differential (H) configurations, with a variety of pressure range options (See Table 6-1 on page 6-10). Figure 2-5 on page 2-7 shows transmitter dimensional drawings.

Rosemount 1153 Series D

Reference Manual
00809-0100-4388, Rev BA
January 2008

Section 2 Installation

Overview	page 2-1
General Considerations	page 2-1
Mechanical Considerations	page 2-2
Electrical Considerations	page 2-4
Installation Procedures	page 2-6

OVERVIEW


This section contains information and instructions regarding the following installation-related information:

- General Considerations
- Mechanical Considerations
 - Process Connections
 - Conduit
- Electrical Considerations
- Installation Procedures
 - Mechanical
 - Electrical

GENERAL CONSIDERATIONS

The quality and accuracy of flow, level, or pressure measurement depends largely on the proper installation of the transmitter and its associated impulse piping and valves. For flow measurement, proper installation of the primary measuring element is also critical to the accuracy of the measurement. Transmitter installation should minimize the effects of temperature gradients and temperature fluctuations, and avoid vibration and shock during normal operation. Take care when designing the measurement to minimize the error caused by incorrect installation. The ambient temperature of the transmitter environment affects the qualified life of the transmitter (see Figure 2-1 on page 2-1).

Figure 2-1. Qualified Life vs. Ambient Temperature.



Rosemount 1153 Series D

MECHANICAL CONSIDERATIONS

This section contains information you should consider when preparing to mount the transmitter. Read this section carefully before proceeding to the mechanical installation procedure.

Mount the Rosemount 1153 Series D transmitter to a rigid support (a support with a fundamental mechanical resonant frequency of 40 Hz or greater). A mounting bracket included with the transmitter facilitates panel mounting. Figure 2-4 on page 2-6 shows qualified transmitter mounting configurations. The transmitter was seismic tested and qualified with the bracket mounted using four $\frac{3}{8}$ -in. diameter bolts. Orientation with respect to gravity is not critical to qualification. However, if the transmitter is mounted with the flanges in a horizontal position, rezero the transmitter to cancel the liquid head effect caused by the difference in height of the process connections.

If you mount the transmitter to a non-rigid panel, ensure that seismic input to the mounting bracket does not exceed qualification levels given in Rosemount Report D8300040.

Process Connections

Process tubing installation must prevent any added mechanical stress on the transmitter under seismic disturbances. This may be done by using stress-relief loops in the process tubing or by separately supporting the process tubing close to the transmitter.

The process connections to the transmitter flanges were qualified with $\frac{3}{8}$ -in. tubing using compression fittings (Swagelok®). For options using $\frac{1}{4}$ -18 NPT connections, the user assumes responsibility for qualifying the interface.

Transmitters with Flange Options A, D, H, J, L, or M are shipped with Swagelok fittings for process connections. Included are front ferrule, rear ferrule, and nut. Ensure that they are placed on the tubing with the orientation and relative position shown in Detail A, Figure 2-5 on page 2-7.

Process tubing used is $\frac{3}{8}$ -in. outside diameter, and of suitable thickness for the pressure involved.

The Swagelok tube fittings come completely assembled and are ready for immediate use. **Do not disassemble them before use;** because they may become dirty or a foreign material get into the fitting and cause leaks. Insert the tubing into the Swagelok tube fitting, making sure that the tubing rests firmly on the shoulder of the fitting and that the nut is finger tight. Tighten the nut one-and-one-quarter turns and it is ready for use. **Do not overtighten.**

The connections can be loosened and retightened 20–30 times without compromising the leak-proof seal. To reconnect, insert the tubing with pre-swaged ferrules into the fitting until the front ferrule sits in the fitting. Tighten the nut by hand, then rotate one-quarter turn more or to the original one-and-one-quarter tight position. Then snug it slightly with a wrench. For more information regarding the use of Swagelok tube fittings, refer to:

Fittings Catalog MS-01-140
“Gaugeable Tube Fittings and Adapter Fittings”
www.swagelok.com

If the drain/vent valves must be opened to bleed process lines, torque them to 7½ ft-lb (10 N-m) when closing.

Proper location of the transmitter with respect to the process tubing depends on various process parameters. When determining the best location, consider the following:

- Keep hot or corrosive fluids from contacting the transmitter.
- Prevent sediment from depositing in the impulse tubing.
- Ambient temperature gradients and fluctuations can result in erroneous transmitter readings.
- Keep impulse tubing as short as possible.
- For differential transmitters, balance the liquid head on both legs of the impulse tubing.
- For liquid flow or pressure measurements, make taps on the side of the line to avoid sediment deposits, and mount the transmitter beside or below the taps so gases vent into the process line (see Figure 2-6 on page 2-8).
- For gas flow or pressure measurements, make taps on the top or side of the line and mount the transmitter beside or above the taps so liquid drains into the process line (see Figure 2-6 on page 2-8).
- For steam flow or pressure measurements, make taps on the side of the line, and mount the transmitter below the taps so the impulse tubing stays filled with condensate (See Figure 2-6 on page 2-8).
- For steam service, fill the lines with water to prevent steam from contacting the transmitter. Condensate chambers are not necessary since the volumetric displacement of the transmitter is negligible.

The piping between the process and the transmitter must transfer the pressure measured at the process taps to the transmitter. Possible sources of error in this pressure transfer are:

- Leaks.
- Friction loss (particularly if purging is used).
- Trapped gas in a liquid line or trapped liquid in a gas line (head error).
- Temperature-induced density variation between legs (head error), for differential transmitters.

To minimize the possibility of errors, take the following precautions:

- Make impulse tubing as short as possible.
- Slope tubing at least one inch per foot up toward the process connections for liquid and steam.
- Slope tubing at least one inch per foot down toward the process connections for gas.
- Avoid high points in liquid lines and low points in gas lines.
- Use impulse tubing of sufficient diameter to avoid friction effects.
- Ensure that all gas is vented from liquid tubing legs.
- Ensure that impulse tubing is of adequate strength to be compatible with anticipated pressures.

For differential transmitters, also consider the following:

- Keep both impulse legs at the same temperature.
- When using sealing fluid, fill both piping legs to the same level.
- When purging, make the purge connection close to the process taps and purge through equal lengths of the same size tubing. Avoid purging through the transmitter.

Conduit

The conduit connection to the transmitter is $\frac{1}{2}$ –14 NPT. Use a qualified conduit seal at the conduit entry to prevent moisture from accumulating in the terminal side of the housing during accident conditions. To prevent the conduit from adding mechanical stress to the transmitter during seismic disturbances, use flexible conduit or support the conduit near the transmitter. Install the conduit seal in accordance with the manufacturer's instructions or use the procedure on page 2-8.

ELECTRICAL CONSIDERATIONS

This section contains information that you should consider when preparing to make electrical connections to the transmitter. Read this section carefully before proceeding to the electrical installation procedures.

The Rosemount 1153 Series D pressure transmitter provides a 4–20 mA signal when connected to a suitable dc power source. Figure 2-2 on page 2-5 illustrates a typical signal loop consisting of transmitter, power supply, and various receivers (i.e., controller, indicator, computer). The power supply must supply at least 12 volts to the transmitter terminals at 30 mA (overscale) signal, or the maximum output current required for proper system operation. Any power supply ripple appears in the output load. The supply voltage versus load limitation relationship is shown in Figure 2-3 on page 2-5. See qualification report D8300040 for details. The load is the sum of the resistance of the signal leads and the load resistance of the receivers.

Signal wiring need not be shielded, but twisted pairs yield the best results. In electrically noisy environments, shielded cable should be used for best results. Do not run signal wiring in conduit or open trays with power wiring, or near heavy electrical equipment. Signal wiring may be ungrounded (floating) or grounded at any place in the signal loop. The transmitter case may be grounded or ungrounded.

The capacitance-sensing element uses alternating current to generate a capacitance signal. This alternating current is developed in an oscillator circuit with a frequency of $32,000 \pm 10,000$ Hz. This 32,000 Hz signal is capacitor coupled to transmitter case ground through the sensing element. Because of this coupling, a voltage may be imposed across the load, depending on choice of grounding.

This impressed voltage, which is seen as high-frequency noise, has no effect on most instruments. Computers with short sampling times in a circuit where the negative transmitter terminal is grounded will detect a significant noise signal. Filter this noise with a large capacitor (1 μ f) or by using a 32,000 Hz LC filter across the load. Signal loops grounded at any other point are negligibly affected by this noise and do not need filtering.

Terminal Side
(Cover Removed)

Output Code P

4—20 mA DC

Load Resistance (Ω)

Power Supply (V DC)

Qualified Region

Design Region

2000
1650
1500
1325
1000
500
0

0 12 13.5 30 40 45

Output Code R

4—20 mA DC

Load Resistance (Ω)

Power Supply (V DC)

Qualified Region

Design Region

1825
1575
1500
1000
500
0

0 12 13.5 35 40 45 50

Rosemount 1153 Series D

INSTALLATION PROCEDURES

Installation consists of mounting the transmitter and conduit and making electrical connections. Following are procedures for each operation.

Mechanical

Transmitter


⚠ CAUTION

Be careful not to break the neck seal between the sensor module and the electronics housing.

The threaded interface between the sensor module and the electronics housing is hermetically sealed before shipment. The integrity of this seal is necessary for the safe operation of the transmitter during accident conditions. If the seal is broken, reseal it according to "Connecting Electrical Housing to Sensor Module" on page 5-5.


1. Mount the bracket to a panel or other flat surface (see Figure 2-4 on page 2-6). Use four $\frac{3}{8}$ -in. diameter bolts (not supplied with unit). SAE grade 2 bolts were used during qualification testing. Torque each bolt to 19 ft-lb (26 N-m).
2. Attach the transmitter to the mounting bracket (see Figure 2-4 on page 2-6). Use four $\frac{7}{16}$ -20 $\times$ $\frac{3}{4}$ bolts with washers (supplied with unit). Torque each bolt to 21 ft-lb (29 N-m).

Figure 2-4. Typical Transmitter Mounting Bracket Configuration.



Rosemount 1153 Series D

Figure 2-5. Transmitter Dimensional Drawings.




Rosemount 1153 Series D

Conduit

1. Seal the conduit threads with thread sealant (the transmitter conduit seal interface was qualified using Grafoil™ tape). Conduit threads mate with a standard 1/2–14 NPT male fitting.
2. Starting at zero thread engagement, install the conduit into the transmitter between 4 and 7 turns, or a minimum of 12.5 ft-lb (16.9 N-m). Hold the electronics housing securely to avoid damaging the threaded neck seal between the sensor module and the electronics housing during conduit installation.
3. Provide separate support for the conduit if necessary.

Figure 2-6. Transmitter Installation Configurations



Electrical


1. Remove the cover from the terminal side of the transmitter (see Figure 2-5 on page 2-7).
2. Connect the power leads to the “SIGNAL” terminals on the transmitter terminal block (see Figure 2-7 on page 2-9). Torque the terminal screws to 5 in-lb (0.6 N-m), or hand-tight.

CAUTION

Do not connect signal leads to the “TEST” terminals.

3. Recheck the connections for proper polarity.
4. Check the cover O-ring grooves for cleanliness. If chips or dirt are present, clean the seat and mating portion of the cover with alcohol. Lubricate replacement O-ring with O-ring grease (RMT P/N 01153-0248-0001 or P/N 01153-0053-0001). The transmitter was qualified using Dow Corning® 55 Silicone O-ring Grease.
5. Spray the inside threads of the electronics covers with cover lubricant (Rosemount P/N 01153-0333-0001 or equivalent) if necessary; if covers are already sufficiently lubricated, do not spray.
6. Carefully replace the cover and tighten to 16.5 ft-lb (22.4 N-m).

Figure 2-7. Transmitter Terminal Block.



Section 3 Calibration

Overview	page 3-1
Calibration	page 3-1
Calibration Procedures	page 3-3

OVERVIEW

Each transmitter is factory calibrated to the range specified by the customer. This section contains the following transmitter calibration information:

- Calibration
 - Span Adjustment
 - Zero Adjustment
- Calibration Procedures
 - Span and Zero Adjustment
 - Linearity Adjustment
 - Damping Adjustment
 - Correction for High Line Pressure

CALIBRATION

The Rosemount 1153DD, HD, GD, and AD Transmitters are factory calibrated to the range shown on the nameplate. This range may be changed within the limits of the transmitter. Zero may also be adjusted to elevate (for all models except the Rosemount 1153AD) or suppress (for all models). The span and zero adjustments are external and located under the nameplate.

Span Adjustment

The span on any Rosemount 1153 Series D Pressure Transmitter is continuously adjustable to allow calibration anywhere between maximum span and $\frac{1}{6}$ of maximum span ($\frac{1}{4}$ of maximum span for Range 0). For example, the span on a Range Code 4 transmitter can be continuously adjusted between 0–150 and 0–25 inH₂O.

Zero Adjustment


The zero can be adjusted for up to 500 percent of span suppression (300 percent for Range code 0) or 600 percent of span elevation (400 percent for Range code 0) (see Figure 3-1 on page 3-2).

The zero may be elevated or suppressed to these extremes with the limitation that no applied pressure within the calibrated range exceeds the full-range pressure limit. For example, a Range Code 4 transmitter cannot be calibrated for 150 to 200 in H₂O (only 300 percent zero suppression) because the 200 in H₂O exceeds the 150 inH₂O upper range pressure limit of a Range Code 4.

The transmitter may be calibrated to cross zero (e.g., –75 to 75 inH₂O) but this may result in a slight loss of linearity

Rosemount 1153 Series D

Figure 3-1. Zero Adjustment Range.



CALIBRATION PROCEDURES

Zero and Span Adjustment

NOTE

The Rosemount 1153 Series D Pressure Transmitter contains electronic circuit boards which may be static sensitive.


NOTE

Covers need not be removed for zero and span adjustment.

The zero and span adjustment screws are accessible externally. They are located behind the nameplate on the side of the electronics housing (see Figure 3-2 on page 3-3). The transmitter output increases with clockwise rotation of the adjustment screws.

The zero adjustment screw has very little effect on the span. The span adjustment, however, does affect the zero. The effect of interaction is more apparent with suppression or elevation. The span adjustment changes the zero output and the full-scale output by approximately the same percentage. Therefore, it is best to calibrate the transmitter from zero to the desired span and finish the calibration by adjusting the zero screw to achieve the desired elevation or suppression.

Figure 3-2. Zero and Span Adjustment.

**Example (for Range Code 4)**

Initial Transmitter Calibration: 25 to 125 inH₂O
(100 inH₂O span with zero suppressed 25 inH₂O).

Desired Transmitter Calibration: -75 to -25 inH₂O
(50 inH₂O span with zero elevated 75 inH₂O).

1. Adjust the zero to eliminate any existing zero elevation or suppression. With 0 inH₂O pressure applied to the transmitter, turn the zero adjustment until the output reads 4 mA. The unit is now calibrated for 0 to 100 inH₂O.
2. Adjust the span to the desired new span. To reduce the span, turn the span screw until the output, with 0 inH₂O pressure input, equals 8 mA:

$$4 \text{ mA} \times \frac{\text{Existing Span}}{\text{Desired Span}} = 4 \text{ mA} \times \frac{100 \text{ inH}_2\text{O}}{50 \text{ inH}_2\text{O}} = 8 \text{ mA}$$

3. Adjust the zero screw to bring the output, with 0 inH₂O input, back to 4 mA. The transmitter calibration should now be very close to 0 to 50 inH₂O.
4. Check the full-scale output and fine tune the span and zero adjustment if required. Remember zero adjustments do not affect span, but span adjustments do affect zero predictably. Adjusting the span screw affects the zero $\frac{1}{5}$ as much as it affects the span. To compensate for this effect, simply overadjust by 25 percent. For example, if, after completing step 3, the transmitter output reads 19.900 mA at 50 inH₂O, turn the span potentiometer until the output (at 50 inH₂O) reads 20.025 mA.

$$19.900 + (20.000 - 19.900) \times 1.25 = 19.900 + 0.125 = 20.025$$

Since the span adjustment affects zero $\frac{1}{5}$ as much as the span, the 0.125 mA increase in span causes a 0.025 mA increase in zero. Therefore, turn the zero adjustment (at 50 inH₂O) until the output reads 20.000 mA. The unit should now be calibrated for 0 to 50 in H₂O.

5. Zero Elevation/Suppression. Elevate zero. Turn the screw until the output reads 4 mA with -75 inH₂O applied to the high side of the transmitter (applying 75 inH₂O to the low side will give the same result). The output may stop changing before the desired 4 mA reading is obtained. If this occurs, turn off power to the unit and unplug the amplifier board (refer to Electrical Housing Disassembly procedure on page 5-4 for cover removal and Figure 5-2 on page 5-7 to locate the amplifier board). To elevate or suppress zero a large amount, use the following procedure:

A. Material

- Wire: 22 gauge tinned solid copper-Fed Spec QQW343, ASTM B33.
- Solder: 60% tin, 40% lead (60/40)-Fed Spec QQ-S-571.
- Flux: Mil F 14256, Type A, Fed Spec QQ-S-571 Type RA.

For transmitters with Output Code P electronics, follow Method B1 for Zero Elevation/Suppression if the amplifier board has four holes. Follow Method B2 if the amplifier board has three turrets (see Figure 3-3 on page 3-7).

For transmitters with Output Code R electronics, follow Method B2.

B1. Method (Output Code P—Amplifier Board with Holes)

- a. Cut the jumper wire, form, and insert across 2 jumper pads on the component side of the board in the “elevate zero” position (see Figure 3-3 (Detail A2) on Page 3-7).
- b. Turn the board over and clip the wire ends to the appropriate length. In accordance with proper electronic practices, solder the jumper wire to the board. Clean solder joints with isopropyl alcohol.
- c. Plug the amplifier board back in and complete the zero adjustment.

To suppress zero follow the same procedure except position the jumper wire on the board in the “suppress zero” position (see Figure 3-3 (Detail A3) on Page 3-7).

B2. Method (Output Code R and Output Code P—Amplifier Board with Turrets)

- a. Locate 3 turret terminals on the component side of the amplifier board. Remove any jumper wires between them (Figure 3-3 on page 3-7).
- b. To elevate zero, connect a jumper wire between the middle terminal and the terminal marked “EZ” (see Figure 3-3 (Detail B2) on Page 3-7).
- c. Wrap the jumper wire once around each terminal and cut off the excess.
- d. Solder the jumper wire to the terminals using proper electronics soldering techniques. Clean solder joints thoroughly with isopropyl alcohol.
- e. Plug the amplifier board back in and complete the zero adjustment.

To suppress zero, follow the same procedure, except connect the jumper wire between the middle terminal and the terminal marked “SZ” (see Figure 3-3 (Detail B3) on Page 3-7).

6. Recheck full scale and zero and fine tune if necessary.

NOTE

There is some mechanical backlash in the zero and span adjustments, so there will be a dead band when you change the direction of adjustment. Because of the backlash, the simplest procedure, if the desired setting is overshoot, is to intentionally overshoot a larger amount before reversing the direction of the adjustment.

Linearity Adjustment

In addition to the span and zero adjustments, there is a linearity adjustment located inside the transmitter on the amplifier board (see Figure 3-4 on page 3-8). Linearity is factory calibrated for optimum performance over the calibrated range of the instrument and is not normally adjusted in the field. If you want to maximize linearity over some particular range, use the following procedure:

1. Apply mid-range pressure and note the error between theoretical and actual output signal.
2. Apply full-scale pressure. Multiply the error noted in step 1 by six and by the rangedown factor.

$$\text{Rangedown Factor} = \frac{\text{Maximum Allowable Span}}{\text{Calibrated Span}}$$

3. Add the result to the full-scale output for negative errors, or subtract the result from the full-scale output for positive errors, by adjusting the linearity trimmer (see Figure 3-4 on page 3-8). Example: At 4-to-1 rangedown the midscale point is low by 0.05 mA. Therefore, adjust the "Linearity" trimmer until full-scale output increases by $(0.05 \text{ mA} \times 6 \times 4) = 1.2 \text{ mA}$.
4. Readjust zero and span.

NOTE

If you remove either cover during the above procedures, replace the O-ring and torque the cover per the instructions given in Section 5 Maintenance and Troubleshooting. Spare cover O-rings are supplied with each transmitter.

Figure 3-3. Jumper Wire Placement.





Figure 3-4. Linearity and Damping Adjustment.



Damping Adjustment

Damping electronics are available as an option. Transmitters with standard electronics can be retrofitted with the adjustable damping feature by changing out both the amplifier board (RMT P/N 01154-0021-0004) and the calibration board (RMT P/N 01154-0023-0002).

The damping adjustment permits damping of rapid pressure variations by adjusting the single-turn trim potentiometer located on the upper right-hand side of the amplifier board (see Figure 3-4 on page 3-8). The available settings, when adjusted to the maximum position, provide time-constant values of at least 1.2 seconds for Range Code 4 and 0.8 seconds for Range Codes 5–9. Transmitters with the electronic damping option are calibrated and shipped with the adjustment set at the counterclockwise stop, giving the minimum time-constant.

To adjust the damping, turn the damping adjustment potentiometer until the desired time-constant is obtained. It is best to set the damping to the shortest possible time-constant. Since transmitter calibration is not affected by the damping setting, you may adjust the damping with the transmitter installed in the process.

⚠ CAUTION

The damping adjustment potentiometer has positive stops at both ends. Forcing the potentiometer beyond the stops may cause permanent damage.

NOTE

If you remove either cover during the above procedures, replace the O-ring and torque the cover per the instructions provided in **Section 5 Maintenance and Troubleshooting**. Spare cover O-rings are supplied with each transmitter.

Correction For High Line Pressure (Rosemount 1153DD and 1153HD Only)

Span

If a differential transmitter is calibrated with the low side at ambient pressure but will be used at high line pressure, correct the span adjustment to compensate for the effect of static pressure on the unit. If zero is elevated or suppressed, also correct the zero adjustment. Correction factors, expressed in percent of differential pressure input at end points per 1,000 psi static pressure, are:

Range 3:

+1.5% of input/1,000 psi

Ranges 4, 5, and 8:

+0.75% of input/1,000 psi

Ranges 6 and 7:

+1.25% of input/1,000 psi

The correction procedure below uses the following example: Range 5, calibrated –100 to 300 inH₂O to be operated at 1,200 psi line pressure. Note that steps 3–6 are omitted for ranges based at zero differential pressure.

1. Calibrate the unit per preceding section to output = 4 mA at –100 inH₂O and 20 mA at 300 inH₂O.

2. Calculate correction factor:

$$\frac{0.75 \%}{1,000 \text{ psi}} \times 1200 \text{ psi} = 0.9\% \text{ differential input}$$

3. Calculate zero adjustment correction in terms of pressure:

$$0.9 \% \times -100 \text{ inH}_2\text{O} = -0.9 \text{ inH}_2\text{O}$$

4. Convert pressure correction to percent of input span:

$$\frac{-0.9 \text{ inH}_2\text{O}}{400 \text{ inH}_2\text{O input span}} = -0.225 \% \text{ span}$$

5. Calculate correction in terms of output span (mA):

$$-0.225 \% \times 16 \text{ mA span} = -0.036 \text{ mA}$$

6. Add the milliamp correction to the ideal zero output (4 mA). This is the corrected ideal zero output:

$$4.00 \text{ mA} - 0.036 = 3.964 \text{ mA}$$

7. Calculate full-scale adjustment correction in terms of pressure:

$$0.9 \% \times 300 \text{ inH}_2\text{O} = 2.7 \text{ inH}_2\text{O}$$

8. Repeat step 4 with the results of step 7:

$$\frac{2.7 \text{ inH}_2\text{O}}{400 \text{ inH}_2\text{O input span}} = 0.675 \% \text{ span}$$

9. Repeat step 5 with the result of step 8:

$$0.675 \% \times 16 \text{ mA span} = 0.108 \text{ mA}$$

10. Add the mA correction to the ideal full-scale output (20 mA). This is the corrected ideal full-scale output.

$$20.00 \text{ mA} + 0.108 \text{ mA} = 20.108 \text{ mA}$$

11. Readjust zero and span adjustments for corrected outputs:

$$\begin{aligned} &3.964 \text{ mA at } -100 \text{ inH}_2\text{O} \\ &20.108 \text{ mA at } 300 \text{ inH}_2\text{O} \end{aligned}$$

There is an uncertainty of ± 0.5 percent of input reading per 1,000 psi associated with the span correction.

Zero

Zero shift with static pressure is not systematic. However, if the calibrated range includes zero differential pressure, the effect can be trimmed out after installation and with the unit at operating pressure.

Equalize pressure to both process connections, and turn the zero adjustment until the ideal output at zero differential input is observed. Do not readjust the span potentiometer.

If the transmitter does not include zero differential pressure within its calibrated span, the zero effect or zero correction can be determined before the unit is suppressed or elevated to eliminate the zero effect after correcting for the span effect.

The following procedure illustrates how to eliminate the zero effect for a non-zero differential pressure calibration. The example uses a Range 5 calibrated from 100 to 500 inH₂O with 1,200 psi static line pressure.

1. Using standard calibration procedures, calibrate the unit to the required span, with the 4 mA or zero point corresponding to zero differential pressure:

4 mA at 0 inH₂O and 20 mA at 400 inH₂O

2. Apply static pressure to both high and low process connections with zero differential pressure across the transmitter, and note the zero correction (zero shift). For example, if the output reads 4.006 mA, the zero correction is calculated as:

$$4.00 \text{ mA} - 4.006 \text{ mA} = -0.006 \text{ mA}$$

Note the sign associated with this correction, as this result is added when determining the final, ideal transmitter output.

3. Remove static pressure and correct for the span effect as outlined in the span correction procedure. Calibrate the unit to the calculated output values. If, for example, the span correction procedure yielded 4.029 mA and 20.144 mA, calibrate the unit for:

4.029 mA at 100 inH₂O
20.144 mA at 500 inH₂O

4. Add the zero correction (–0.006 mA), found in step 2, to the ideal zero point value calculated in step 3.

$$4.029 \text{ mA} + (-0.006 \text{ mA}) = 4.023 \text{ mA}$$

5. To eliminate the zero effect, readjust the zero potentiometer so the output reads the ideal zero point calculated in step 4 (do not readjust the span potentiometer). Note that all the calibration points will shift the same amount toward the correct reading. The example output is now 4.023 mA at 100 inH₂O.

The transmitter output is now 4–20 mA over its calibrated span when the unit is operated at 1,200 psi static line pressure.

Section 4 Operation

Overview	page 4-1
Transmitter Operation	page 4-1
The δ -Cell Sensor	page 4-3
Demodulator	page 4-3
Linearity Adjustment	page 4-3
Oscillator	page 4-4
Voltage Regulator	page 4-4
Zero And Span Adjustments	page 4-4
Current Control	page 4-4
Current Limit	page 4-4
Reverse Polarity Protection	page 4-4

OVERVIEW

This section provides brief descriptions of basic transmitter operations in the following order:

- Transmitter Operation
- The δ -Cell™ Sensor
- Demodulator
- Linearity Adjustment
- Oscillator
- Voltage Regulator
- Zero and Span Adjustments
- Current Control
- Current Limit
- Reverse Polarity Protection

TRANSMITTER OPERATION

The block diagram in Figure 4-1 on page 4-2 illustrates the operation of the transmitter.

Rosemount 1153 Series D Alphaline Pressure Transmitters have a variable capacitance sensing element, the δ -Cell (see Figure 4-2 on page 4-3). Differential capacitance between the sensing diaphragm and the capacitor plates is converted electronically to a 2-wire 4–20 mA dc signal.

$$P = K_1 \left(\frac{C_2 - C_1}{C_1 + C_2} \right)$$

Where:

P is the process pressure.

Rosemount 1153 Series D

K_1 is a constant.

C_1 is the capacitance between the high pressure side and the sensing diaphragm.

C_2 is the capacitance between the low pressure side and the sensing diaphragm.

$$fV_{p-p} = \frac{I_{ref}}{C_1 + C_2}$$

Where:

I_{ref} is the current source.

V_{p-p} is the peak-to-peak oscillation voltage.

f is the oscillation frequency.

$$I_{diff} = fV_{p-p}(C_2 - C_1)$$

Where:

I_{diff} is the difference in current between C_1 and C_2 .

Therefore:

$$P = \text{Constant} \times I_{diff} = I_{ref} \left(\frac{C_2 - C_1}{C_2 + C_1} \right)$$

Figure 4-1. Electrical Block Diagram.





Figure 4-2. The δ -Cell.



THE δ -CELL SENSOR

Process pressure is transmitted through an isolating diaphragm and silicone oil fill fluid to a sensing diaphragm in the center of the δ -Cell. The reference pressure is transmitted in like manner to the other side of the sensing diaphragm.

The position of the sensing diaphragm is detected by the capacitance plates on both sides of the sensing diaphragm. The capacitance between the sensing diaphragm and either capacitor plate is approximately 150 pF. The sensor is driven through transformer windings by an oscillator at roughly 32 kHz and 30 Vp-p.

DEMODULATOR

The demodulator consists of a diode bridge that rectifies the ac signal from the sensor cell to a dc signal.

The oscillator driving current, I_{ref} (the sum of the dc currents through two transformer windings) is controlled to be a constant by an integrated circuit amplifier.

The dc current through a third transformer winding is a current directly proportional to pressure; i.e.:

$$I_{diff} = fV_{p-p} (C_2 - C_1)$$

The diode bridge and span temperature-compensating thermistor are located inside the sensor module. The effect of the thermistor is controlled by resistors located in the electronics housing.

LINEARITY ADJUSTMENT

Linearity is adjusted by a variable-resistance network, capacitor, and diodes. The currents generated through this part of the circuit are summed into the inputs of the oscillator control circuit. This provides a programmed correction that raises the oscillator peak-to-peak voltage to compensate for first-order nonlinearity of capacitance as a function of pressure.

OSCILLATOR

The oscillator has a frequency determined by the capacitance of the sensing element and the inductance of the transformer windings.

The sensing element capacitance is variable. Therefore, the frequency is variable about a nominal value of 32 kHz.

An integrated circuit amplifier is used as a feedback control circuit and controls the oscillator drive voltage such that:

$$fV_{p-p} = \frac{I_{ref}}{C_1 + C_2}$$

VOLTAGE REGULATOR

The transmitter uses a zener diode, transistor, and resistors to provide a constant voltage of 6.4 V dc for the reference and 7 V dc for the oscillator.

ZERO AND SPAN ADJUSTMENTS

Zero adjustment components consist of a potentiometer and resistor that develop a separate adjustable current that sums with the sensor current. The coarse zero switch switches resistors into the circuit as needed.

Span adjustment is performed with a potentiometer that determines the amount of loop current that is sensed and fed back to the current control amplifier.

CURRENT CONTROL

The current control amplifier consists of an integrated circuit, two transistors, and associated components. The IC reference voltage is established at the junction of a resistor network. The current control amplifier drives the current control to a level such that the current detector feeds back a signal equal to the sum of the zero current and the variable sensor current.

CURRENT LIMIT

A current limiter prevents the output current from exceeding 30 mA in an overpressure condition.

REVERSE POLARITY PROTECTION

A zener diode provides reverse polarity protection.

Section 5 Maintenance and Troubleshooting

Overview	page 5-1
Safety Messages	page 5-1
Test Terminals	page 5-2
Board Checkout	page 5-2
Sensing Module Checkout	page 5-2
Disassembly Procedure	page 5-3
Reassembly Procedure	page 5-4
Post-assembly Tests	page 5-6

OVERVIEW

This section outlines a technique for checking out the components, a method for disassembly and reassembly, and a troubleshooting guide.

NOTE

Maintenance of traceability of replacement parts is the responsibility of the user (see “Important Notice” on page 6-13 and **Important Notice** at beginning of this manual, preceding Table of Contents).

The Rosemount 1153 Series D has no moving parts and requires a minimum of scheduled maintenance. Calibration procedures for range adjustment are outlined in **Section 3, Calibration**. A calibration check should be conducted after inadvertent exposure to overpressure, unless your plant considers this factor separately in the plant error analysis.

Test terminals are available for in-process checks. For further checks, the transmitter can be divided into three active physical components: the sensing module, the amplifier board, and the calibration board.

An exploded view of the transmitter is provided in Figure 5-2 on page 5-7. In the following procedures, numbers in parentheses refer to item numbers in the exploded view.

SAFETY MESSAGES

Instructions and procedures in this section may require special precautions to ensure the safety of the people performing the operations. Information that raises potential safety issues is indicated by a warning message. The following warning messages appear in this section.

WARNING

Use only the procedures and new parts specifically referenced in this manual to ensure specification performance and certification compliance. Unauthorized procedures or parts can render the instrument dangerous to life, limb, or property.

⚠ WARNING

Process o-rings may retain some process fluid after disassembly of process flanges. If this fluid is determined to be contaminated, take appropriate safety measures.

TEST TERMINALS

The test terminals are connected across a diode through which the loop signal current passes. The indicating meter or test equipment shunts the diode when connected to the test terminals. As long as the voltage across the terminals is kept below the diode threshold voltage, no current passes through the diode. To insure that there is no current leaking through the diode while making a test reading or when connecting an indicating meter, the resistance of the test connection or meter should not exceed 10 Ω .

BOARD CHECKOUT

NOTE

Numbers in parentheses refer to item numbers in Figure 5-2 on page 5-7.


NOTE

The Rosemount 1153 Series D Pressure Transmitter contains electronic circuit boards which may be static sensitive.

You can easily check the printed circuit boards (5 and 6) for a malfunction by substituting spare boards into the circuit. If this procedure turns up a malfunctioning board, return the defective board to Rosemount Nuclear Instruments, Inc. for replacement. Because of parts traceability, qualification becomes the responsibility of the customer in the event of unauthorized board repairs.

The “R” and “P” electronics circuits boards are interchangeable and either may be used. They must, however, be used as a pair (i.e., **you must use an “R” calibration board with the “R” amplifier board and not with the “P” amplifier board**). This also applies to the “P” calibration board.

Figure 5-1. Header Board Connections.



SENSING MODULE CHECKOUT

NOTE

Numbers in parentheses refer to item numbers in Figure 5-2 on page 5-7.

The sensing module (12) is not field-repairable and must be replaced if defective. If no defect such as a punctured isolating diaphragm or loss of fill fluid is observed, check the sensing module in the following manner.

1. Disengage the header assembly board (4) as described in the electrical housing disassembly procedure on 5-4. You need not remove the sensing module from the electrical housing for checkout.
2. Jump connections 1 and 2 on the header assembly board (see Figure 5-1 on page 5-2).
3. Using a low-voltage ohmmeter, check the resistance between the jumper wire and sensing module housing. This resistance should be greater than 10 MΩ. Remove the jumper wire.
4. Jump connections 3 and 4 on the header assembly board and repeat step 3 (see Figure 5-1 on page 5-2).

NOTE

The above procedure does not completely test the sensing module. If circuit board replacement does not correct the abnormal condition and no other problems are obvious, replace the sensing module.

DISASSEMBLY PROCEDURE

NOTE

Numbers in parentheses refer to item numbers in Figure 5-2 on page 5-7.

NOTE

The Rosemount 1153 Series D Pressure Transmitter contains electronic circuit boards which may be static sensitive.

Process Flange Removal

⚠ WARNING

Process O-rings may retain some process fluid after disassembly of process flanges. If this fluid is determined to be contaminated, take appropriate safety measures.

NOTE

Read the Process Flange Reassembly procedure on page 5-6 before attempting disassembly. Special testing and traceability are required.

1. Remove the transmitter from service before disassembling flanges.
2. Detach process flanges (13, 15) by removing the four large bolts (14). **Take care not to scratch or puncture the isolating diaphragms.** Identify high and low ("H" and "L") flanges for reassembly.

NOTE

Carefully remove the O-rings (11) from the cell if they do not come off when the flange is removed. Do not pry the O-ring from its seat as you may damage the isolating diaphragm.

3. Clean isolating diaphragms with a soft rag and a mild cleaning solution. Do not use any chlorine or acid solutions to clean the diaphragms. Rinse diaphragms with distilled water.

Rosemount 1153 Series D

Electrical Housing Disassembly

1. The signal terminals and test terminals are accessible by unscrewing the cover (1) on the terminal side. This compartment is identified as "terminal side" on the nameplate. The terminals are permanently attached to the housing and must not be removed.
2. Circuit boards are located in a separate compartment identified as "Circuit Side" on the nameplate. Remove power from the transmitter before removing the circuit side cover. Unscrew the cover (1) on the circuit side to access the circuit boards. A special cover wrench (RMT P/N 01153-0382-0001) is available from Rosemount to remove and replace the housing covers.
3. Unplug the amplifier board (6) after removing three holding screws (7).
4. The header assembly board (4) is permanently attached to the sensor module (12) and contains the temperature-compensating resistors. Carefully pull this board off the bayonet pins and rotate the board 180 degrees about the axis formed by the connecting leads. This allows access to the calibration board (5).
5. Disconnect the calibration board (5) by aligning the zero and span adjust screws so that their slots are perpendicular to the board. Remove the board by inserting a 6–32 screw in the rivnut on the board and carefully pulling the board off the bayonet pins.
6. If replacement of the zero and span adjustment screws (16) is necessary, remove the nameplate (17) and detach the snap rings (18) inside the housing.

Removing Sensor Module from Electrical Housing

1. Remove flanges per "Process Flange Removal" on page 5-3.
2. Remove amplifier board and calibration board as described in the "Electrical Housing Disassembly Section" above.
3. Loosen the lock nut (9).
4. Unscrew the sensor module (12) from the electronics housing, simultaneously turning the header board and leads to prevent them from being twisted or damaged. The threaded connection has a sealing compound on it and must be broken loose. **Be careful not to damage the isolating diaphragms when unscrewing the sensor module.** Then carefully pull the header assembly board (4) through the hole.
5. The sensor module (12) is a welded assembly and cannot be further disassembled.

REASSEMBLY PROCEDURE

NOTE

Numbers in parentheses refer to item numbers in Figure 5-2 on page 5-7.

NOTE

The Rosemount 1153 Series D Pressure Transmitter contains electronic circuit boards which may be static sensitive.

Preliminary

1. Replace the cover O-rings (2) whenever you remove a cover. Clean the sealing areas with alcohol, if necessary, and lightly grease the O-ring with Dow Corning 55 Silicone O-ring Grease (Rosemount P/N 01153-0248-0001 or P/N 01153-0053-0001). Spray the inside threads of the electronics covers with cover lubricant (Rosemount P/N 01153-0333-0001 or equivalent) if necessary; if covers are already sufficiently lubricated, do not spray.
2. Verify that the circuit boards are clean.
3. Verify that the bayonet pins on the connection board are clean.
4. If you remove the sensor module, clean the thread sealant from the sensor module threads, lock nut, and electronics housing threads with a wire brush.

Connecting Electrical Housing to Sensor Module

1. Run the lock nut down to the base of the sensor module threads.
2. Apply a heavy, continuous bead (about $\frac{3}{8}$ -in. wide) of Loctite® 580 PST sealant (RMT P/N 01153-0329-0001) around the top sensor module threads.
3. Insert the header assembly board (4) through the hole in the bottom of the electronics housing.
4. Screw the sensor module (12) into the electrical housing (3) making sure that five full threads are engaged. Be careful not to damage or twist the sensor module leads. Turn the header board to avoid twisting the wires.
5. Align the sensor module with the high and low pressure sides oriented per Figure 2-5 on page 2-7, as applicable. Alternately, tighten the module one-half turn further to reverse the orientation of the module about the electronics housing.
6. Tighten the lock nut (9) to 35 ft-lb (48 N-m) torque.
7. Wipe off excess sealant.
8. Place the assembled unit in an oven at 200 ± 5 °F (93 ± 3 °C) for 12 hours to cure the sealant.

Electrical Housing Reassembly

1. If zero and span adjustment screws (16) have been removed replace O-rings with new O-rings (19). Lightly grease the O-rings with Dow Corning 55 Silicone O-ring Grease (Rosemount P/N 01153-0248-0001 or P/N 01153-0053-0001). Reinstall the adjustment screws and secure with snap rings (18).
2. Align the zero and span adjustment screws with the potentiometer stems on the calibration board (5) and push the calibration board onto the bayonet pins.
3. Slide the header assembly board (4) onto the bayonet pins with the component side toward the pins. Slide any excess wire behind the calibration board, **taking care to avoid kinks**.
4. Push the amplifier board (6) onto the bayonet pins and secure with holding screws (7). Use nominal torque of 10 in-lb (1.1 N-m).
5. Carefully replace the cover and tighten to 16.5 ft-lb (22.4 N-m) ("Preliminary" on page 5-5).
6. Replace the nameplate (17), and secure with two nameplate screws (20).

Rosemount 1153 Series D

Process Flange Reassembly

1. Replace the metal O-rings (11) with new O-rings if the flanges were removed.
2. Carefully place an O-ring (11) in the isolator well of the high side ("H") of the sensing module. Place the O-ring so the edge of the rolled ring faces the module. (See Detail A of Figure 5-2 on page 5-7).
3. Carefully place the flange (13 or 15) as shown in Figure 5-2 on page 5-7. Take care not to disturb the O-rings or damage the diaphragms.
4. On differential units, repeat steps 2 and 3 for the low side ("L") of the module. If a gage unit has two O-rings (one on each side), repeat steps 2 and 3 for the low side. If the gage unit has only one O-ring, reassemble with one O-ring on the high side.
5. Keeping the flanges parallel to each other and to the module faces, insert the four bolts (14) (and four washers on Range 9) and finger-tighten the nuts (8).
Each spare bolts and nuts parts kit contains the correct number of nuts, bolts and washers for the specific transmitter range code it is designated for. Due to consolidation of parts kits, the bolt length and quantity of washers required may differ for existing transmitter assemblies and/or parts kits. Verify by part number that the appropriate spare parts kit is used for the transmitter range code being re-assembled. Contact Rosemount Nuclear Instruments, Inc. if there are questions.
6. Evenly seat the flanges on the sensor module housing, using a hand torque wrench as specified in steps 7 through 11. See Figure 5-2 on page 5-7 to identify the bolts.
7. Alternately tighten bolts A and B to 10 ft-lb (14 N-m) torque.
8. Alternately tighten bolts C and D to 10 ft-lb (14 N-m) torque.
9. Check the torque on bolts A and B.
10. Check the torque on bolts C and D.
11. Repeat steps 7–10 at 15 ft-lb (20 N-m) torque, at 20 ft-lb (27 N-m) torque, at 25 ft-lb (34 N-m) torque, at 30 ft-lb (41 N-m) torque, and at 35 ft-lb (48 N-m) torque until all bolts are torqued to 35 ±1 ft-lb (48 ±1.4 N-m).
12. Expose all ranges of absolute and gage transmitters to two temperature cycles over the expected temperature operating range before calibrating. Expose differential and high-line differential range 3's and 4's to two temperature cycles over the expected temperature operating range before calibrating.

POST-ASSEMBLY TESTS

1. Conduct hydrostatic testing to 150% of maximum working pressure or 2,000 psi, whichever is greater.
2. Calibrate the transmitter per the calibration section of this manual.
3. Conduct nuclear cleaning to one ppm chloride content of transmitter "wetted parts."

Figure 5-2. Typical Rosemount 1153 Series D Exploded View.




Table 5-1. Rosemount 1153 Series D Parts List.

Part	Description	Part	Description
1	Electronics Cover	11	Metal O-Ring for Process Flange
2	O-Ring for Electronics Cover	12	Sensor Module
3	Electronics Housing	13	Process Flange
4	Header Assembly Board	14	Process Flange Bolts
5	Calibration Board	15	Process Flange
6	Amplifier Board	16	Zero and Span Adjustment Screws
7	Holding Screws	17	Nameplate
8	Process Flange Nuts	18	Snap Rings
9	Sensor Module Lock Nut	19	O-Ring for Adjustment Screw
10	Valve Stem	20	Nameplate Screws

Table 5-2. Torque References.

Item To Be Torqued	Torque Value	Tolerance
Bracket to Mounting Panel Bolts	19 ft-lb (26 N-m)	±1 ft-lb (1 N-m)
Transmitter to Bracket Bolts	21 ft-lb (29 N-m)	±1 ft-lb (1 N-m)
Swagelok Process Fittings	See installation instructions	—
Drain/Vent Valves	7.5 ft-lb (10 N-m)	±0.5 ft-lb (0.7 N-m)
Covers	16.5 ft-lb (22.4 N-m)	±1 ft-lb (1 N-m)
Module Neck Lock Nut	35 ft-lb (48 N-m)	±1 ft-lb (1 N-m)
Conduit Fitting	4 to 7 turns or a minimum of 12.5 ft-lb (16.9 N-m)	±1 ft-lb (1 N-m)
Flange Bolts	See Process Flange Reassembly	—
Terminal Block Screws	5 in-lb (0.6 N-m) or hand tight	±1 in-lb (0.1 N-m)
Amplifier Board Screws	Nominal 10 in-lb (1.1 N-m)	—

Table 5-3. Troubleshooting.

Symptom	Potential Source	Corrective Action
High Output	Primary Element	Check for restrictions at primary element, improper installation or poor condition. Note any changes in process fluid properties.
	Impulse Piping	Check for leaks or blockage. Ensure that blocking valves are fully open. Check for entrapped gas in liquid lines and for liquid in dry lines. Ensure that density of fluid in impulse lines is unchanged. Check for sediment in the transmitter process flanges.
	Transmitter Electronics	Make sure that post connectors and the sensor connections are clean. If the electronics are still suspect, substitute new electronics.
	Transmitter Electronics Failure	Determine faulty circuit board by trying spare boards. Replace faulty circuit board.
	Sensing Module	See sensing module checkout section. The sensing module is not field repairable and must be replaced if found to be defective. See "Disassembly procedure" for instructions on disassembly. Check for obvious defects, such as punctured isolating diaphragm or fill fluid loss, and contact Rosemount Nuclear Instruments, Inc.
	Power Supply	Check the power supply output voltage at the transmitter.
Low Output or No Output	Primary Element	Check for restrictions at primary element, improper installation or poor condition. Note any changes in process fluid properties.
	Loop Wiring	⚠ CAUTION Do not use over 100 volts to check the loop, or damage to the transmitter electronics may result. Check for adequate voltage to the transmitter. Check the milliamp rating of the power supply against the total current being drawn for all transmitters being powered. Check for shorts and multiple grounds. Check for proper polarity at the signal terminal. Check loop impedance. Check wire insulation to detect possible shorts to ground.
	Impulse Piping	Ensure that the pressure connection is correct. Check for leaks or blockage. Check for entrapped gas in liquid lines. Check for sediment in the transmitter process flange. Ensure that blocking valves are fully open and that bypass valves are tightly closed. Ensure that density of the fluid or other fluid properties in the impulse piping are unchanged.
	Transmitter Electronics Connections	Ensure that calibration adjustments are in allowable range. Check for shorts in sensor leads. Make sure post connectors are clean, and check the sensor connections. If the electronics are still suspect, substitute new electronics.
	Test Diode Failure	Replace electronics housing.
	Transmitter Electronics Failure	Determine faulty circuit board by trying spare boards. Replace faulty circuit board.
	Sensing Module	See Sensing Module Checkout section. The sensing module is not field repairable and must be replaced if found to be defective. See "Disassembly Procedure" for instructions on disassembly. Check for obvious defects, such as punctured isolating diaphragm or fill fluid loss, and contact Rosemount Nuclear Instruments, Inc.
	Power Supply	Check the power supply output voltage at transmitter.
Continued on Next Page		

Symptom	Potential Source	Corrective Action
Erratic Output	Loop Wiring	⚠ CAUTION Do not use over 100 volts to check the loop, or damage to the transmitter electronics may result. Check for adequate voltage to the transmitter. Check for intermittent shorts, open circuits and multiple grounds.
	Impulse Piping and Process Connections	Check for entrapped gas in liquid lines and for liquid in dry lines.
	Transmitter Electronics	Check for intermittent shorts or open circuits. Make sure that post connectors and the sensor connectors are clean and properly connected.
	Transmitter Electronics Failure	Determine faulty board by trying spare boards. Replace faulty circuit board.
	Power Supply	Check power supply output voltage.

Section 6

Specifications and Reference Data

Nuclear Specifications	page 6-1
Performance Specifications	page 6-3
Functional Specifications	page 6-6
Physical Specifications	page 6-8
Important Notice	page 6-13

NUCLEAR SPECIFICATIONS

Qualified per IEEE Std 323-1974 and IEEE Std 344-1975 as stated in Rosemount Report D8300040.

Output Code P

Radiation:

Accuracy within $\pm 6\%$ of upper range limit during and after exposure to 5.19×10^7 rads, total integrated dosage
Range Code 0: $\pm 8.2\%$ of upper range limit

Seismic:

Accuracy within $\pm 0.5\%$ of upper range limit during and after a disturbance defined by a required response spectrum with a ZPA of 7 g
Range Code 0: $\pm 0.75\%$ of upper range limit

Steam Pressure/Temperature:

Accuracy within $\pm(4.5\%$ upper range limit $+3.5\%$ span) during and after exposure to steam at the following temperatures and pressures:

420 °F (215.6 °C), 95 psig for 3 minutes
350 °F (176.6 °C), 85 psig for 7 minutes
320 °F (160 °C), 60 psig for 3 hours
240 °F (115.5 °C), 27 psig for 21 hours
176 °F (80 °C), 3 psig for 30 days simulating
one year post-DBE operation

Range Code 0: $\pm(6.7\%$ of upper range limit $+ 3.5\%$ of span)

Post DBE Operation:

Accuracy at reference conditions shall be within $\pm 1.5\%$ of upper range limit (2.25% for Range Code 0) for one year following DBE

Output Code R

Radiation:

Accuracy within $\pm(1.5\%$ of upper range limit $+ 1.0\%$ span) during and after exposure to 5.5×10^7 rads, total integrated dosage
Range Code 0: $\pm(2.3\%$ of upper range limit $+ 1.0\%$ of span)

Seismic:

Accuracy within $\pm 0.5\%$ of upper range limit during and after disturbance defined by a required response spectrum with a ZPA of 7 g
Range Code 0: $\pm 0.75\%$ of upper range limit

Steam Pressure/Temperature:

Accuracy within $\pm(4.5\%$ upper range limit + 3.5% span) during and after exposure to steam at the following temperatures and pressures:

420 °F (215.6 °C), 95 psig for 3 minutes
350 °F (176.6 °C), 120 psig for 7 minutes
320 °F (160 °C), 70 psig for 8 hours
265 °F (129.4 °C), 24 psig for 67 hours

Range Code 0: $\pm(6.7\%$ of upper range limit + 3.5% of span)

Additional Radiation:

After completion of the above tests, the transmitters were exposed to an additional 5.5×10^7 rads TID.

Performance: $\pm(1.5\%$ of upper range limit + 1.0% span)

Range Code 0: $\pm(2.3\%$ of upper range limit + 1.0% of span)

Post DBE Operation:

Accuracy at reference conditions shall be within $\pm 3\%$ of upper range limit (4.5% for Range Code 0) for one year following DBE.

Both Output Codes**Chemical Spray:**

Composition is 0.28 molar boric acid, 0.064 molar sodium thiosulfate, and sodium hydroxide as required to make an initial pH of 11.0 and a subsequent pH ranging from 8.5 to 11.0. Chemical spray is sprayed at a rate of 0.25 gal/min/ft².

Quality Assurance Program:

In accordance with NQA-1, 10CFR50 Appendix B, and ISO 9001:2000

Nuclear Cleaning:

To 1 ppm maximum chloride content

Hydrostatic Testing:

To 150% of maximum working pressure or 2,000 psi (13.8 MPa), whichever is greater


Traceability:

In accordance with NQA-1 and 10CFR50 Appendix B; chemical and physical material certification of pressure-retaining parts

Qualified Life:

Dependent on continuous ambient temperature at the installation site (see Figure 6-1 on page 6-3). Replacement of the amplifier and calibration circuit boards at the end of their qualified life permits extension of the transmitter qualified life to the module qualified life. Details of the test are in the Rosemount Report D8300040.

Figure 6-1. Qualified Life vs. Ambient Temperature.



PERFORMANCE SPECIFICATIONS

Based on zero-based ranges under reference conditions.

Accuracy

±0.25% of calibrated span; includes combined effects of linearity, hysteresis, and repeatability

Dead Band

None

Drift

±0.2% of upper range limit for 30 months (±0.3% of upper range limit for Range Code 0)

Temperature Effect

Per 100 °F (55.6 °C) ambient temperature change:

Range Code	Temperature Effect
3	±(1.5% of upper range limit + 1.0% span)
4–9	±(0.75% of upper range limit + 0.5% span)
0	±(1.13% of upper range limit + 0.5% span)

Overpressure Effect

Rosemount 1153DD:

Maximum zero shift after 2,000 psi (13.8 MPa) overpressure:

Range Code	Overpressure Effect
3, 4	±0.25% of upper range limit
5	±1.0% of upper range limit
6, 7	±3.0% of upper range limit
8	±6.0% of upper range limit

Rosemount 1153HD:

Maximum zero shift after 3,000 psi (20.68 MPa) overpressure:

Range Code	Overpressure Effect
4	±1.0% of upper range limit
5	±2.0% of upper range limit
6, 7	±5.0% of upper range limit

Rosemount 1153GD and 1153AD:

Maximum zero shift after 2,000 psi (13.8 MPa) overpressure:

Range Code	Overpressure Effect
3, 4	±0.25% of upper range limit
5–8	±1.0% of upper range limit

Maximum zero shift after 4,500 psi (31.0 MPa) overpressure:

Range Code	Overpressure Effect
9	±0.5% of upper range limit

Maximum zero shift after 6,000 psi (41.34 MPa) overpressure:

Range Code	Overpressure Effect
0	±0.25% of upper range limit

Static Pressure Zero Effect

Rosemount 1153DD:

Per 1,000 psi (6.89 MPa):

Range Code	Zero Effect
4, 5	±0.2% of upper range limit
3, 6–8	±0.5% of upper range limit

Rosemount 1153HD:

Per 1,000 psi (6.89 MPa):

Range Code	Zero Effect
4–7	±0.66% of upper range limit

Static Pressure Span Effect

The effect is systematic and can be calibrated out for a particular pressure before installation. Correction uncertainty equals ±0.5% of input reading/1,000 psi (6.89 MPa).

Power Supply Effect

Less than 0.005% of output span per volt

Load Effect

No load effect other than the change in the voltage supply to the transmitter

Mounting Position Effect

No span effect; zero shift of up to 1.5 inH₂O (372 Pa) which can be calibrated out

Response Time

Fixed time constant (63%) at 100 °F (37.8 °C) as follows:

Range Code	Response Time
3	2 seconds or less
4	0.5 seconds or less
5-9, 0	0.2 seconds or less

Adjustable damping is available through a special N-Option.

FUNCTIONAL SPECIFICATIONS

Service

Liquid, gas, or vapor


Output

4–20 mA dc

Power Supply

Load limits are as shown in Figure 6-2

Figure 6-2. Load Limits.



Span and Zero

Continually adjustable externally

Zero Elevation and Suppression

Maximum zero elevation: 600% of calibrated span
(400% of calibrated span for Range Code 0)

Maximum zero suppression: 500% of calibrated span (300% of calibrated span for Range Code 0)

Zero elevation and suppression must be such that neither the calibrated span nor the upper or lower range value exceeds 100% of the upper range limit.

Temperature Limits

Normal operating limits: 40 to 200 °F (4.4 to 93.3 °C)

Qualified storage limits: -40 to 120 °F (-40 to 48.9 °C)

Humidity Limits

0–100% relative humidity (NEMA 4X)

Volumetric Displacement

Less than 0.01 in³ (0.16 cm³)

Turn-On Time

2 seconds maximum. No warm-up required.

Pressure Ranges

Rosemount 1153DD and 1153HD:

Range Code	Pressure Ranges
3	0–5 to 0–30 inH ₂ O (D units only) (0–1.24 to 0–7.46 kPa)
4	0–25 to 0–150 inH ₂ O (0–6.22 to 0–37.3 kPa)
5	0–125 to 0–750 inH ₂ O (0–31.08 to 0–186.4 kPa)
6	0–17 to 0–100 psi (0–0.12 to 0–0.69 MPa)
7	0–50 to 0–300 psi (0–0.34 to 0–2.07 MPa)
8	0–170 to 0–1,000 psi (D units only) (0–1.17 to 0–6.89 MPa)

Rosemount 1153GD and 1153AD:

Range Code	Pressure Ranges
3	0–5 to 0–30 inH ₂ O (G units only) (0–1.24 to 0–7.46 kPa)
4	0–25 to 0–150 inH ₂ O (G units only) (0–6.22 to 0–37.3 kPa)
5	0–125 to 0–750 inH ₂ O (0–31.08 to 0–186.4 kPa)
6	0–17 to 0–100 psi (0–0.12 to 0–0.69 MPa)
7	0–50 to 0–300 psi (0–0.34 to 0–2.07 MPa)
8	0–170 to 0–1,000 psi (0–1.17 to 0–6.89 MPa)
9	0–500 to 0–3,000 psi (G units only) (0–3.45 to 0–20.68 MPa)
0	0–1,000 to 0–4,000 psi (G units only) (0–6.89 to 0–27.56 MPa)

Maximum Working Pressure

Rosemount 1153DD and 1153HD:

Static pressure limit

Rosemount 1153GD and 1153AD:

Upper range limit

Static Pressure and Overpressure Limits

Rosemount 1153DD:

0.5 psia to 2,000 psig (3.4 kPa abs to 13.8 MPa) maximum rated static pressure for operation within specifications; overpressure limit is 2,000 psig (13.8 MPa) on either side without damage to the transmitter

Rosemount 1153HD:

0.5 psia to 3,000 psig (3.4 kPa abs to 20.7 MPa) maximum rated static pressure for operation within specifications; overpressure limit is 3,000 psig (20.7 MPa) on either side without damage to the transmitter

Overpressure Limits

Rosemount 1153GD and Rosemount 1153AD:

Operates within specifications from 0.5 psia (3.4 kPa abs) to upper range limit. Overpressure limits without damage to the transmitter are:

Range Code	Overpressure Limit
3–8	2,000 psig (13.8 MPa)
9	4,500 psig (31.0 MPa)
0	6,000 psig (41.34 MPa)

PHYSICAL SPECIFICATIONS

Materials of Construction

Isolating Diaphragms:

316L SST

Drain/Vent Valves:

316 SST

Process Flanges:

CF-8M (cast version of 316 SST)

Process O-rings:

316L SST

Electronics Housing O-rings:

Ethylene propylene

Fill Fluid:

Silicone oil

Flange Bolts and Nuts:

Plated alloy steel, per ASTM A-540

Electronics Housing:

316 SST

Mounting Bracket:

316L SST

Mounting Bolts (Bracket to Transmitter):

SAE J429 Carbon steel, Grade 2 or Grade 5

Process Connections

$\frac{3}{8}$ -in. Swagelok compression fitting,
316 SST ($\frac{1}{4}$ -18 NPT optional)

Electrical Connections

$\frac{1}{2}$ -14 NPT conduit with screw terminals

Weight

24 lb (10.9 kg) including mounting bracket

Rosemount 1153 Series D

Table 6-1. Transmitter Design Specifications.

Model	Product Description			
1153	Alphaline Pressure Transmitters for Nuclear Applications			
Code	Pressure Measurement			
D	Differential Pressure; 2,000 psig (13.8 MPa) Static Pressure Rating			
H	Differential Pressure; 3,000 psig (20.68 MPa) Static Pressure Rating			
A	Absolute Pressure			
G	Gage Pressure			
Code	Series			
D	SST Housing; qualified per IEEE Std 323-1974 and IEEE Std 344-1975			
Pressure Ranges at 68 °F				
Code	Rosemount 1153D (Differential)	Rosemount 1153H (Differential)	Rosemount 1153A (Absolute)	Rosemount 1153G (Gage)
3	0–5 to 0–30 inH ₂ O (0–1.24 to 0–7.46 kPa)	N/A	N/A	0–5 to 0–30 inH ₂ O (0–1.24 to 0–7.46 kPa)
4	0–25 to 0–150 inH ₂ O (0–6.22 to 0–37.3 kPa)	0–25 to 0–150 inH ₂ O (0–6.22 to 0–37.3 kPa)	N/A	0–25 to 0–150 inH ₂ O (0–6.22 to 0–37.3 kPa)
5	0–125 to 0–750 inH ₂ O (0–31.08 to 0–186.4 kPa)	0–125 to 0–750 inH ₂ O (0–31.08 to 0–186.4 kPa)	0–125 to 0–750 inH ₂ O (0–31.08 to 0–186.4 kPa)	0–125 to 0–750 inH ₂ O (0–31.08 to 0–186.4 kPa)
6	0–17 to 0–100 psi (0–0.12 to 0–0.69 MPa)	0–17 to 0–100 psi (0–0.12 to 0–0.69 MPa)	0–17 to 0–100 psia (0–0.12 to 0–0.69 MPa)	0–17 to 0–100 psi (0–0.12 to 0–0.69 MPa)
7	0–50 to 0–300 psi (0–0.34 to 0–2.07 MPa)	0–50 to 0–300 psi (0–0.34 to 0–2.07 MPa)	0–50 to 0–300 psia (0–0.34 to 0–2.07 MPa)	0–50 to 0–300 psi (0–0.34 to 0–2.07 MPa)
8	0–170 to 0–1,000 psi (0–1.17 to 0–6.89 MPa)	N/A	0–170 to 0–1,000 psia (0–1.17 to 0–6.89 MPa)	0–170 to 0–1,000 psi (0–1.17 to 0–6.89 MPa)
9	N/A	N/A	N/A	0–500 to 0–3,000 psi (0–3.45 to 0–20.68 MPa)
0	N/A	N/A	N/A	0–1,000 to 0–4,000 psi (0–6.89 to 0–27.56 MPa)
Code	Output			
P	Standard 4–20 mA			
R ⁽¹⁾	Improved Radiation Performance, 4–20 mA			
Code	Flange Option			
A	Welded 3⁄8-in. Swagelok Compression Fitting Process Connection and Welded Drain/Vent Valve			
B ⁽²⁾	1⁄4–18 NPT Process Connection and Welded Drain/Vent Valve			
C ⁽²⁾	1⁄4–18 NPT Process Connection and Drain Hole (Drain/Vent Valve Not Included)			
D	One Flange Option Code A and one Remote Seal			
E ⁽²⁾	One Flange Option Code B and one Remote Seal			
F ⁽²⁾	One Flange Option Code C and one Remote Seal			
G	Two Remote Seals			
H	Welded 3⁄8-in. Swagelok Compression Fitting on Process Connection and Drain/Vent Connection			
J ⁽²⁾	Welded 3⁄8-in. Swagelok Compression Fitting Process Connection and 1⁄4–18 NPT Drain Hole			
L	One Flange Option Code H and one Remote Seal			
M ⁽²⁾	One Flange Option Code J and one Remote Seal			
Typical Model Number:1153 D D 4 R A				

- (1) The Rosemount 1153 Series D with the Output Code R Electronics is also available with adjustable damping. Specify this option by adding "N0037" to the end of the complete model number. For example: 1153DD4RAN0037.
- (2) Customer assumes responsibility for qualifying interfaces on this option. Contact Rosemount Nuclear Instruments, Inc. for details.

Table 6-2. Rosemount 1153 Series D Spare Parts List.

Spare Parts Category ⁽¹⁾					Rosemount 1153DD Order No.	Rosemount 1153HD Order No.	Rosemount 1153GD Order No.	Rosemount 1153AD Order No.
Traceable Part								
Quantity Required								
Item Number (see Figure 5-2 on page 5-7)								
Part Description								
Amplifier Cir. Board, Output Code P	6	1		A	01153-0123-0004	01153-0123-0004	01153-0123-0004	01153-0123-0004
Calib. Cir. Board, Output Code P	5	1		A	01153-0125-0001	01153-0125-0001	01153-0125-0001	01153-0125-0001
Amplifier Cir. Board, Output Code R	6	1		A	01154-0001-0005	01154-0001-0005	01154-0001-0005	01154-0001-0005
Calib. Cir. Board, Output Code R	5	1		A	01154-0002-0001	01154-0002-0001	01154-0002-0001	01154-0002-0001
Amplifier Cir. Board with Damping, Output Code R	6	1		A	01154-0021-0004	01154-0021-0004	01154-0021-0004	01154-0021-0004
Calib. Cir. Board with Damping, Output Code R	5	1		A	01154-0023-0002	01154-0023-0002	01154-0023-0002	01154-0023-0002
Sensor Module, 316 SST 0–5/30 inH ₂ O 0–25/150 inH ₂ O 0–125/750 inH ₂ O 0–17/100 psi 0–50/300 psi 0–170/1,000 psi 0–500/3,000 psi 0–1,000/4,000 psi	12	1	X X X X X X X X	B B B B B B B B	01153-0320-0232 01153-0320-0242 01153-0320-0252 01153-0320-0262 01153-0320-0272 01153-0320-0282 — —	— 01153-0320-0342 01153-0320-0352 01153-0320-0362 01153-0320-0372 — — —	01153-0320-0132 01153-0320-0142 01153-0320-0152 01153-0320-0162 01153-0320-0172 01153-0320-0182 01153-0320-0192 01153-0320-0102	— — 01153-0320-0052 01153-0320-0062 01153-0320-0072 01153-0320-0082 — —
Electronics Housing, Austenitic SST	3	1			01153-0211-0001	01153-0211-0001	01153-0211-0001	01153-0211-0001
Electronics Cover, Austenitic SST	1	2			01153-0204-0001	01153-0204-0001	01153-0204-0001	01153-0204-0001
Cover Wrench					01153-0382-0001	01153-0382-0001	01153-0382-0001	01153-0382-0001
Hollow Terminal Block Screw Kit					01153-0041-0001	01153-0041-0001	01153-0041-0001	01153-0041-0001
Solid Terminal Block Screw Kit (Kit Contains 20 each)					01153-0330-0001	01153-0330-0001	01153-0330-0001	01153-0330-0001
Process Flange, Welded <i>Swagelok</i>	13/15		X		01153-0175-0001	01153-0175-0001	01153-0175-0001	01153-0175-0001
Process Flange, ¼–18 NPT		(2)	X		01153-0175-0002	01153-0175-0002	01153-0175-0002	01153-0175-0002
Process Flange, ¼–18 NPT/¼–18 NPT			X		01153-0291-0001	01153-0291-0001	01153-0291-0001	01153-0291-0001
Blank Flange					—	—	—	01153-0272-0001
Vented Blank Flange					—	—	01153-0234-0001	—
Valve Stem, 316 SST	10	2	X	A	01153-0277-0001	01153-0277-0001	01153-0277-0001	01153-0277-0001
Valve Stem and Seat Kit, 316 SST					01153-0038-0001	01153-0038-0001	01153-0038-0001	01153-0038-0001
Axial Drain/Vent Valve Kit					01153-0350-0002	01153-0350-0002	01153-0350-0002	01153-0350-0002
Quick Disconnect Axial Drain/Vent Valve Kit					01153-0373-0001	01153-0373-0001	01153-0373-0001	01153-0373-0001
Adjustment Screw Kit		1			01153-0294-0001	01153-0294-0001	01153-0294-0001	01153-0294-0001
Adjustment Screw (2)	16							
Retaining Ring (2)	18							
O-ring for Adjustment Screw (2)	19							
O-ring for Electronics Cover (Kit contains 20 each)	2	2		C	01153-0039-0001	01153-0039-0001	01153-0039-0001	01153-0039-0001
O-ring for Electronics Cover (Kit contains 1 each)	2	2		C	01153-0039-0003	01153-0039-0003	01153-0039-0003	01153-0039-0003
O-ring for Process Flange, SST (Kit contains 6 each)	11	2	X	B	01153-0249-0001	01153-0249-0001	01153-0249-0001	01153-0249-0001
D.C. 55 O-ring Lubricant (0.25 oz)					01153-0053-0001	01153-0053-0001	01153-0053-0001	01153-0053-0001
D.C. 55 O-ring Lubricant (5.3 oz)					01153-0248-0001	01153-0248-0001	01153-0248-0001	01153-0248-0001
Loctite 580 PST Thread Sealant (50 ml)					01153-0329-0001	01153-0329-0001	01153-0329-0001	01153-0329-0001
Lubri-Bond A Cover Lubricant (12 oz)					01153-0333-0001	01153-0333-0001	01153-0333-0001	01153-0333-0001

Continued on Next Page

Rosemount 1153 Series D

Spare Parts Category ⁽¹⁾					Rosemount 1153DD Order No.	Rosemount 1153HD Order No.	Rosemount 1153GD Order No.	Rosemount 1153AD Order No.
Traceable Part								
Quantity Required								
Item Number (see Figure 5-2 on page 5-7)								
Part Description								
Electronics Assembly Hardware Electronics Screw (3) Nameplate Screw (2) Locknut	7 20 9	1		A	01153-0040-0001	01153-0040-0001	01153-0040-0001	01153-0040-0001
Jumper Wire Kit (36 in.)					01153-0055-0001	01153-0055-0001	01153-0055-0001	01153-0055-0001
Bolts and Nuts for Process Flange ⁽³⁾ Range Codes 3–8 (Pkg of 4) Range Code 9 (Pkg of 4) Range Code 0 (Pkg of 4)	14/8	1 1	X X		01153-0245-0001 — —	01153-0245-0001 — —	01153-0245-0001 01153-0246-0001 01153-0246-0002	01153-0245-0001 — —
Panel Mounting Bracket with Bolts Universal Mounting Bracket with Bolts Bolts and Washers for Bracket (Pkg of 4)		1			01153-0013-0001 01153-0013-0003 01153-0321-0001	01153-0013-0001 01153-0013-0003 01153-0321-0001	01153-0013-0001 01153-0013-0003 01153-0321-0001	01153-0013-0001 01153-0013-0003 01153-0321-0001
Pipe Mount Bracket Kit (Adapters) Pipe Mount Bracket Kit (Bracket and Adapters)					01154-0044-0001 01154-0038-0002	01154-0044-0001 01154-0038-0002	01154-0044-0001 01154-0038-0002	01154-0044-0001 01154-0038-0002
Conduit Elbow (M22) Conduit Elbow (½–14 NPT)					01154-0035-0001 01154-0040-0001	01154-0035-0001 01154-0040-0001	01154-0035-0001 01154-0040-0001	01154-0035-0001 01154-0040-0001
Amplifier Circuit Board, Output Code R, N0026 ⁽⁴⁾					01154-0001-0006	01154-0001-0006	—	—

- (1) Rosemount recommends one spare part or kit for every 25 transmitters in Category "A," one spare part or kit for every 50 transmitters in Category "B," and one spare part or kit for every 5 transmitters in Category "C."
- (2) Two flanges are required per transmitter. Flange parts depend on desired connection and transmitter type.
- (3) Each spare bolts and nuts parts kit for process flange contains the correct number of nuts, bolts and washers for the specific transmitter range code it is designated for. Due to consolidation of parts kits, the bolt length and quantity of washers required may differ for existing transmitter assemblies and/or parts kits. Verify by part number that the appropriate spare parts kit is used for the transmitter range code being re-assembled. Contact Rosemount Nuclear Instruments, Inc. if there are questions.
- (4) For use with existing N0026 transmitter only.

NOTE: 1153 Spare Parts not hydrostatic tested or nuclear cleaned.

Spare Parts Shelf Life

Store all spare transmitters and spare component parts in accordance with ANSI N45.2.2 level B.

Qualified transmitters, spare circuit boards, spare O-rings: The qualified life (as defined in Qualification Test Report D8300040) plus the shelf life is equal to the typical design life of the plant (40 years) when the ambient storage temperature is below 90 °F.

Lubricants and sealant: The date of the end of shelf life (use by date) is provided with the lubricants and/or sealant, at the time of shipment. The product has a minimum of six months shelf life at the time of shipment.

All other parts: Shelf life is not applicable.

IMPORTANT NOTICE

There are factors to consider concerning maintenance of qualification and traceability during on-site instrument repair because of the nuclear use intended for these parts. Rosemount Nuclear Instruments, Inc. rigidly controlled the original assembly of the instrument to ensure that the specifications were met. Since we are not installing the replacement parts in the instruments, Rosemount Nuclear Instruments, Inc. is unable to ensure that the specifications are being satisfied. This responsibility is shifted to the user. The integrity of the instrument as originally assembled is broken.

Replacing parts has ramifications under 10CFR21, for which the user is responsible. These same regulations additionally mandate a component traceability program, which the user must undertake for the replacement parts. In view of this, and in order to maintain the qualification of the product, the user must ensure that all replacement parts are installed in accordance with the Rosemount Nuclear Instruments, Inc. approved installation and recalibration procedures herein.

Notes

1. "R" electronics boards (set of 2) are interchangeable with "P" electronics boards (set of 2).
2. Rosemount 1153 spare parts are not hydrostatic tested or nuclear cleaned.
3. Part numbers shown may differ from those currently supplied. The part numbers shown are current at the time of printing of this manual, but may be revised in the future. Parts provided are compatible and interchangeable with those listed on your order as to the form, fit, and function of the part required. Please adjust your needs accordingly.

Index

A

About The Transmitter 1-1

B

Board Checkout 5-2
Both Output Codes 6-2

C

Calibration 3-1
Calibration Procedures 3-3
Conduit Connection 2-4
Connecting Electrical Housing to
Sensor Module 5-5
Correction For High Line Pressure
(Rosemount 1153DD and 1153HD
Only) 3-9
Current Control 4-4
Current Limit 4-4

D

Damping Adjustment 3-8
Demodulator 4-3
Dimensional Drawings 2-7
Disassembly Procedure 5-3

E

Electrical 2-9
Electrical Block Diagram 4-2
Electrical Considerations 2-4
Electrical Housing Disassembly 5-4
Electrical Housing Reassembly 5-5

F

Functional Specifications 6-6

G

General Considerations 2-1

H

Humidity Limits 6-7

I

Important Notice 6-13
Installation Procedure 2-6
Introduction 1-1

J

Jumper Wire Placement 3-7

L

Linearity Adjustment 3-5, 4-3
Load Effect 6-5
Load Limits 6-6

M

Materials of Construction 6-8
Maximum Working Pressure 6-7
Mechanical Considerations 2-2
Mounting Position Effect 6-5

N

Nuclear Specifications 6-1

O

Oscillator 4-4
Output Code P 6-1
Output Code R 6-1
Overview 4-1

P

Performance Specifications 6-3
Physical Specifications 6-8
Post-assembly Tests 5-6
Power Supply Effect 6-4
Preliminary 5-5
Pressure Ranges 6-7
Process Connections 2-2
Process Flange Reassembly 5-6
Process Flange Removal 5-3

Q

Qualified Life vs. Ambient Temperature
. 2-1, 6-3

R

Reassembly Procedure 5-4
Removing Sensor Module from
Electrical Housing 5-4
Response Time 6-5
Reverse Polarity Protection 4-4
Rosemount 1153 Series D Parts List
5-7
Rosemount 1153 Series D Spare Parts
List 6-11

S

Safety Messages 5-1
Sensing Module Checkout 5-2
Span 3-9
Span Adjustment 3-1
Span and Zero 6-6
Spare Parts Shelf Life 6-12
Static Pressure and Overpressure
Limits 6-8
Static Pressure Span Effect 6-4

T

Temperature Limits 6-6
Test Terminals 5-2
The d-Cell 4-3
The d-Cell Sensor 4-3
Torque References 5-8
Transmitter Design Specifications .
6-10
Transmitter Installation Configurations
2-8
Transmitter Load Limits Graph 2-5
Transmitter Operation 4-1
Transmitter Terminal Block 2-9
Transmitter Wiring Connections
Diagram 2-5
Troubleshooting 5-9
Turn-On Time 6-7
Typical Rosemount 1153 Series D
Exploded View 5-7
Typical Transmitter Mounting Bracket
Configuration 2-6

V

Voltage Regulator 4-4
Volumetric Displacement 6-7

Z

Zero 3-11
Zero Adjustment 3-1
Zero Adjustment Range 3-2
Zero And Span Adjustments 4-4
Zero Elevation and Suppression 6-6

The Emerson logo is a trade mark and service mark of Emerson Electric Co.

Rosemount, the Rosemount logotype, and Alphaline are registered trademarks of Rosemount Inc.

δ-cell is a trademark of Rosemount, Inc.

All other marks are the property of their respective owners.

Emerson Process Management

Rosemount Nuclear Instruments, Inc.

8200 Market Boulevard
Chanhassen, MN 55317 USA
T (U.S.) (952) 949-5210
F (952) 949-5201

www.rosemountnuclear.com



Rosemount Nuclear Instruments, Inc. satisfies all obligations coming from legislation to harmonize product requirements in the European Union.

