TOSHIBA

T1000 Series UPS Tower Cap Installation Instructions - 94037-001

1. T1000 Tower Cap Installation

The Tower configuration modules are arranged side by side, and secured by a press-fit cap over the assembly. If the optional Caster Kits are to be used, the casters should be installed before the Tower Cap is installed.

2. Contents - T1000 Tower Cap Installation Kit (93807)

1 ea.: 94037 - Installation Instructions
1 ea.: 93178 - Tower Cap for 3 module System

3. Tower Cap Installation

NOTE: If optional Caster Kits, P/N 90508, are to be used, install them before installing the Tower Cap.

1. Unpack the T1000 modules and place them in the final location with the faceplates at the top as shown in Figure 2.
2. Facing the front of the modules, ensure the modules are arranged from left to right in the following order:
   - Transformer Module (if available)
   - Power Module
   - Battery Module with output panel(if available)
   - Second Battery Module without output panel (if available)
3. Locate the front of the Tower Cap. The front of the Cap has three taps extending beyond the skirt line. See Figure 1.
4. Fit the Tower Cap over the T1000 Modules, beginning with the front and lower the bak end over the top back of the modules.
5. Press the T1000 Tower Cap down evenly and firmly until the cap is seated over all for corners. (Figure 2)
6. The T1000 tower is ready for installing the interconnecting cables. See the **T1000 Installation and Operation Manual - 91074**.



FIGURE 1: TOWER CAP FRONT - DETAIL



FIGURE 2: INSTALL CAP ON THREE MODULE TOWER SYSTEM

TOSHIBA

TOSHIBA INTERNATIONAL CORPORATION

SOCIAL INFRASTRUCTURE SYSTEMS GROUP
POWER ELECTRONICS DIVISION
13131 West Little York Road, Houston, Texas 77041-9990
Tel (855) 803-7087 Fax. (713) 896-5212
US (800) 231-1412 Canada (800) 872-2192 Mexico 01/800/527-1204
https://www.toshibaups.com