High Performance AC Drives 0.4-400kW

VXM



- 5 year warranty
- High performance open and closed loop operation
- Speed or torque control
- 15 preset speeds
- FieldBus options Profibus, DeviceNet etc
- RS485 port
- IMO loader PC software
- Display remote mounting
- Maintenance information/alarm









	VXM***	()	40	75	150	220	400	550	750	1100	1500	1850	2200G	l -	30	37	45	55	75	90	110	132	160	200	220	280	315		
Type	VXMKP			*1)	-	-	-	-	-	-	-	-	-	-	-	30	-	-	-	-	-	-	-	-	-	-	_	-	_
Applied	Nominal (HT) he	avy torque	е	kW	0.4	0.75	1.5	2.2	4.0	5.5	7.5	11	15	18.5	22	-	30	37	45	55	75	90	110	132	160	200	220	280	315
	Maximum (NT) r	normal/ligh	nt torque	kW	-	-	-	-	-	7.5	11	15	18.5	22	-	30	37	45	55	75	90	110	132	160	200	220	280	315	400
Output	Rated capacity *	*2)	ŀ	κVA	1.0	1.7	2.6	3.9	6.4	9.3	12	17	21	28	32	32	43	53	65	80	107	126	150	181	218	270	298	373	
ratings	Rated voltage *3	3)		٧	3 ph	ase	38	0, 40	0, 41	5V/50)Hz	3	80, 4	00, 4	40, 4	60V/6	0Hz		OM:	440V/	50Hz								
	Rated current *4	1)	HT	Α	1.5	2.5	3.7	5.5	9.0	13	18	24	30	39	45	-	60	75	91	112	150	176	210	253	304	377	415	520	
	Cont.		NT	Α	-	-	-	-	_	16.5	23	30	37	44	-	60	75	91	112	150	176	210	253	304	377	415	520		
	Over Load Sho Capability	ort time	HT NT	*1)					nt for nt for	1 min 0.5s	11	0% 1	min.	НТ				rated rated				1. 1	10%	1 mir	ı. NT				
	Output frequency	y		Hz	0.1	- 400)																						
Input	Phases, Voltage,	, Frequenc	y *	10)	3 ph	nase	380) to 4	80V	50/	60Hz					3 phase 380 to 440V/50Hz 380 to 480V/60Hz *5)													
ratings	Voltage/Frequenc	cy variatio	ns		Volt	age:	+101	to -15	i% (Va	oltage	unba	ılance	*6):	2% о	r less	,													
	Momentary volta	age dip ca	pability	*7)	When the input voltage is 310V or more, the inverter can be operated continuously. When the input voltage drops below 310V from rated voltage, the inverter can be operated for 15ms. The smooth recovery method is selectable. 0.82 1.5 2.9 4.2 7.1 10.0 13.5 19.8 26.8 33.2 39.3 54 54 67 81 100 134 160 196 232 282 352 385 491																								
	Rated current *8	3) (with D	OCR)		0.82	1.5	2.9	4.2	7.1	10.0	13.5	19.8	26.8	33.2	39.3	54	54	67	81	100	134	160	196	232	282	352	385	491	
	ļ ,	A (withou	ut DCR)		1.8	3.5	6.2	9.2	14.9	21.5	27.9	39.1	50.3	59.9	69.3	86	86	104	124	150	-	-	-	-	-	-	-		
	Required power supply capacity	(with DCR		kVA	0.6	1.1	2.1	3.0	5.0	7.0	9.4	14	19	24	28	38	38	47	57	70	93	111	136	161	196	244	267	341	
Control	Starting torque			*1)	>20	0% (with D) ynan	nic tor	que-v	ector	conti	rol sel	ected	i)	>180% (with Dynamic torque-vector control selected)													
Braking	문 Braking torqu	е			15	0%			100%			20	% *	9)							15 to	10%	*9)						
	Time Distriction		,	S		5			5										No I	imit									
	Duty cycle		Ç	%	5	3	5	3	2	3	2								No I	imit									
	Braking torque (Using opti	ons)							150)%								100	0%									
	DC injection bral	king			Sta	ırting	frequ	ency:	0.1 t	o 60.0	OHz	Bral	king ti	me: (0.0 to	30.08	s E	Brakin	g leve	I: 0 to	1009	% of r	ated (urrer	t				
Enclosur	(IEC 60529)									IP	40									ΙP	00(IF	20: (Option)					
Cooling r	nethod		Natura	cooling											Fan	cooli	ng												
Standard	S			-UL/o	-El			(Ratir	igs, s	pecifi	catior		low v	oltage spec	e adju	stabl		uency		V (up powe			ems)						
Mass			kg	2.2	2.5	3.8	3.8	3.8	6.5	6.5	10	10	10.5	10.5	31	31	36	41	42	50	73	73	104	104	145	145			

- HT: Suitable for high starting torques and sustained overloads
- NT: Suitable for normal or lighter loads and variable torque applications

NOTES:

- *1) Specifications for VT use are shown below.
- *2) Inverter output capacity (kVA) at 415V.
- *3) Output voltage is proportional to the power supply voltage and cannot exceed the power supply voltage.
- *4) Current derating may be required in case of low impedance loads such as high frequency motor.
- *5) When the input voltage is 380V/50Hz or 380 to 415V/60Hz, the top of the auxiliary transformer must be changed.
- *6) Refer to the EN 61800-3 (5.2.3).
- *7) Tested at standard load condition (85% load).
- *8) This value is calculated. (Refer to IMO).

- *9) With a nominal applied motor, this value is average torque when the motor decelerates and stops from 60Hz. (It may change according to motor loss.)
- *10) Input ratings given for HT use.

Conformity to Low Voltage Directive

The Jaguar VXM Series conforms to the Low Voltage Directive with EN50178. Conformity to EMC Directive

- Emission requirement
- EMC filters in compliance with EN61800-3 are provided for all models as an optional extra $\,$
- Immunity requirement
 The Jaguar VXM Series inverters meet EN61800-3 as standard.

High Performance AC Drives 0.4-400kW VXM



Common specification

	Item	Explanation									
utput	Maximum frequency	50 to 400Hz *1)									
equency	Base frequency	25 to 400Hz *1)									
	Starting frequency	0.2 to 60Hz, Holding time: 0.0 to 10.0s									
	Carrier frequency *2)	HD use, heavy duty 0.75 to 15kHz (55kW or smaller) *3) 0.75 to 10kHz (75kW or larger) 0.75 to 10kHz (75kW or larger) 0.75 to 10kHz (30 to 75kW) 0.75 to 6kHz (90kW or larger)									
	Accuracy (Stability)	• Analog setting : $\pm 0.2\%$ of maximum frequency (at 25 $\pm 10^{\circ}$ C) • Digital setting : $\pm 0.01\%$ of maximum frequency (at -10 to +50°C)									
	Setting resolution	 Analog setting Digital setting LINK setting 1/3000 of maximum frequency ex.) 0.02Hz at 60Hz, 0.04Hz at 120Hz, (0.15Hz at 400Hz : EN) 0.01Hz at maximum frequency of up to 99.99Hz (0.1Hz at Maximum frequency of 100Hz and above) 1/20000 of maximum frequency ex.) 0.003Hz at 60Hz, 0.06Hz at 120Hz, (0.02Hz at 400Hz : EN) 0.01Hz (Fixe) 									
ontrol	Control method	V/f control (Sinusoidal PWM control) • Dynamic torque-vector control (Sinusoidal PWM control) • Vector control with PG (*) (EN onl									
	Voltage/freq. (V/f) characteristic	Adjustable at base and maximum frequency, with AVR control: 320 to 480V									
	Torque boost	Selectable by load characteristics: Constant torque load (Auto/manual), variable torque (manual)									
	Operation method	KEYPAD operation :									
		Digital input signal operation : FWD or REV command, Coast-to-stop command, etc.									
		• LINK operation : RS485 (Standard)									
		Profibus-DP, Interbus-S, DeviceNet, Modbus Plus, CAN open (Option)									
	Frequency setting (Frequency command)	KEYPAD operation: or key									
	(Frequency command)	• External potentiometer (*) : 1 to 5k (1/2W)									
		Analog input (Reversible) (Inverse) (Inverse) (Reversible) (Inverse) (I									
		UP/DOWN control Output frequency increases when UP signal is ON, and decreases when DOWN signal is ON.									
		Multistep frequency : Up to 16 different frequencies can be selected by digital input signal.									
		Pulse train input (*) : 0 to 100kp/s Digital signal (parallel) (*) : 16-bit binary									
		• LINK operation : RS485 (Standard)									
		Profibus-DP, Interbus-S, DeviceNet, Modbus Plus, CAN open (Option)									
		Programmed PATTERN operation: Maximum 7 stages Way PWD or PEV digital input signal.									
	Jogging operation	or key, FWD or REV digital input signal									
	Running status signal	Transistor output (4 points) : RUN, FAR, FDT, OL, LU, TL, etc.									
		Relay output (2 points) : Same as transistor output • Alarm output (for any fault) Analog output (1 point) : Output frequency output current output torque etc.									
		Analog output (1 point) : Output frequency, output current, output torque, etc.									
		Pulse output (1 point) : Output frequency, output current, output torque, etc.									
	Acceleration/Deceleration time	0.01 to 3600s : Independently adjustable acceleration and deceleration • 4 different times are selectable. Mode select : Linear, S-curve (weak), S-curve (strong), Non-linear									
	Active drive	When the acceleration time reaches 60s, the motor output torque is automatically reduced to rated torque. After 60s the motor operation mode is changed to torque limiting operation. The acceleration time is automatically extended up to 3 times.									
	Frequency limiter	High and low limiter can be preset.									
	Bias frequency	Bias frequency can be preset.									
	Gain for frequency setting	Gain for frequency setting can be preset (0.0 to 200.0%) ex.) Analog input 0 to +5VDC with 200% gain results in maximum frequency at 5VDC.									
	Skip frequency control	Skip frequency (3 points) and its common skip hysteresis width (0 to 30Hz) can be preset.									
	Rotating motor pick up (Flying start)	A rotating motor (including inverse rotating mode) can be smoothly picked up without stopping the motor (speed search method).									
	Auto-restart after momentary power failure	Automatic restart is available without stopping motor after a momentary power failure (speed search method). When "Smooth recovery" mode is selected, the motor speed drop is held minimum. (The inverter searches the motor speed and smoothly returns to setting frequency.									
	Line/Inverter changeover operation	Controls the switching operation between line power and inverter. The inverter has internal sequence function.									
	Slip compensation	The inverter output frequency is controlled according to the load torque to keep motor speed constant. When the value is set at "0.00" and "Torque-vector" is set at "active", the compensation value is automatically set. Slip compensation can be preset for the second motor.									
	Droop operation	The motor speed droops in proportional to output torque (-9.9 to 0.0Hz).									
	Torque limiting										
	Torque inflitting	When the motor torque reaches a preset limiting level, this function automatically adjusts the output frequency to prevent the inverter from tripping due to an overcurrent. Torque limiting 1 and 2 can be individually set, and are selectable with a digital input signal.									
	Torque control	Output torque (or load factor) can be controlled with an analog input signal.									
	PID control	This function can control flow rate pressure, etc. (with an analog feedback signal.) Reference KEYPAD operation (

NOTES: (*) Option *1) For application at 120Hz or above, please contact IMO. *2) Inverter may automatically reduce carrier frequency, in accordance with ambient temperature or output current for protection purposes. *3) The minimum carrier frequency changes depending on maximum output frequency.



Common specification continued

	Item	Explanation								
Control	Automatic deceleration	• In constant speed operation : Based on regenerative energy, the frequency is	ed up to 3 times the setting time for tripless operation even if braking resistor not use							
	Second motor's setting	This function is used for two motors switching operation. • The second motor's V/f characteristics (base and maximum fr. • The second motor's circuit parameter can be preset. Torque-ve								
	Energy saving operation	This function minimises inverter and motor losses at light load.								
	Fan stop operation	This function is used for silent operation or extending the fan's lif	lifetime.							
	Universal DI	Transmits to main controller of LINK operation.								
	Universal DO	Outputs command signal from main controller of LINK operation.								
	Universal AO	Outputs analog signal from main controller of LINK operation.								
	Zero speed control (*)	The motor speed is controlled with the speed reference of zero –	(holding torque)							
	• • • • • • • • • • • • • • • • • • • •	· · · · · · · · · · · · · · · · · · ·	(0 1 /							
	Positioning control (*)	The SY option card can be used for positioning control by differe								
lication	Synchronised operation (*)	The function controls the synchronised operation between 2 axes								
	Operating mode (Running)	LED monitor	LCD monitor (English, German, French, Spanish, Italian, Japane							
		Output frequency 1 (before slip compensation) (Hz)	Operation monitor and alarm monitor							
		Output frequency 2 (after slip compensation) (Hz)	Operation monitor							
		Setting frequency (Hz)	Displays operation guidance							
		Output current (A)	Bargraph:							
		Output voltage (V)	Output frequency (%), output current (A), output torque (%)							
		Motor synchronous speed (r/min)	Alarm monitor							
		Line speed (m/min)	The alarm data is displayed when the inverter trips.							
		Load shaft speed (r/min)								
		Torque calculation value (%)	Function setting and monitor							
		• Input power (kW)	Function setting							
		PID reference value ("F01")	Displays function codes and its data or data code, and							
		PID reference value (TOT) PID reference value (Remote) ("C30")	changes the data value.							
		, , , ,	Operation condition							
		PID feedback value	Output frequency (Hz) Motor synchronous speed (r/min)							
		 Trip history: Cause of trip by code (even when main power supply is off, trip history data of the last 4 trips are retained). 	Output current (A) Load shaft speed (r/min)							
	Ctonning		Output voltage (V) Line speed (m/min)							
	Stopping	Selected setting value or output value	Torque calculation value (%) • PID reference value							
	Trip mode	Displays the cause of trip by codes as follows.	Setting frequency (Hz) PID feedback value							
		OC1 (Overcurrent during acceleration)	Operation condition Driving torque limiter setting value (%)							
		OC2 (Overcurrent during deceleration)	(FWD/REV, IL, VL/LU, TL) • Braking torque limiter setting value (%)							
		OC3 (Overcurrent running at constant speed)	Tester function							
		EF (Ground fault)	(I/O check)							
		Lin (Input phase loss)	• Digital I/O: ■ (ON), □ (OFF)							
		FUS (Fuse blown)	 Analog I/O: (V), (mA), (H), (p/s) 							
		OU1 (Overvoltage during acceleration)	Maintenance data							
		OU2 (Overvoltage during deceleration)	Operation time (h) Cooling fan operation time (h)							
		OU3 (Overvoltage running at constant speed)	DC link circuit voltage (V) Communication error times							
		• LU (Undervoltage)	Temperature of inside air (°C) (KEYPAD, RS485, Option)							
		OH1 (Overheating at heat sink)	Temperature of heat sink (°C) ROM version							
		OH2 (External thermal relay tripped)	Maximum current (A) (Inverter, KEYPAD, Option)							
		OH3 (Overtemperature of inside air)	Main circuit capacitor life (%)							
			Control PC board life (h)							
		dBH (Overheating of DB circuit)	Load factor calculation							
		OL1 (Motor 1 overload)	Measurement time (s) Average current (A)							
		OL2 (Motor 2 overload)	Maximum current (A) Average braking power (%)							
		OLU (Inverter unit overload)	Alarm data							
		OS (Overspeed)	Output frequency (Hz) Temperature of inside air (°C)							
		PG (PG error)	Output current (A) Heat sink temperature (°C)							
		• Er1 (Memory error)	Output voltage (V) Communication error times							
		Er2 (KEYPAD panel communication error)	Torque calculation value (%) (KEYPAD, RS485, Option)							
		• Er3 (CPU error)	Setting frequency (Hz) Digital input terminal condition							
		• Er4 (Option error)	Operation condition (Remote, communication)							
		• Er5 (Option error)	(FWD/REV, IL, VL/LU, TL) • Transistor output terminal condition							
		Er7 (Output phase loss error, impedance imbalance)								
			Operation time (h) Trip history code DC link circuit voltage (A) Multiple alarm occurrence							
		• Er8 (RS485 error)	DC link circuit voltage (V) Multiple alarm occurrence lamp is ON.							

vxm/03/03 www.imopc.com




Common specification continued


	Item	Explanation								
Protection	Overload	Protects the inverter by electronic thermal and detection of inverter temperature.								
	Overvoltage	Detects DC link circuit overvoltage, and stops the inverter. 400V series: 800VDC.								
	Undervoltage	Detects DC link circuit undervoltage, and stops the inverter. 400V series: 400VDC.								
	Input phase loss	Phase loss protection for power line input.								
	Overheating	Protects the inverter by detection of inverter temperature.								
	Short-circuit	Short-circuit protection for inverter output circuit.								
	Ground fault	 Ground fault protection for inverter output circuit (3 phase current detection method). Zero-phase current detection method (30kW or larger). 								
	Motor overload	 Electronic thermal overload relay can be selected for standard motor or inverter rated motor. Thermal time constant (0.5 to 75.0 minutes) can be preset for a special motor. The second motor's electronic thermal overload relay can be preset for 2-motor changeover operation. 								
	DB resistor overheating	 Prevents DB resistor overheating by internal electronic thermal overload relay (7.5kW or smaller). Prevents DB resistor overheating by external thermal overload relay attached to DB resistor (11kW or larger). (The inverter stops discharge operation to protect the DB resistor). 								
	Stall prevention	 Controls the output frequency to prevent (overcurrent) trip when the output current exceeds the limit value during acceleration. Lowers the output frequency to hold almost constant torque when the output current exceeds the limit value during operation at constant speed. Controls the output frequency to prevent (overvoltage) trip when the DC link circuit voltage exceeds the limit value during deceleration. 								
	Output phase loss	When the inverter executes auto-tuning, detects each phase impedance imbalance and displays an Error code.								
	Motor protection by PTC thermistor	When the motor temperature exceeds allowable value, the inverter trips automatically.								
	Auto reset	When the inverter is tripped it can be set to automatically reset and start.								
Condition	Installation location	Free from corrosive gases, flammable gases, oil mist, dusts and direct sunlight. Indoor use only.								
(Installation and	Altitude	1000m or less. Applicable to 3000m with power derating (-10%/1000m).								
operation)	Ambient temperature	-10 to +50°C. For inverters of 22kW or smaller, remove the ventilation covers when operating it at a temperature of 40°C or above.								
	Ambient humidity	5 to 95%RH (non-condensing).								
	Vibration	3mm from 2 to less than 9Hz, 9.8m/s² from 9 to less than 20Hz 2m/s² from 20 to less than 55Hz, 1m/s² from 55 to less than 200Hz								
Storage cor	ndition	Temperature: -25 to +65°C, Humidity: 5 to 95%RH (non-condensing)								

Basic wiring diagram

Terminal arrangement

• Main circuit terminals





Control circuit terminals





Terminal functions continued

	Symbol	Terminal name	Function	Remarks	Func. code
Main circuit	L1/R, L2/S, L3/T	Power input	Connect a 3 phase power supply		
	U, V, W	Inverter output	Connect a 3 phase induction motor		
	P1, P(+)	For DC REACTOR	Connect the DC REACTOR for power-factor correcting or harmonic current reducing	DC REACTOR: Option	
	P(+), N(-)	For BRAKING UNIT	Connect the BRAKING UNIT (option) Used for DC bus connection system	BRAKING UNIT (Option): 11kW or larger	
	P(+), DB	For EXTERNAL BRAKING RESISTOR	Connect the EXTERNAL BRAKING RESISTOR (option)	Only for 7.5kW or smaller	
	⊕ G	Grounding	Ground terminal for inverter chassis (housing)		
	R0, T0	Auxiliary control power supply	Connect the same AC power supply as that of the main circuit to back up the control circuit power supply	0.75kW or smaller: Not applicable	
Analog input	13	Potentiometer power supply	+10VDC power supply for frequency setting POT (POT: 1 to $5k\Omega$)	Allowable maximum output current: 10mA	
	12	Voltage input	• 0 to +10VDC/0 to 100% (0 to +5VDC/0 to 100%) • Reversible operation can be selected by function setting. 0 to ±10VDC/0 to ±100% (0 to ±5VDC/0 to ±100%) • Inverse mode operation can be selected by function setting or digital input signal +10 to 0VDC/0 to 100%	Input impedance: 22kΩ Allowable maximum input voltage: ±15VDC If input voltage is 10 to 15VDC, the inverter estimates it to 10VDC If input voltage is 10 to 15VDC, the inverter estimates it to 10VDC	F01, C30
		(Torque control)	Used for torque control reference signal		H18
		(PID control)	Used for PID control reference signal or feedback signal		F01, H21
		(PG feedback)	Used for reference signal of PG feedback control (option)		-
	C1	Current input	4 to 20mA DC/0 to 100% Inverse mode operation can be selected by function setting or digital input signal. 20 to 4mA DC/0 to 100%	Input impedance: 250kΩ Allowable maximum input current: 30mA DC If input current is 20 to 30mA DC, the inverter estimates it to 20mA DC	
		(PID control)	Used for PID control reference signal or feedback signal		F01, H21
		(PTC-Thermistor input)	The PTC-thermistor (for motor protection) can be connected to terminal C1-11	Change over the PIN switch on control board (SW2: PTC)	H26, H27
	V2	Voltage input 2	0 to +10VDC	Can't change over the terminal C1	F01
Digital	11 FWD	Common Forward operation	Common for analog signal FWD: ON The motor runs in the forward direction	Isolated from terminal CMY and CM When FWD and REV are simultaneously ON, the	F02
input	REV	command Reverse operation	REV: ON The motor duris in the loward affection REV: ON The motor runs in the reverse direction	decelerates and stops	FU2
		command	REV: OFF The motor decelerates and stops		
	X1	Digital input 1	These terminals can be preset as follows	ON state maximum input voltage: 2V	E01 to E09
	X2	Digital input 2		(maximum source current: 5mA) • OFF state maximum terminal voltage: 22 to 27V	
	X3 X4	Digital input 3 Digital input 4	-	(allowable maximum leakage current: 0.5mA)	
	X5	Digital input 5			
	X6	Digital input 6			
	X7	Digital input 7			
	X8	Digital input 8			
	Х9	Digital input 9			
	(SS1) (SS2) (SS4) (SS8)	Multistep freq. selection	(SS1) : 2 (0,1) different frequencies are selectable (SS1, SS2) : 4 (0 to 3) different frequencies are selectable (SS1, SS2, SS4) : 8 (0 to 7) different frequencies are selectable (SS1, SS2, SS4, SS8) : 16 (0 to 15) different frequencies are selectable	Frequency 0 is set by F01 (or C30) (All signals of SS1 to SS8 are OFF)	C05 to C19
	(RT1) (RT2)	ACC/DEC time selection	(RT1 : 2 (0, 1) different ACC/DEC times are selectable (RT1, RT2) : 4 (0 to 3) different ACC/DEC times are selectable	Time 0 is set by F07/F08 (All signals of RT1 to RT2 are OFF)	F07, F08 E10 to E15
	(HLD)	3 wire operation stop command	Used for 3 wire operation (HLD): ON The inverter self-holds FWD or REV signal (HLD): OFF The inverter releases self-holding	Assigned to terminal X7 at factory setting	
	(BX)	Coast-to-stop command	(BX): ON Motor will coast-to-stop. (No alarm signal will be output)	The motor restarts from OHz by turning off BX with the operation command (FWD or REV) ON Assigned to terminal X8 at factory setting	H11
	(RST)	Alarm reset	(RST): ON Faults are reset. (This signal should be held for more than 0.1s)	During normal operating, this signal is ignored Assigned to X9 at factory setting	
	(THR)	Trip command (External fault)	(THR): OFF "OH2 trip" occurs and motor will coast-to-stop	This alarm signal is held internally	
	(JOG)	Jogging operation	(JOG): ON JOG frequency is effective	This signal is effective only while the inverter is stopped	C20
	(Hz2/Hz1)	Freq. set 2/Freq. set 1	(Hz2/Hz1): ON Freq. set 2 is effective	If this signal is changed while the inverter is running the signal is effective only after the inverter stops	C30/F01
	(M2/M1)	Motor 2/Motor 1	(M2/M1): ON The motor circuit parameter and V/f characteristics are changed to the second motor's ones	If this signal is changed while the inverter is running	A10 to A18/
	(DCBRK)	DC brake command	(DCBRK): ON The DC injection brake is effective. (In the inverter deceleration mode)	the signal is effective only after the inverter stops If the operation command (FWD/REV) is input while DC braking is effective, the operation command (FWD/REV) has priority	P01 to P09 F20 to F22
	(TL2/TL1)	Torque limiter 2/ Torque limiter 1	(TL2/TL1): ON Torque limiter 2 is effective	to enecuve, the operation continuity (FWD/NEV) has phonty	E16, E17/ F40, F41
	(SW50)	Switching operation between line and inverter	(SW50(SW60)): ON The motor is changed from inverter operation to line operation	Main circuit changeover signals are output through	140,141
	(SW60) (UP)	UP command	(SW50(SW60)): OFF The motor is changed from line operation to inverter operation (UP): ON The output frequency increases	Y1 to Y5 terminal When UP and DOWN commands are simultaneously	+
	(DOWN)	DOWN command	(DOWN): ON The output frequency decreases The output frequency change rate is determined by ACC/DEC time Restarting frequency can be selected from OHz or setting value at the time of stop	ON, DOWN signal is effective	F01, C30
	(WE-KP)	Write enable for KEYPAD	(WE-KP): ON The data is changed by KEYPAD		F00
	(Hz/PID)	PID control cancel	(Hz/PID): ON The PID control is cancelled, and frequency setting by KEYPAD (■■ or ■■) is effective		H20 to H25
	(IVS)	Inverse mode changeover	(IVS): ON Inverse mode is effective in analog signal input the signal is effective only after the inverter stops	If this signal is changed while the inverter is running	F01, C30
	(IL)	Interlock signal for 52-2	Connect to auxiliary contact (1NC) of 52-2		
	(Hz/TRQ)	TRQ control cancel	(Hz/TRQ): ON The torque control is cancelled, and ordinary operation is effective		H18
	(LE)	Link enable (RS485, Bus)	(LE): ON The link operation is effective. Used to switch between manual operation and serial link auto mode	RS485: Standard, Bus: option	H30
	(U-DI)	Universal DI	This signal is transmitted to main controller of LINK operation		1
	(STM)	Pick up start mode	(STM): ON The "Pick up" start mode is effective		H09

www.imopc.com



Terminal functions continued


	Symbol	Terminal name	Function	Remarks	Func. code
Digital input	(PG/Hz)	SY-PG enabled	(PG/Hz): ON Synchronised operation or PG-feedback operation is effective	Option	
прис	(SYC)	Synchronised command	(SYC): ON The motor is controlled for synchronised operation between 2 axes with PGs	Option	
	(ZERO)	Zero speed command	(ZERO): ON The motor speed is controlled with the speed reference of zero	This function can be selected at PG feedback control. Option	
	(STOP 1)	Forced stop command	(STOP 1): OFF The motor decelerates and stops		
	(STOP 2)	Forced stop command with Deceleration time 4	(STOP 2): OFF The motor decelerates and stops with Deceleration time 4		E15
	(EXITE)	Pre-exciting command	(EXITE): ON Motor magnetic flux is established before starting in PG vector mode		
	PLC	PLC terminal	Connect PLC power supply to avoid malfunction of the inverter that has SINK type		
	P24	DC voltage cumply	digital input, when PLC power supply is off DC voltage supply (+24V, maximum 100mA)		
Analog	FMA	DC voltage supply Analog monitor	Output voltage (0 to 10VDC) is proportional to selected function's value as follows.	Allowable maximum output current: 2mA	F30 to F31
output	(11)	(Common)	The proportional coefficient and bias value can be preset.	Allowable maximum output current. Zim	130 10101
Pulse	FMP	Pulse rate monitor	Pulse rate mode: Pulse rate is proportional to selected function's value* (50% duty pulse)	Allowable maximum output current: 2mA	F33 to F35
Output	(011)		Average voltage mode: Average voltage is proportional to selected function's value* (2670p/s pulse width control)		
	(CM)	(Common)	Function to be output is same as those of analog output (FMA) Common for pulse output	Isolated from terminal CMY and 11	
Transistor	Y1	Common Transistor output 1	Common for pulse output Output the selected signals from the following items		E20 to E23
output	Y2	Transistor output 2	output the selected signals from the following femis	ON state maximum output voltage: 3V (Allowable maximum sink current: 50mA)	220 10 120
	Y3	Transistor output 3		OFF state maximum leakage current: 0.1mA	
	Y4	Transistor output 4		(Allowable maximum voltage: 27V)	
	(RUN)	Inverter running	Outputs ON signal when the output frequency is higher than starting frequency		
	(FAR)	Frequency equivalence	Outputs ON signal when the difference between output frequency and setting frequency is		E30
	(FDT1)	signal Frequency level detection	smaller than FAR hysteresis width Outputs ON signal by comparison of output frequency and preset value (level and hysteresis)		E31, E32
	(LU)	Undervoltage detection signal	Outputs ON signal when the inverter stops by undervoltage while the operation command is ON.		L31, L32
	(B/D)	Torque polarity	Outputs ON signal in braking or stopping mode, and OFF signal in driving mode		
	(TL)	Torque limiting	Output ON signal when the inverter is in torque-limiting mode		
	(IPF)	Auto-restarting	Outputs ON signal during auto restart operation (Instantaneous power failure) mode. (Including "restart time")		
	(OL1)	Overload early warning	Outputs ON signal when the electronic thermal value is higher than preset alarm level		E33 to E35
	` ,		Outputs ON signal when the output current value is higher than preset alarm level		
	(KP)	KEYPAD operation mode	Outputs ON signal when the inverter is in KEYPAD operation mode		F02
	(STP) (RDY)	Inverter stopping Ready output	Outputs ON signal when the inverter is in stopping mode or in DC braking mode Outputs ON signal when the inverter is ready for operation		
	(SW88)	Line/Inv changeover	Outputs 88's ON signal for Line/Inverter changeover operation		
	(SW52-2)	(for 88) Line/Inv changeover (for 52-2)	Outputs 52-2's ON signal for Line/Inverter changeover operation		
	(SW52-1)	Line/Inv changeover (for 52-1)	Outputs 52-1's ON signal for Line/Inverter changeover operation		
	(SWM2)	Motor2/Motor1	Outputs the motor changeover switch ON signal from motor 1 to motor 2		A01 to A18
	(AX)	Auxiliary terminal	Used for auxiliary circuit of 52-1	Refer to wiring diagram example	
	(TII)	(for 52-1)	(Same function as AX1, AX2 terminal Jaguar VX series. (30kW or larger)		004 1: 000
	(TU) (TO)	Time-up signal Cycle completion signal	Outputs time up signal (100ms ON pulse) at every stage end of PATTERN operation Outputs one cycle completion signal (100ms ON pulse) at PATTERN operation		C21 to C28
	(STG1) (STG2) (STG4)	Stage No. indication 1 Stage No. indication 2 Stage No. indication 4	Outputs Pattern operation's stage No. by signals STG1, STG2 and STG4		
	(AL1) (AL2) (AL4) (AL8)	Alarm indication 1 Alarm indication 2 Alarm indication 4 Alarm indication 8	Outputs trip alarm No. by signals AL1, AL2, AL4 and AL8		
	(FAN)	Fan operation signal	Outputs the inverter cooling fan operation status signal		H06
	(TRY)	Auto-resetting	Outputs ON signal at auto resetting mode. (Including "Reset interval")		H04, H05
	(U-D0) (OH)	Universal DO Overheat early warning	Outputs command signal from main controller of Link operation Outputs ON signal when the heat sink temperature is higher than (trip level – 10°C) and		
	(SY)	Synchronisation completion signal	outputs OFF signal when the temperature is lower than (trip level – 15°C) Synchronisation completion signal for synchronised operation	Option	
	(LIFE)	Lifetime alarm	Outputs ON signal when the calculated lifetime is longer than preset alarm level		
	(FDT2)	2nd Freq. level detection	2nd outputs ON signal by comparison of output frequency and preset value (FDT2 level)		
	(0L2)	2nd OL level early warning	2nd outputs ON signal when the output current value is larger than preset alarm level (OL2 level)		
	(C10FF)	Terminal C1 off signal	Outputs ON signal when the C1 current is smaller than 2mA		
	(N-EX) CMY	Speed existence signal Common (transistor	Outputs ON signal when motor speed is larger than stop speed* on vector control with PG Common for transistor output signal	*stop speed = stop frequency (F25) x 120/pole (r/m) Isolated from terminals CM and 11	F25
		output)	. ,		
Relay	30A, 30B	Alarm relay output	Outputs a contact signal when a protective function is activated	Contact rating:	F36
			Lance 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		
output	30C	D.I.	Changeable exciting mode active or non-exciting mode active by function "F36"	250VAC, 0.3A, cosø=0.3	E24
		Relay output	Changeable exciting mode active or non-exciting mode active by function "F36" Functions can be selected the same as Y1 to Y4 Changeable excitation mode active or non-excitation mode active by function "E25"	250VAC, 0.3A, cosø=0.3 48VDC, 0.5A, non-inductive	E24 E25

vxw/03/03 www.imopc.com



External signal input operation

The following diagram is for reference only. For detailed wiring diagrams, refer to the relevant instruction manual.



NOTE:

Digital inputs can be source or sink depending on position of switch SW1 on control PCB. Do not connect (P24) to (CM) as shown or damage may occur.

*Option

- *1) Use the inverter whose rated input voltage matches the power supply voltage.
- *2) An optional device. Use it when necessary.
- *3) Use this peripheral device when necessary.
- *4) Terminals (P1) and (P(+)] are connected with a jumper wire before shipping. When connecting an optional DC reactor (DCR) *9), remove the jumper wire that connects the terminal (P1) and (P(+)].
- *5) For models from 0.2 to 7.5kW, a built-in braking resistor (DBR) is connected to the inverter before shipping. (DBR is not mounted on models 11kW or larger.) When connecting an optional external braking resistor (DB), remove the DBR connection cables from (P(+)] and (DB) terminals. The end of the removed cables (indicated with an X) must be insulated.
- *6) When connecting an optional external braking resistor (DB), be sure to also use an optional braking unit *8). Connect the optional braking unit to the (P(+)] and (N(-)] terminals. Auxiliary terminals (1) and (2) have polarity.
 - Be sure to connect cables to these terminals correctly. (See the diagram).
- *7) Terminals (R0) and (T0) are provided for models 1.5kW or larger. These terminals are not provided for models 0.75kW or smaller. Even if these terminals are not powered, the invertor can be operated.
- *8) For EMC compliance it is necessary to use screened/armoured cable between inverter U, V, W terminals and the motor. The screen should be terminated to earth at both ends of the cable. The appropriate power supply filter kit may also be fitted to the inverter input circuit. For further details contact IMO.



Protective functions

Function	Description			LED monitor
Overcurrent protection (Short-circuit)	Stops running to protect inverter from an overcurrent resulting from overload. Stops running to protect inverter from an overcurrent due to a short-circuit in the output circuit.		During acceleration During	00 1
(Earth fault)			deceleration	002
	 Stops running to protect inverter from an overcurrent due to an earth fault in the output circuit. 		While running at constant speed	003
	Stops running to protect inverter from an overcurrent resulting from earth fault in the output circuit by detecting zero-phase current.	30kW or larger model only	Earth	EF
Overvoltage protection	The inverter stops when it detects an overvoltage in the DC link circuit.	400V series: 800VDC or more	During acceleration	ו טם
,		Protection is not assured if excess AC line voltage is	During deceleration	002
		applied inadvertently.	While running at constant speed	003
Incoming surge protection	Protects the inverter against surge voltage between the main circuit power line and earth. Protects the inverter against surge voltage in the main circuit power line.	The inverter may be tripped I protective function.	by some other	
Undervoltage protection	Stops the inverter when the DC link circuit voltage drops below undervoltage level.	400V series : 400VDC or les 200V series : 200VDC or les		LU
Input phase loss protection	The inverter is protected from being damaged when open-phase fault occurs.			Lin
Overheat protection	Stops the inverter when it detects excess heat sink temperature in case of cooling fan failure or overload.			OH I
	Stops the inverter when it detects an abnormal rise in temperature in the inverter unit caused by insufficient ventilation in cubicles or an abnormal ambient temperature. Stops the inverter when it detects an abnormal rise in temperature inside the inverter.			0H3
	When the built-in braking resistor overheats, the inverter stops discharging and running. Function data appropriate for the resistor type (built-in/external) must be set.	7.5kW or smaller model only		аьн
Electronic thermal	This function stops the inverter by detecting an inverter overload.			OLU
overload relay (Motor protection)	This function stops the inverter by detecting an overload in a standard motor or inverter motor.		Motor 1 overload Motor 2 overload	01.5 01.1
Fuse blown	When a blown fuse is detected, the inverter stops running.	30kW or larger model only		FUS
Stall prevention (Momentary overcurrent limitation)	When an output current exceeds the limit during acceleration, this function lowers output frequency to prevent an OC1 trip.	The stall prevention function	can be disabled.	
Active drive	During running in which acceleration is 60s or longer, this function increases the acceleration time to prevent the occurrence of an OLU trip.	The acceleration time can be three times the preset time.	prolonged up to	
External alarm input	The inverter stops on receiving external alarm signals.	Use THR terminal function (continuous)	ligital input).	0H2
Overspeed protection	 Stops the inverter when the output frequency exceeds the rated maximum frequency by 20%. 			05
PG error	Alarm output if encoder (PG) signals are disconnected.			PG
Alarm output (for any fault)	The inverter outputs a relay contact change over signal.	Output terminals: 30A, 30B a Use the RST terminal function	n for signal input.	
Alarm reset command	An alarm-stop state of the inverter can be cleared with the RESET key or by a digital input signal (RST).	Even if main power input is thistory and trip-cause data a		
Alarm history memory	Stores up to four previous alarm conditions.	_		
Storage of data on cause of trip	The inverter will store and display details of the latest alarm history data.			
Memory error	The inverter checks memory data after power-on and when the data is written. If a memory error is detected, the inverter trips.			Erl
KEYPAD panel communication error	If an error is detected in communication between the inverter and KEYPAD when the Keypad panel is being used, the inverter trips.	When operated by external sig continues running. The alarm fault) is not output. Only Er2 is	output (for any	Er2
CPU error	If the inverter detects a CPU error caused by noise or some other factor, the inverter trips.			Er3
Option communication error	If a checksum error or disconnection is detected during communication, the inverter issues an alarm.			Er4
Option error	If a linkage error or other option error is detected, the inverter issues an alarm.			Er5
Output phase loss error	If an unbalance of output circuits is detected during auto-tuning, this function issues an alarm (and trips the inverter).			Er7
RS485 communication error	If an RS485 communication error is detected, the inverter issues an alarm.			E-8


NOTES:

- Retaining alarm signal when auxiliary control power supply is not used:
 If the inverter power supply is cut off while an internal alarm signal is being output, the alarm signal cannot be retained.
- 2) To issue the RESET command, press the key on the KEYPAD panel or connect terminals RST and P24 and disconnect them afterwards.
- 3) Fault history data is stored for the past four trips.



External dimensions

Fig 1



Туре	D	D4	D5
VXM40	130	36.5	80
VXM75	145	51.5	95

Fig 2 VXM150 → VXM400





Fig 3 VXM550 → VXM750








Fig 4 VXM1100 → VXM2200G








External dimensions continued

Fig 5




Power	Nominal	Tuno	Dimensions (mm)														
supply voltage	applied motor (kW)	Туре	W	W1	W2	Н	H1	H2	Н3	H4	H5	Н6	D	D1	D2	C	Mtg. Bolt
400V	30/37	VXM30K/VXM30KP	340	240	326	CAE	E20	500	E40				255				
	37/45	VXM37K			361	645	530	500	512	12	25		270	145		10	MO
	45/55	VXM45K	375	275		770	655	625	637	12	25	9	270	145		10	M8
	55/75	VXM55K	3/3			170	000	020	037								
	75/90	VXM75K]			835	720	690	702						4		
	90/110	VXM90K		400	510	827.5	710	675	685				315	175	4		
	110/132	VXM110K	530				/ 10	0/3	075 005				313	1/3			
	132/160	VXM132K	330	430							32.5	12.5				15	M12
	160/200	VXM160K]			- -1087.5	970	935	945	15.5		12.3	360	220		15	IVITZ
-	200/220	VXM200K				1007.3	970	933	940	13.5			300	220			
	220/280	VXM220K	600	E00	cco												
	280/315	VXM280K	680	580	660	1400	1270	1220	1240		35	1/15	450	285	6.4	1	
	315/355	VXM315K	1			1400	1370	1330	1340		33	14.5	450	200	6.4		

www.imopc.com VXM/03/03



Options


EMC filters (typical)





Inverter type	Filter	Rated	F1	Dimensions (mm)									
(and use)	required	current (A)	Fig.	w	W1	Н	H1	H2	НЗ	D			
VXM40-75	RFM75FP	5		116	90	310	293	265	10	42			
VXM150-400	RFM400FP	12		155	105	310	293	265	10	45			
VXM550-750	RFM750FP	35	Α	225	167	331	311	260	10	47.5			
VXM1100-1500	RFM1500FP	50		250	185	480	449	400	20	70			
VXM1850-2200G	RFM2200FP	72		250	185	480	449	400	20	70			
VXM30K (CT) -30KP	RFM30K	100		200	166	435	408	-	-	130			
VXM30K (VT) -90K (CT)	RFM90K	180	В	200	166	495	468	-	-	160			
VXM90K (VT) -132K (CT)	RFM132K	280		250	170	587	560	-	-	205			
VXM132K (VT) -220K (CT)	RFM220K	400	С	250	170	587	560	-	-	205			
VXM220K (VT) -315K	RFM315K	880	*	364	300	688	648	-	-	180			

^{*} See Jaguar VXM instruction manual or contact IMO for details

DC reactors (typical)







Power supply	Nominal	Reactor		Typical dimensions, mm								Typical	
voltage	applied motor (kW)	type	Fig. A	В	C	D	E	F	G	H Ter	ninal sc	rew (kg)	mass
Three phase 400V	0.4	*	Α	66	56	72	90	60	35	5.2 x 8	94	M4	1.0
	0.75	*	Α	66	56	72	90	60	40	5.2 x 8	94	M4	1.4
	1.5	*	Α	66	56	72	90	60	45	5.2 x 8	94	M4	1.6
	2.2	*	Α	86	71	80	100	65	45	6 x 9	110	M4	2.0
	4.0	*	Α	86	71	80	100	70	50	6 x 9	110	M4	2.6
	5.5	*	Α	86	71	80	100	70	50	6 x 9	110	M4	2.6
	7.5	*	Α	111	95	80	100	75	60	7 x 11	130	M5	4.2
	11	VXLC11	Α	111	95	80	100	75	60	7 x 11	130	M5	4.3
	15	VXLC15	Α	146	124	96	120	75	60	7 x 11	171	M5	5.9
	18.5	VXLC18	Α	146	124	96	120	85	65	7 x 11	171	M6	7.2
	22	VXLC22	Α	146	124	96	120	85	65	7 x 11	171	M6	7.2
	30	VXLC30	В	152	90	115	157	100	78	8	130	M8	13
	37	VXLC37	В	171	110	110	150	100	75	8	150	M8	15
	45	VXLC45	В	171	110	125	165	110	82	8	150	M8	18
	55	VXLC55	В	171	110	130	170	110	85	8	150	M8	20
	75	VXLC75	С	190	160	115	151	100	75	10	240	M10	20
	90	VXLC90	С	190	160	125	161	120	80	10	250	ø12	23
	110	VXLC110	С	190	160	125	161	120	80	10	250	ø12	25
	132	VXLC132	С	200	170	135	171	120	85	10	260	ø12	28
	160	VXLC160	С	210	180	135	171	120	85	12	290	ø12	32
	200	VXLC200	С	210	180	135	171	140	90	12	295	ø12	35
	220	VXLC220	С	220	190	135	171	140	90	12	300	ø15	40
	280	VXLC280	С	220	190	145	181	150	95	12	320	ø15	45
	315	VXLC315			1		1	Avai	lable so	on		1	

NOTE:

vxm/03/03 www.imopc.com

⁽¹⁾ A DC reactor must be used for 75kW and above.

⁽²⁾ The above drawings, masses and dimensions are intended as a guide only. Product details may be subject to change without prior notice. If in doubt contact IMO Ltd.

^{*}Please contact IMO for details.




Options continued

Braking unit, braking resistor

Power		Inv	erter			Op	tion	СТ	Continuous braking (100% torque conversion value)		Repetitive braking (100s or less cycle)		VT		ous braking king torque)		itive braking or less cycle)	
supply	Constan	t Torque Rating (CT)	Variabl	e Torque Rating (VT)	Braking	J	Brakin		Max. braking	Braking	Discharging	Duty	Average	Max. braking	Braking	Discharging	Duty	Average
voltage	Motor (kW)	Inverter type	Motor (kW)	Inverter type	Unit Type	Qty	resisto Ω(min)	kW	torque (%)	time (s)	capability (kWs)	cycle (%)	loss (kW)	torque (%)	time (s)	capability (kWs)	cycle (%)	loss (kW)
Three-	0.4	VXM40			-	1	200	0.2		45	9	22	0.044					
phase 400V	0.75	VXM75			_	1	200	0.2	1	45	17	18	0.068					
4007	1.5	VXM150] -	_	-	1	160	0.4	1	45	34	10	0.075	-	-	-	-	_
	2.2	VXM220			-	1	160	0.4	1	30	33	7	0.077					
	4.0	VXM400			-	1	130	0.4	1	20	37	5	0.093		15	37	3.5	0.093
	5.5	VXM550	7.5	VXM550	-	1	80	0.8	150%	20	55	5	0.138		15	55	3.5	0.138
	7.5	VXM750	11	VXM750	-	1	60	0.9	1	10	38	5	0.188		7	38	3.5	0.188
	11	VXM1100	15	VXM1100		1	40	1.4	1	10	55	5	0.275	100%	7	55	3.5	0.275
	15	VXM1500	18.5	VXM1500	VXDBU	1	35	1.4	1	10	75	5	0.375		8	75	4	0.375
	18.5	VXM1850	22	VXM1850	11-22	1	27	1.8	l	10	93	5	0.463		8	93	4	0.463
	22	VXM2200G	-	-		1	22	1.8		8	88	5	0.55		6	88	3	0.55
	-	_	30	VXM30KP	VXDBU	1	15	3.6	-	_	-	-	-		10	150	10	1.5
	30	VXM30K	37	VXM30K	30-37	1	15	3.6		10	150	10	1.5		10	150	10	1.5
	37	VXM37K	45	VXM37K		1	12	4.8	l	10	185	10	1.85		10	185	10	1.85
	45	VXM45K	55	VXM45K	VXDBU	1	10	6	l	10	225	10	2.25		10	225	10	2.25
	55	VXM55K	75	VXM55K	45-55	1	7.5	7.2	1	10	275	10	2.75		10	275	10	2.75
	75	VXM75K	90	VXM75K	VXDBU	1	6	9.6	100%	10	375	10	3.75		10	375	10	3.75
	90	VXM90K	110	VXM90K	75-90	1	5	12	l	10	450	10	4.5	75%	10	450	10	4.5
	110	VXM110K	132	VXM110K	VXDBU	1	3.75	14.4	1	10	550	10	5.5		10	550	10	5.5
	132	VXM132K	160	VXM132K	110-132	1	3.33	18	l	10	660	10	6.6		10	660	10	6.6
	160	VXM160K	200	VXM160K	VADBII	1	3.0	19.2	1	10	800	10	8.0		10	800	10	8.0
	200	VXM200K	220	VXM200K	VXDBU	1	2.5	24	l	10	1000	10	10.0		10	1000	10	10.0
	220	VXM220K	280	VXM220K	160-220	1	1.88	28.8	1	10	1100	10	11.0		10	1100	10	11.0
	280	VXM280K	315	VXM280K														
	315 VXM315K 400 VXM315K					Available soon												

NOTE:

The braking time and duty cycle (%) are calculated as the constant-torque braking used for deceleration.



• Duty cycle (%) =
$$\frac{T1}{T0}$$
 x 100[%]

(Procedure for selecting options)

All three conditions listed below must be satisfied.

- 1. The maximum braking torque does not exceed the value shown in the table.
- The energy discharged in the resistor for each braking (the area of the triangle shown in the above figure) does not exceed the discharging capability (kWs) in the table.
- 3. The average loss (energy discharged in the resistor divided by a braking interval) does not exceed the average loss (kW) shown in the table.



Options continued

Braking unit





Fig. C

Voltage	Туре	Fig.	Dimensions (mm)									
			W	W1	Н	H1	H2	D	D1	(kg)		
	VXDBU 11-22	Α		_	1.1							
	VXDBU 30-37	В	150	100		265	250	160	-	4		
400V	VXDBU 45-55	C	230	130	280				1.2	5.5		
Series	VXDBU 75-90											
	VXDBU 110-132		250	150	370	355	340		0.4	9		
	VXDBU 160-220				450	435	420		2.4	13		

Braking resistors

(typical combinations for heavier duty applications)

Example 1 - DBR160R380W



Example 2 - DBR150R220W

Covers: $VXM40 \rightarrow VXM75$ 150 Ω 220W —



Option Cards and other Options

Name (type)	Function	Specifications	Specifications					
Relay output card (VXMROC)	 Includes four relay output circuits. Converts transistor output signals from inverter control output terminals Y1 to Y4 to relay (1SPDT) output signals. 							
Digital I/O interface card (VXMDIO)	 For setting frequency using a binary code. For monitoring frequency, output current and output voltage using a binary code. For input and output of other individual signals. 							
Analog I/O interface card (VXMAIO)	For setting a torque limit value using an input analog signal. For input of auxiliary signal to set frequency. For analog monitoring of inverter output frequency, output current and torque.							
T-link interface card (OPC-G11S-TL)	 For setting a frequency. For setting and reading function data for function codes. For setting operation commands (FWD, REV, RST, etc.). For monitoring the operation status. For reading trip information. 	Used together with MICREX-F series PLC.						
PG feedback card (VXMEFC)	For performing PG vector control using feedback signals obtained from an encoder.	Applicable P 100 to 3000 12V or 15V						
Synchronised operation card (VXMSYN)	 Wait and synchronise mode, simultaneous start and synchronising mode. Proportional speed operation. Speed control by pulse train input can be made. 							
Extension cable for keypad	Connects the keypad panel to an inverter unit. Three cable types are available: straight 2m, curled 1m and	Туре	Nominal length	Maximum length				
(VXPODCABLE)	curled 2m.	VXPODCABLE	2m	2m				
	The curled 1m cable can be extended up to 5m, and the curled 2m cable up to 10m.	CONTACT IMO	1m	5m				
	Note: Cables once extended to the maximum length do not return to their original length.	CONTACT IMO	2m	10m				
Copy unit (VXMCOPY)	 For batch data transfer (read, store, write) between an inverter unit and the copy unit. For comparison of data stored in an inverter and data stored in the copy unit. For comparison of two sets of data stored in the copy unit. For editing a part of the data stored in an inverter. Write protection is available in copy mode and edit mode. The copy unit can write data to inverter memory even though the inverter is not connected to power source. 	Application						
IP20 enclosure adaptor	Used to put 30kW or larger models to increase enclosure setting from ID00 to ID30	Туре	Applicable inverter type					
	rating from IP00 to IP20.	P20G11-30	VXM30K VXM30KP					
		P20G11-55	VXM37K to VXM55K					
		P20G11-75-4	VXM75K					
		P20G11-75-2	Not Available					
		P20G11-110	VXM90K to VXM110K					
		P20G11-160	VXM132K to VXM160K					
		P20G11-220	VXM200K to VXM220K					
Mounting adaptor for external	Used to put the cooling fan section of the inverter outside	Туре	Applicable inverter type					
cooling	the panel. Only applicable to 22kW and below inverters.	PBG11-0.75	VXM40 to VXM75					
	(30kW and above inverters can be modified to external cooling type by replacing the mounting bracket, as standard.)	PBG11-3.7	VXM150 to VXM400					
		PBG11-7.5	VXM550 to VXM750					
		PBG11-22	22 VXM1100to VXM2200G					
Panel-mount adaptor	Used to mount a Jaguar VXM inverter in panel holes that were	Туре	Type Applicable inverter type					
(MAG9-□□)	used to mount a Fuji G7S inverter.	MAG9-3.7	VXM40 to VXM400					
		MAG9-7.5	VXM550 to VXM750					

vxw/03/03 www.imopc.com



Wiring equipment

Power supply voltage		Inverter type		MCCB or ELCB Rated current (A)		Magnetic contactor (MC)			Recommended wire size (mm²)						
	Nominal applied					MC1 for input circuit		MC2 for	Input circuit		Output circuit		DCR	DB	
	motor (kW)	Constant Torque Rating (CT)	Variable Torque Rating (VT)	With DCR	Without reactor		Without	output circuit	(L1/R, L2/S, L3/T)		(U.V.W.)		circuit	circuit	
							reactor		With DCR	Without reactor	СТ	VT (P1,P(+)	(P1,P(+))	(P(+),DB,N(-))	
Three phase 400V	0.4	VXM40	-		6		MC14-S-10	MC14-S-10	1.5	1.5	1.5	-	1.5	- 1.5	
	0.75	VXM75	-	6											
	1.5	VXM150	-		10	MC14-S-10									
	2.2	VXM220	-	10	16										
	4.0	VXM400	-		10					2.5					
	5.5	VXM550	-	16	20	MC24-S-00	MC24-S-00	MC24-S-00	2.5	4		2.5	2.5		
	7.5	VXM750	VXM550	20	32	101624-3-00				6					
	11	VXM1100	VXM750	32	40	MC32-S-00	MC32-S-00	MC32-S-00	٠.	10	2.5	4	1	1	
	15	VXM1500	VXM1100	40	50	MC40-S-00	MC40-S-00	MC40-S-00	6 10	16	6	6	4		
	18.5	VXM1850	VXM1500		60	14050 0 00	MOEO C 00 MO	MC50-S-00		- 10		10	6		
	22	VXM2200G	VXM1850	50	75	MC50-S-00 MC50-S	MC50-S-00	IMC20-2-00		25		1 10	10	1	
	30	VXM30K	VXM30KP	75	100	MC62-S-00	MC62-S-00	MC62-S-00	16	25	16	16	16	2.5	
	37	VXM37K	VXM30K	100	125	MC74-S-00	MC74-S-00	MC74-S-00	10	35	16	25	1 10		
	45	VXM45K	VXM37K		150	K110A22	K110A22	K110A22	25	50	25	35	25		
	55	VXM55K	VXM45K	125	175	K3150A11	K3150A11	K3150A11	35	70	35	50	35	4	
	75	VXM75K	VXM55K	175		K3150A11 K3175A11 K3315A11 –		K3150A11	50	50 70 95 120 150 240 300	50	70	50	- 6	
	90	VXM90K	VXM75K	200	1				70		70	95	70		
	110	VXM110K	VXM90K	225	- - - -			K3175A11	95		95	120	95	10	
	132	VXM132K	VXM110K	300				K3315A11	120		120	150	120	10	
	160	VXM160K	VXM132K	350			1 -		185		240	185	16		
	200	VXM200K	VXM160K	400		K3450A22	1	K3450A22	300		240	300	300	25	
	220	VXM220K	VXM200K	500				1/0700400	300		300	400			
	280	VXM280K	VXM220K	600		K3700A22	1	K3700A22	500	1	400	-	500		
	315	VXM315K	VXM280K		1	1	-	-		-	I.	1	-	-	
	400		VXM315K	1				,	Available soo	1					

NOTES:

- For moulded-case circuit breakers (MCCB) and earth-leakage circuit breakers (ELCB), the required frame type and series depend on the transformer capacity and other factors. When selecting breakers, refer to IMO, if uncertain.
- Select the current sensitivity of ELCB, with reference to motor cable length and type, and carrier frequency.
- The recommended cable sizes are based on the condition that the temperature inside the panel does not exceeds 50°C.
- The above are 600V PVC insulated (75°C).
- Data in the above table may differ for different conditions (ambient temperature, power supply voltage and other factors).

Caution

 If in doubt, consult local/national wiring regulations such as the relevant IEE Wiring Regulations - latest edition.

vxw/03/03 www.imopc.com